

REDESDALE, Australia

WMO: 948590

Lat: 37.0194S

Lon: 144.5203E

Elev: 951

StdP: 14.20

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.2	33.0	26.8	21.5	60.8	29.3	24.1	52.1	24.9	50.5	21.1	49.3	5.8	200	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	96.2	64.6	91.7	63.8	88.0	63.1	69.2	82.1	67.3	82.5	65.7	81.5	10.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	99.1	71.8	62.9	89.0	70.9	60.5	81.6	69.6	33.9	81.0	32.2	82.6	30.9	81.8	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.4	21.7	18.9	DB	27.7	103.7	1.9	3.9	26.3	106.5	25.2	108.8	24.2	111.0	22.8	113.8
			WB	27.1	72.6	2.0	2.7	25.7	74.6	24.5	76.2	23.4	77.8	21.9	79.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	70.0	69.4	64.5	57.0	50.8	46.7	45.3	46.4	50.0	54.3	60.6	64.9	(6)
(7)		DBStd	10.38	7.47	6.95	6.76	5.58	4.30	3.64	3.31	3.60	4.63	5.94	6.95	7.33	(7)
(8)		HDD50	505	0	0	0	7	43	110	148	121	54	20	2	0	(8)
(9)		HDD65	3632	32	33	94	245	442	550	610	575	451	336	171	93	(9)
(10)		CDD50	2909	621	542	448	218	66	10	4	11	54	154	319	462	(10)
(11)		CDD65	559	188	155	77	6	0	0	0	0	5	38	90	90	(11)
(12)		CDH74	7917	2566	1894	953	101	0	0	0	9	166	679	1549	1549	(12)
(13)		CDH80	3530	1309	858	353	14	0	0	0	0	41	248	707	707	(13)
(14)	Wind	WSAvg	8.6	10.7	10.1	9.2	7.9	7.0	7.1	6.9	7.4	7.8	9.0	9.8	9.9	(14)
(15)	Precipitation	PrecAvg	24.8	1.5	1.7	1.2	1.4	2.0	2.9	2.9	2.6	2.6	2.0	2.2	1.8	(15)
(16)		PrecMax	41.6	7.8	5.5	3.6	3.7	5.0	6.1	5.0	4.5	6.1	5.6	6.7	4.8	(16)
(17)		PrecMin	15.1	0.0	0.1	0.1	0.2	0.1	0.8	0.7	0.3	0.5	0.1	0.7	0.0	(17)
(18)		PrecStd	6.7	1.5	1.5	0.9	0.9	1.3	1.5	1.1	1.3	1.5	1.5	1.4	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.2	100.3	94.3	81.8	69.3	60.9	58.5	64.6	74.0	85.3	92.9	100.1	(19)
(20)			MCWB	65.3	66.6	63.7	59.7	55.1	51.9	51.1	54.2	56.4	58.8	63.7	63.8	(20)
(21)		2%	DB	97.4	93.4	88.5	76.6	65.4	58.0	55.8	60.3	68.4	78.8	86.8	93.1	(21)
(22)			MCWB	65.4	64.9	63.0	58.3	54.8	51.5	49.7	51.6	55.5	58.0	61.2	62.9	(22)
(23)		5%	DB	91.9	89.3	83.6	73.2	62.6	56.1	54.0	57.4	64.3	73.4	81.8	87.7	(23)
(24)			MCWB	64.2	64.2	62.0	57.3	53.9	50.6	48.8	50.1	54.2	56.6	60.8	61.6	(24)
(25)		10%	DB	87.3	85.3	79.2	69.7	59.9	54.1	52.4	55.0	61.0	68.5	76.8	82.9	(25)
(26)			MCWB	63.4	63.2	60.8	56.3	52.8	49.6	47.9	48.8	52.7	55.3	59.7	60.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	72.8	68.6	62.9	59.3	55.8	53.4	55.3	60.0	63.4	67.9	69.2	(27)
(28)			MCD B	83.8	86.8	81.3	73.8	63.3	57.1	55.3	62.0	67.4	74.8	81.1	80.1	(28)
(29)		2%	WB	69.2	69.6	66.2	60.9	57.0	53.0	51.3	52.9	57.4	60.7	65.0	66.3	(29)
(30)			MCD B	83.3	81.5	79.4	69.8	61.3	55.8	54.0	58.3	65.0	70.5	78.4	81.7	(30)
(31)		5%	WB	67.1	67.0	64.3	59.1	55.1	51.6	49.7	51.1	55.2	58.5	62.9	64.1	(31)
(32)			MCD B	85.0	81.5	77.5	69.4	60.4	54.5	52.7	56.1	63.1	69.3	76.2	81.1	(32)
(33)		10%	WB	65.3	65.2	62.5	57.4	53.7	50.2	48.5	49.3	53.1	56.5	60.9	62.3	(33)
(34)			MCD B	83.2	80.6	76.0	67.8	59.0	53.3	51.4	54.1	60.2	67.3	73.2	79.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.8	26.4	24.3	22.2	17.9	14.9	14.1	17.0	20.6	24.0	25.7	28.5	(35)
(36)			MCD BR	35.9	33.0	31.1	28.1	22.0	18.1	17.1	21.5	26.5	32.8	34.5	37.2	(36)
(37)			MCWBR	11.5	11.1	11.5	12.7	12.6	12.0	11.5	13.6	14.9	15.3	13.6	12.8	(37)
(38)		5% WB	MCD BR	28.3	26.3	24.8	22.7	17.8	14.9	14.1	19.1	23.0	26.7	27.5	29.0	(38)
(39)			MCWBR	11.1	11.1	10.9	11.4	11.3	10.7	10.2	12.8	14.0	14.2	12.9	12.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.335	0.316	0.307	0.294	0.287	0.287	0.296	0.320	0.326	0.337	0.328	(40)	
(41)		taud	2.512	2.521	2.572	2.569	2.583	2.592	2.590	2.547	2.471	2.474	2.478	2.522	(41)	
(42)		Ebn at Noon	317	309	304	287	273	266	273	287	297	309	314	320	(42)	
(43)		Edh at Noon	36	34	30	26	22	21	22	26	32	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2376	2092	1685	1188	801	616	677	961	1361	1802	2101	2350	(44)	
(45)		RadStd	140	108	88	62	47	54	40	67	101	138	120	122	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.88	N/A	N/A	+2.34	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.94	N/A	N/A	+1.66	N/A	N/A	-32	-230	+319	+113

Nomenclature: See separate page