

KILMORE GAP, Australia

WMO: 948600

Lat: 37.3808S

Lon: 144.9653E

Elev: 1734

StdP: 13.80

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.4	36.8	29.9	25.6	52.4	31.8	27.8	47.9	39.8	46.3	36.0	45.2	14.8	0	0.756

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.8	89.5	63.4	85.3	62.7	81.5	61.7	67.4	79.5	65.6	78.1	64.0	76.1	16.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	95.9	70.1	62.0	88.5	67.9	60.1	82.7	66.6	32.8	79.0	31.4	78.2	30.1	75.8	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.3	30.3	27.2	DB	33.3	97.9	1.2	3.9	32.4	100.7	31.8	103.0	31.1	105.2	30.3	108.0
			WB	32.1	70.6	1.2	2.7	31.2	72.5	30.4	74.1	29.7	75.6	28.8	77.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	64.9	64.6	60.8	55.0	49.5	45.2	43.7	45.0	48.4	52.1	57.1	60.9
	DBStd	9.55	8.06	7.72	7.19	5.97	4.27	3.29	2.86	3.60	4.59	6.61	7.62	7.80
	HDD50	734	0	0	2	18	61	147	196	161	83	49	14	3
	HDD65	4372	103	97	174	303	480	593	660	619	497	404	263	179
	CDD50	2153	463	408	337	169	47	4	1	7	36	115	225	341
	CDD65	315	101	85	44	4	0	0	0	0	5	24	52	
	CDH74	3262	1158	825	357	17	0	0	0	0	42	231	632	
	CDH80	1160	481	291	95	1	0	0	0	0	6	58	228	
Wind	WSAvg	14.8	15.5	14.9	14.1	13.5	14.2	14.9	15.7	15.4	15.1	15.2	14.8	14.9
Precipitation	PrecAvg	24.7	1.5	2.0	1.5	1.8	1.8	2.4	2.4	2.3	2.5	2.1	2.4	2.0
	PrecMax	38.2	5.7	5.7	3.7	3.7	4.6	5.0	4.2	4.1	6.4	5.2	7.0	5.2
	PrecMin	15.8	0.0	0.2	0.3	0.4	0.2	0.7	0.7	0.4	0.6	0.3	0.9	0.1
	PrecStd	6.0	1.1	1.6	0.9	1.0	1.0	1.1	0.9	1.1	1.4	1.3	1.3	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.1	93.0	88.6	76.5	64.6	56.2	53.8	59.5	67.9	79.2	86.6	93.8
		MCWB	65.1	64.9	62.0	57.9	53.5	50.8	49.5	52.7	55.1	58.3	62.1	63.3
	2%	DB	90.2	87.4	82.2	71.3	60.9	53.7	51.2	55.9	62.6	73.1	80.2	86.4
		MCWB	63.8	63.3	61.3	57.0	53.2	49.9	47.8	49.8	53.9	56.5	60.7	61.5
	5%	DB	84.9	83.3	77.7	68.0	58.3	51.8	49.5	53.2	59.4	68.0	75.4	80.9
		MCWB	63.1	62.6	60.3	55.6	51.9	48.6	46.7	48.1	52.4	55.3	59.2	60.6
	10%	DB	80.4	79.0	73.5	64.7	55.8	50.1	48.1	50.9	56.4	63.6	71.0	76.2
		MCWB	61.9	61.7	59.4	54.7	51.2	47.6	45.7	46.8	50.4	53.8	58.0	59.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	69.4	66.7	61.2	57.3	53.4	51.3	53.5	57.6	61.9	66.9	68.2
		MCDB	81.0	80.5	77.2	69.8	59.9	54.1	51.7	58.5	63.0	71.1	77.3	78.5
	2%	WB	67.4	67.1	64.5	59.1	54.8	50.7	49.0	50.9	55.1	58.6	63.3	64.9
		MCDB	81.8	78.4	74.6	66.8	57.6	52.4	50.2	54.5	60.7	67.4	74.0	76.6
	5%	WB	65.5	65.1	62.5	57.4	53.2	49.4	47.3	49.0	53.0	56.8	61.2	62.8
		MCDB	79.2	77.4	72.6	64.3	56.7	51.0	48.7	52.2	58.5	65.4	71.2	75.6
	10%	WB	63.7	63.4	60.8	55.8	51.7	48.1	46.2	47.3	50.8	54.7	59.0	60.9
		MCDB	77.0	75.1	70.4	62.6	55.3	49.7	47.6	50.2	55.7	62.6	68.6	73.2
Mean Daily Temperature Range	5% DB	MDBR	21.8	20.0	17.3	13.4	9.0	7.3	7.3	9.4	12.1	15.8	18.2	20.7
		MCDBR	29.7	26.8	23.7	18.0	12.0	9.2	8.8	12.2	16.0	22.5	25.2	28.6
		MCWBR	9.5	8.7	8.3	7.6	6.9	6.4	6.3	7.8	9.5	10.8	10.4	9.9
	5% WB	MCDBR	25.0	22.7	19.4	15.3	9.9	7.8	7.6	11.2	14.9	19.4	21.0	23.2
		MCWBR	10.2	9.5	8.9	7.8	6.8	6.2	6.1	7.9	9.5	11.1	10.9	10.6
Clear-Sky Solar Irradiance	taub	0.326	0.329	0.308	0.303	0.287	0.282	0.280	0.291	0.311	0.315	0.325	0.319	
	taud	2.538	2.538	2.598	2.579	2.609	2.611	2.613	2.567	2.501	2.514	2.511	2.551	
	Ebn at Noon	319	311	306	288	275	267	275	288	300	312	318	323	
	Edh at Noon	35	33	29	26	22	20	21	25	31	34	35	34	
All-Sky Solar Radiation	RadAvg	2308	2016	1622	1128	746	573	635	901	1282	1713	2022	2264	
	RadStd	145	110	91	68	48	51	39	67	100	145	123	125	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.94	+0.72	N/A	N/A	N/A	N/A	-122	-302	N/A	+126
(47)	Regional (40 neighbors)	+0.92	N/A	N/A	+1.62	N/A	N/A	-32	-232	+326	+117

Nomenclature: See separate page