

KILMORE GAP, Australia

WMO: 948600

Lat: 37.3808S

Lon: 144.9653E

Elev: 528

StdP: 95.14

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.9	2.7	-1.2	3.7	11.3	-0.1	4.0	8.8	17.8	7.9	16.1	7.3	6.6	0	0.756

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	31.9	17.5	29.6	17.1	27.5	16.5	19.6	26.4	18.7	25.6	17.8	24.5	7.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	13.7	21.2	16.6	12.6	19.9	15.6	11.8	19.2	58.4	26.1	55.1	25.7	52.1	24.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.5	12.1	0.7	36.6	0.6	2.2	0.2	38.2	-0.1	39.4	-0.5	40.7	-1.0	42.2
			0.0	21.5	0.7	1.5	-0.5	22.5	-0.9	23.4	-1.3	24.2	-1.8	25.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	18.3	18.1	16.0	12.8	9.7	7.4	6.5	7.2	9.1	11.2	13.9	16.1
	DBStd	5.31	4.48	4.29	4.00	3.32	2.37	1.83	1.59	2.00	2.55	3.67	4.24	4.33
	HDD10.0	408	0	0	1	10	34	82	109	89	46	27	8	2
	HDD18.3	2429	57	54	97	168	267	329	367	344	276	224	146	99
	CDD10.0	1196	257	227	187	94	26	2	1	4	20	64	125	189
	CDD18.3	175	56	47	24	2	0	0	0	0	3	13	29	
	CDH23.3	1812	643	458	198	9	0	0	0	0	23	128	351	
	CDH26.7	644	267	162	53	1	0	0	0	0	3	32	127	
Wind	WSAvg	6.6	6.9	6.7	6.3	6.0	6.3	6.6	7.0	6.9	6.7	6.8	6.6	6.7
Precipitation	PrecAvg	627	37	52	38	45	46	61	62	58	64	53	61	50
	PrecMax	970	146	146	94	95	117	126	107	103	162	132	177	132
	PrecMin	401	0	5	7	10	4	19	18	9	15	7	22	3
	PrecStd	153	29	41	22	25	26	27	24	27	35	33	34	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.7	33.9	31.4	24.7	18.1	13.4	12.1	15.3	19.9	26.2	30.3	34.3
		MCWB	18.4	18.3	16.7	14.4	11.9	10.5	9.7	11.5	12.8	14.6	16.7	17.4
	2%	DB	32.3	30.8	27.9	21.8	16.0	12.1	10.7	13.3	17.0	22.9	26.8	30.2
		MCWB	17.7	17.4	16.3	13.9	11.8	10.0	8.8	9.9	12.2	13.6	16.0	16.4
	5%	DB	29.4	28.5	25.4	20.0	14.6	11.0	9.7	11.8	15.2	20.0	24.1	27.2
		MCWB	17.3	17.0	15.7	13.1	11.1	9.2	8.2	9.0	11.3	12.9	15.1	15.9
	10%	DB	26.9	26.1	23.1	18.2	13.2	10.0	9.0	10.5	13.6	17.6	21.6	24.5
		MCWB	16.6	16.5	15.2	12.6	10.6	8.7	7.6	8.2	10.2	12.1	14.4	15.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	20.8	19.3	16.2	14.0	11.9	10.7	11.9	14.2	16.6	19.4	20.1
		MCDB	27.2	27.0	25.1	21.0	15.5	12.3	11.0	14.7	17.2	21.7	25.2	25.8
	2%	WB	19.7	19.5	18.0	15.0	12.7	10.4	9.5	10.5	12.8	14.8	17.4	18.3
		MCDB	27.7	25.8	23.7	19.3	14.2	11.3	10.1	12.5	15.9	19.7	23.3	24.8
	5%	WB	18.6	18.4	17.0	14.1	11.8	9.6	8.5	9.5	11.7	13.8	16.2	17.1
		MCDB	26.2	25.2	22.6	18.0	13.7	10.6	9.3	11.2	14.7	18.6	21.8	24.2
	10%	WB	17.6	17.4	16.0	13.2	10.9	8.9	7.9	8.5	10.5	12.6	15.0	16.1
		MCDB	25.0	23.9	21.4	17.0	12.9	9.8	8.7	10.1	13.2	17.0	20.4	22.9
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.1	9.6	7.5	5.0	4.1	4.1	5.2	6.7	8.8	10.1	11.5
		MCDBR	16.5	14.9	13.1	10.0	6.7	5.1	4.9	6.8	8.9	12.5	14.0	15.9
		MCWBR	5.3	4.9	4.6	4.2	3.8	3.5	3.5	4.3	5.3	6.0	5.8	5.5
	5% WB	MCDBR	13.9	12.6	10.8	8.5	5.5	4.3	4.2	6.2	8.3	10.8	11.7	12.9
MCWBR		5.7	5.3	4.9	4.3	3.8	3.4	3.4	4.4	5.3	6.2	6.0	5.9	
Clear-Sky Solar Irradiance	taub	0.326	0.329	0.308	0.303	0.287	0.282	0.280	0.291	0.311	0.315	0.325	0.319	
	taud	2.538	2.538	2.598	2.579	2.609	2.611	2.613	2.567	2.501	2.514	2.511	2.551	
	Ebn at Noon	1007	981	965	909	868	843	868	909	945	985	1002	1019	
	Edh at Noon	109	104	90	81	68	63	66	80	98	106	111	108	
All-Sky Solar Radiation	RadAvg	7.28	6.36	5.11	3.56	2.35	1.81	2.00	2.84	4.04	5.40	6.37	7.14	
	RadStd	0.46	0.35	0.29	0.21	0.15	0.16	0.12	0.21	0.32	0.46	0.39	0.39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.52	+0.40	N/A	N/A	N/A	N/A	-68	-168	N/A	+70
Regional (40 neighbors)		+0.51	N/A	N/A	+0.90	N/A	N/A	-18	-129	+181	+65

Nomenclature: See separate page