

SHE OAKS, Australia

WMO: 948630

Lat: 37.9075S

Lon: 144.1303E

Elev: 779

StdP: 14.29

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.7	35.7	30.1	24.9	51.5	32.1	27.3	48.0	28.1	52.4	26.1	51.8	6.7	350	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	93.3	65.0	88.6	64.2	84.2	63.0	68.4	82.8	66.7	80.6	65.2	78.7	12.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.0	95.3	69.8	62.9	88.4	68.6	61.1	82.8	67.3	33.2	82.8	31.8	80.6	30.5	78.5	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.6	21.7	19.1	DB	29.8	103.1	1.6	4.2	28.6	106.2	27.7	108.6	26.8	111.0	25.6	114.0
			WB	29.4	71.9	1.8	2.2	28.1	73.4	27.1	74.7	26.1	75.9	24.8	77.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.9	65.5	65.6	62.3	56.7	52.3	48.2	47.5	48.3	50.8	54.1	58.3	61.8	(6)
(7)		DBStd	8.76	7.63	7.11	6.82	5.89	4.71	3.83	3.62	4.22	5.11	6.31	7.06	7.24	(7)
(8)		HDD50	363	0	0	0	6	26	78	95	85	46	22	4	1	(8)
(9)		HDD65	3665	84	72	137	259	395	503	543	519	426	345	228	154	(9)
(10)		CDD50	2518	482	437	381	209	96	25	17	31	71	150	254	365	(10)
(11)		CDD65	345	101	88	53	11	1	0	0	0	1	8	28	54	(11)
(12)		CDH74	4536	1350	1013	642	105	1	0	0	0	7	144	423	851	(12)
(13)		CDH80	1947	676	441	247	17	0	0	0	0	0	32	148	386	(13)
(14)	Wind	WSAvg	9.2	9.0	8.6	8.3	8.2	9.0	8.9	10.3	10.3	10.1	9.7	9.0	8.9	(14)
(15)	Precipitation	PrecAvg	21.5	1.4	1.6	1.5	1.7	1.5	2.0	1.9	1.8	2.4	2.1	2.2	1.6	(15)
(16)		PrecMax	29.2	5.3	5.3	3.0	5.9	2.9	4.7	3.5	3.2	4.3	4.2	5.2	4.6	(16)
(17)		PrecMin	13.2	0.0	0.1	0.7	0.4	0.4	0.5	0.9	0.4	1.1	0.1	0.6	0.0	(17)
(18)		PrecStd	4.2	1.1	1.3	0.6	1.2	0.7	0.9	0.7	0.7	0.9	1.2	1.2	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.5	96.3	94.1	82.2	71.2	62.9	61.3	67.0	73.8	84.3	89.8	97.0	(19)
(20)			MCWB	66.7	66.0	65.4	59.7	55.9	53.2	51.7	53.7	57.5	60.0	63.7	64.2	(20)
(21)		2%	DB	93.8	90.9	86.6	77.0	66.8	59.2	57.8	62.3	68.6	77.9	84.6	90.0	(21)
(22)			MCWB	65.0	65.4	63.8	58.6	54.6	52.7	50.2	51.4	55.1	58.7	62.7	63.1	(22)
(23)		5%	DB	87.7	85.6	81.2	72.6	63.7	56.9	55.4	58.9	64.8	72.7	78.7	83.7	(23)
(24)			MCWB	64.6	64.4	62.0	57.5	54.0	51.2	48.6	50.2	53.6	56.8	60.8	61.9	(24)
(25)		10%	DB	81.2	80.1	75.8	68.5	60.9	54.9	53.7	56.1	61.4	67.5	72.9	77.4	(25)
(26)			MCWB	63.5	63.7	60.9	56.4	53.4	50.2	48.2	48.8	52.2	55.3	59.0	61.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	70.8	68.0	62.9	59.1	56.4	53.8	55.2	59.6	63.1	67.6	68.5	(27)
(28)			MCD B	87.0	85.2	82.0	75.4	63.4	59.7	57.8	62.8	68.6	75.7	81.2	81.9	(28)
(29)		2%	WB	68.6	68.4	65.5	60.8	57.1	53.9	51.8	52.8	56.9	60.3	64.8	65.6	(29)
(30)			MCD B	84.7	81.3	79.2	69.7	63.7	57.2	55.5	59.6	66.5	71.7	77.7	80.7	(30)
(31)		5%	WB	66.6	66.7	63.9	59.2	55.4	52.3	50.2	51.1	54.8	58.2	62.5	63.8	(31)
(32)			MCD B	82.3	78.8	75.8	68.3	61.4	55.6	53.6	56.9	62.7	69.6	74.5	79.1	(32)
(33)		10%	WB	64.5	65.0	62.2	57.6	54.0	50.9	49.0	49.6	52.8	56.2	60.3	61.9	(33)
(34)			MCD B	79.1	76.8	72.8	65.9	59.3	54.1	52.4	54.7	59.6	65.8	71.0	75.1	(34)
(35)	Mean Daily Temperature Range		MDBR	22.9	21.0	19.7	17.5	13.1	11.7	11.0	13.1	15.6	18.8	20.2	22.7	(35)
(36)		5% DB	MCD BR	34.9	31.5	30.0	24.9	17.7	14.5	13.1	17.6	21.5	29.2	32.2	35.4	(36)
(37)			MCWBR	11.4	10.8	11.0	10.9	9.4	9.4	8.0	9.4	11.1	13.1	12.9	12.3	(37)
(38)		5% WB	MCD BR	28.3	24.8	24.2	20.8	14.8	12.3	11.0	15.6	19.1	24.7	26.7	28.0	(38)
(39)			MCWBR	11.2	10.2	10.2	10.1	9.1	8.8	7.7	9.3	11.1	12.7	12.1	11.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.342	0.342	0.323	0.316	0.306	0.293	0.292	0.301	0.324	0.331	0.340	0.332	(40)	
(41)		taud	2.499	2.511	2.562	2.556	2.561	2.588	2.585	2.548	2.471	2.469	2.471	2.517	(41)	
(42)		Ebn at Noon	314	307	300	283	266	261	269	284	294	307	313	319	(42)	
(43)		Edh at Noon	36	34	30	26	23	20	22	26	32	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2273	1982	1565	1089	728	570	635	896	1276	1699	1990	2241	(44)	
(45)		RadStd	141	96	90	64	37	42	38	54	83	132	123	132	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	-256	+369	+90	(46)
(47)	Regional (39 neighbors)	+0.90	N/A	N/A	+1.57	N/A	N/A	-29	-232	+315	+104	(47)

Nomenclature: See separate page