

SHE OAKS, Australia

WMO: 948630

Lat: 37.9075S

Lon: 144.1303E

Elev: 237

StdP: 98.51

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.9	2.1	-1.1	3.6	10.8	0.1	3.9	8.9	12.6	11.3	11.7	11.0	3.0	350	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	34.1	18.3	31.5	17.9	29.0	17.2	20.2	28.2	19.3	27.0	18.4	25.9	5.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.6	21.0	17.2	12.6	20.3	16.2	11.8	19.6	59.2	28.2	56.0	27.0	53.1	25.8	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.5	DB	-1.2	39.5	0.9	2.3	-1.9	41.2	-2.4	42.6	-2.9	43.9	-3.5	45.6	(4)
(5)			WB	-1.4	22.2	1.0	1.2	-2.2	23.0	-2.7	23.7	-3.3	24.4	-4.0	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	18.6	18.7	16.8	13.7	11.3	9.0	8.6	9.0	10.5	12.3	14.6	16.5	(6)	
	DBStd	4.87	4.24	3.95	3.79	3.27	2.62	2.13	2.01	2.35	2.84	3.51	3.92	4.02	(7)	
	HDD10.0	202	0	0	0	3	14	43	53	47	26	12	2	1	(8)	
	HDD18.3	2036	47	40	76	144	219	279	302	288	237	192	127	86	(9)	
	CDD10.0	1399	268	243	212	116	53	14	9	17	39	83	141	203	(10)	
	CDD18.3	192	56	49	29	6	1	0	0	0	1	4	16	30	(11)	
	CDH23.3	2520	750	563	357	58	1	0	0	0	4	80	235	473	(12)	
	CDH26.7	1082	376	245	137	9	0	0	0	0	0	18	82	214	(13)	
(14) Wind	WSAvg	4.1	4.0	3.8	3.7	3.6	4.0	4.0	4.6	4.6	4.5	4.3	4.0	4.0	(14)	
(15) Precipitation	PrecAvg	547	36	41	37	42	37	51	47	46	61	53	55	41	(15)	
	PrecMax	742	134	135	77	149	73	119	90	82	109	107	131	117	(16)	
	PrecMin	335	0	3	19	10	10	12	24	11	28	2	14	0	(17)	
	PrecStd	106	28	33	15	30	17	23	18	19	24	30	31	32	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	35.7	34.5	27.9	21.8	17.1	16.3	19.4	23.2	29.1	32.1	36.1	(19)	
		MCWB	19.3	18.9	18.6	15.4	13.3	11.8	10.9	12.1	14.2	15.6	17.6	17.9	(20)	
	2%	DB	34.4	32.7	30.3	25.0	19.3	15.1	14.3	16.8	20.4	25.5	29.2	32.2	(21)	
		MCWB	18.3	18.6	17.7	14.8	12.5	11.5	10.1	10.8	12.8	14.8	17.1	17.3	(22)	
	5%	DB	30.9	29.8	27.3	22.5	17.6	13.8	13.0	15.0	18.2	22.6	25.9	28.7	(23)	
		MCWB	18.1	18.0	16.7	14.1	12.2	10.7	9.2	10.1	12.0	13.8	16.0	16.6	(24)	
	10%	DB	27.3	26.7	24.4	20.3	16.1	12.7	12.1	13.4	16.3	19.7	22.7	25.2	(25)	
		MCWB	17.5	17.6	16.1	13.5	11.9	10.1	9.0	9.3	11.2	13.0	15.0	16.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.6	20.0	17.1	15.0	13.6	12.1	12.9	15.4	17.3	19.8	20.3	(27)	
		MCDB	30.5	29.6	27.8	24.1	17.5	15.4	14.3	17.1	20.3	24.3	27.3	27.7	(28)	
	2%	WB	20.4	20.2	18.6	16.0	13.9	12.2	11.0	11.5	13.9	15.7	18.2	18.7	(29)	
		MCDB	29.3	27.4	26.2	21.0	17.6	14.0	13.1	15.4	19.1	22.1	25.4	27.0	(30)	
	5%	WB	19.2	19.3	17.7	15.1	13.0	11.3	10.1	10.6	12.6	14.6	16.9	17.7	(31)	
		MCDB	27.9	26.0	24.3	20.2	16.3	13.1	12.0	13.8	17.1	20.9	23.6	26.2	(32)	
	10%	WB	18.1	18.4	16.8	14.2	12.2	10.5	9.5	9.8	11.6	13.4	15.7	16.6	(33)	
		MCDB	26.2	24.9	22.7	18.8	15.1	12.3	11.3	12.6	15.3	18.8	21.7	24.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	11.7	11.0	9.7	7.3	6.5	6.1	7.3	8.7	10.4	11.2	12.6	(35)	
		MCDBR	19.4	17.5	16.7	13.8	9.9	8.1	7.3	9.8	11.9	16.2	17.9	19.7	(36)	
	5% WB	MCWBR	6.3	6.0	6.1	6.0	5.2	5.2	4.5	5.2	6.2	7.3	7.2	6.9	(37)	
		MCWBR	15.7	13.8	13.4	11.6	8.2	6.9	6.1	8.6	10.6	13.7	14.8	15.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.342	0.323	0.316	0.306	0.293	0.292	0.301	0.324	0.331	0.340	0.332	(40)	
		taud	2.499	2.511	2.562	2.556	2.561	2.588	2.585	2.548	2.471	2.469	2.471	2.517	(41)	
	Ebn at Noon		991	967	947	891	839	823	848	894	928	967	986	1005	(42)	
		Edh at Noon	113	107	94	82	71	64	68	81	100	110	115	112	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.17	6.25	4.93	3.43	2.29	1.80	2.00	2.83	4.02	5.36	6.27	7.07	(44)	
	RadStd		0.45	0.30	0.28	0.20	0.12	0.13	0.12	0.17	0.26	0.42	0.39	0.42	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-142	+205	+50	(46)	
(47)	Regional (39 neighbors)	+0.50	N/A	N/A	+0.87	N/A	N/A	-16	-129	+175	+58	(47)	

Nomenclature: See separate page