

HUNTERS HILL, Australia

WMO: 948780

Lat: 36.214S

Lon: 147.539E

Elev: 3219

StdP: 13.07

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.9	32.2	23.5	20.0	49.2	26.3	22.8	46.7	18.5	39.0	16.1	38.5	5.1	250	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	86.9	61.8	83.2	60.9	80.2	60.2	66.4	76.2	64.8	74.8	63.4	73.6	6.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	100.5	67.7	62.0	93.8	67.1	60.0	87.2	66.7	33.0	76.1	31.6	74.8	30.5	73.2	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	12.9	11.3	DB	28.7	92.4	1.1	3.3	27.9	94.8	27.3	96.8	26.6	98.6	25.8	101.1	(4)
(5)			WB	27.5	69.2	1.3	2.0	26.5	70.7	25.7	71.8	24.9	73.0	24.0	74.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	68.3	66.9	61.8	54.6	47.0	42.3	40.2	41.6	46.6	52.5	58.9	62.8
	DBStd	11.43	7.53	6.80	6.83	5.97	5.17	4.03	3.46	4.60	5.52	6.89	7.79	7.14
	HDD50	1150	0	1	4	26	121	232	305	262	130	52	13	4
	HDD65	4571	51	52	141	314	558	681	770	724	551	390	214	125
	CDD50	2451	569	475	371	164	28	1	0	3	29	131	279	401
	CDD65	396	154	105	43	2	0	0	0	0	0	4	30	58
	CDH74	2801	1277	718	219	2	0	0	0	0	0	12	171	402
	CDH80	739	406	184	31	0	0	0	0	0	0	0	26	92
Wind	WSAvg	4.8	4.9	4.4	4.4	4.0	4.2	4.4	4.8	5.2	5.4	5.3	5.2	5.3
Precipitation	PrecAvg	36.4	2.3	2.4	2.2	2.1	2.6	4.3	4.3	4.1	3.5	3.1	3.0	2.6
	PrecMax	53.2	7.2	11.6	9.0	6.6	6.7	7.2	7.7	7.6	7.6	9.4	5.9	6.5
	PrecMin	13.5	0.0	0.0	0.2	0.0	0.0	1.2	1.6	0.5	0.8	0.4	0.8	0.4
	PrecStd	9.3	1.8	2.4	1.9	1.7	1.8	1.7	1.8	2.0	1.9	2.1	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	90.7	84.0	73.0	62.9	54.9	52.2	58.5	65.6	75.6	83.2	87.6
		MCWB	63.4	63.0	60.0	57.4	52.3	47.8	47.3	49.0	52.2	55.1	59.7	60.4
	2%	DB	88.4	85.2	79.4	68.8	59.3	52.3	49.3	54.5	62.0	70.9	78.7	82.3
		MCWB	62.7	61.8	59.5	55.1	51.3	46.8	45.0	46.9	51.4	54.5	58.8	60.5
	5%	DB	84.2	81.6	76.0	66.1	56.5	50.1	47.4	51.5	58.7	67.4	74.9	78.3
		MCWB	61.6	60.9	58.2	54.2	50.1	45.9	43.7	45.4	49.9	53.1	57.3	58.5
	10%	DB	81.0	78.4	72.9	63.5	54.4	48.1	45.5	48.9	55.8	64.1	71.4	74.9
		MCWB	60.8	60.2	57.6	53.2	49.0	44.9	42.6	44.1	48.5	51.8	56.1	57.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	69.2	65.4	60.4	55.3	50.6	49.5	51.0	54.9	59.4	64.5	66.0
		MCDB	79.3	77.9	72.6	68.0	57.6	52.1	50.3	54.6	60.3	66.3	73.3	72.6
	2%	WB	66.6	66.4	63.3	58.0	52.9	48.4	46.3	48.4	53.2	57.1	61.9	63.4
		MCDB	78.1	75.0	71.3	64.5	57.1	50.4	48.1	52.5	58.3	63.7	72.2	72.2
	5%	WB	64.9	64.7	61.6	56.2	51.1	46.8	44.4	46.5	51.6	55.4	60.1	61.7
		MCDB	77.1	73.5	70.2	62.7	55.2	48.9	46.3	50.5	56.6	63.0	69.8	71.7
	10%	WB	63.4	63.2	59.8	54.6	49.7	45.3	43.0	44.8	49.6	53.6	58.2	60.1
		MCDB	75.7	72.6	68.8	60.9	53.5	47.5	44.8	48.2	54.8	61.6	67.2	71.0
Mean Daily Temperature Range	5% DB	MDBR	19.4	18.2	16.3	13.3	10.0	8.4	8.3	9.9	12.8	15.4	16.9	18.4
		MCDBR	21.3	20.7	18.8	15.1	12.2	11.0	11.1	13.7	16.1	18.2	19.1	20.9
		MCWBR	8.4	8.1	8.2	7.8	7.6	7.6	7.8	8.5	8.9	8.8	9.0	8.7
	5% WB	MCDBR	18.7	16.5	15.6	13.0	10.8	9.3	9.2	12.1	13.9	15.6	16.1	17.0
		MCWBR	9.2	8.6	8.6	7.8	7.3	7.2	7.1	8.4	8.8	9.3	8.9	9.4
Clear-Sky Solar Irradiance	taub	0.335	0.313	0.290	0.281	0.271	0.261	0.260	0.267	0.290	0.293	0.306	0.309	
	taud	2.493	2.599	2.675	2.655	2.646	2.687	2.695	2.657	2.571	2.599	2.590	2.588	
	Ebn at Noon	317	317	314	299	285	280	287	300	308	321	325	327	
	Edh at Noon	36	31	27	24	21	19	20	23	29	31	33	33	
All-Sky Solar Radiation	RadAvg	2380	2058	1723	1253	850	644	695	967	1398	1862	2149	2386	
	RadStd	139	154	119	73	59	71	44	89	154	174	134	110	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.76	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	+218	+106

Nomenclature: See separate page