

HUNTERS HILL, AustraliaWMO: **948780**Lat: **36.214S**Lon: **147.539E**Elev: **981**StdP: **90.08**Time Zone: **10.00 (AUS)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.6	0.1	-4.7	2.9	9.5	-3.2	3.3	8.2	8.3	3.9	7.2	3.6	2.3	250	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	30.5	16.6	28.5	16.1	26.8	15.7	19.1	24.5	18.2	23.8	17.4	23.1	2.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	14.4	19.8	16.7	13.4	19.5	15.6	12.5	19.3	58.8	24.5	55.7	23.8	53.0	22.9	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
6.7	5.8	5.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-1.8	33.6	0.6	1.9	-2.3	34.9	-2.6	36.0	-3.0	37.0	-3.4	38.4
			-2.5	20.7	0.7	1.1	-3.1	21.5	-3.5	22.1	-3.9	22.8	-4.5	23.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	20.2	19.4	16.6	12.6	8.3	5.7	4.5	5.4	8.1	11.4	14.9	17.1
	DBStd	6.35	4.19	3.78	3.79	3.31	2.87	2.24	1.92	2.56	3.06	3.83	4.33	3.97
	HDD10.0	639	0	1	2	14	67	129	169	146	72	29	7	2
	HDD18.3	2539	28	29	78	174	310	378	428	402	306	217	119	69
	CDD10.0	1362	316	264	206	91	16	1	0	2	16	73	155	223
	CDD18.3	220	86	58	24	1	0	0	0	0	0	2	17	32
	CDH23.3	1556	709	399	122	1	0	0	0	0	0	7	95	223
	CDH26.7	411	226	102	17	0	0	0	0	0	0	0	14	51
Wind	WSAvg	2.1	2.2	2.0	2.0	1.8	1.9	2.0	2.1	2.3	2.4	2.4	2.3	2.3
Precipitation	PrecAvg	925	58	62	57	53	65	108	108	104	90	79	76	66
	PrecMax	1351	182	294	229	168	169	184	196	192	194	238	151	165
	PrecMin	342	0	0	4	0	0	30	40	12	21	9	20	11
	PrecStd	235	45	61	48	42	45	42	46	50	48	54	38	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	32.6	28.9	22.8	17.2	12.7	11.2	14.7	18.7	24.2	28.5	30.9
		MCWB	17.5	17.2	15.5	14.1	11.3	8.8	8.5	9.4	11.2	12.8	15.4	15.8
	2%	DB	31.4	29.5	26.3	20.4	15.2	11.3	9.6	12.5	16.7	21.6	26.0	27.9
		MCWB	17.0	16.5	15.3	12.8	10.7	8.2	7.2	8.3	10.8	12.5	14.9	15.8
	5%	DB	29.0	27.5	24.4	18.9	13.6	10.0	8.5	10.8	14.8	19.7	23.8	25.7
		MCWB	16.5	16.1	14.6	12.3	10.0	7.7	6.5	7.5	10.0	11.7	14.0	14.7
	10%	DB	27.2	25.8	22.7	17.5	12.5	8.9	7.5	9.4	13.2	17.8	21.9	23.8
		MCWB	16.0	15.7	14.2	11.8	9.4	7.2	5.9	6.7	9.2	11.0	13.4	14.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	20.7	18.6	15.8	13.0	10.3	9.7	10.5	12.7	15.2	18.0	18.9
		MCDB	26.3	25.5	22.6	20.0	14.2	11.2	10.2	12.6	15.7	19.0	22.9	22.6
	2%	WB	19.2	19.1	17.4	14.4	11.6	9.1	8.0	9.1	11.8	14.0	16.6	17.4
		MCDB	25.6	23.9	21.8	18.1	13.9	10.2	8.9	11.4	14.6	17.6	22.3	22.3
	5%	WB	18.3	18.2	16.4	13.4	10.6	8.2	6.9	8.1	10.9	13.0	15.6	16.5
		MCDB	25.1	23.0	21.2	17.0	12.9	9.4	7.9	10.3	13.7	17.2	21.0	22.1
	10%	WB	17.5	17.3	15.5	12.5	9.8	7.4	6.1	7.1	9.8	12.0	14.6	15.6
		MCDB	24.3	22.6	20.4	16.0	11.9	8.6	7.1	9.0	12.7	16.5	19.5	21.7
Mean Daily Temperature Range	5% DB	MDBR	10.8	10.1	9.1	7.4	5.5	4.7	4.6	5.5	7.1	8.6	9.4	10.2
		MCDBR	11.8	11.5	10.4	8.4	6.8	6.1	6.1	7.6	8.9	10.1	10.6	11.6
		MCWBR	4.7	4.5	4.6	4.3	4.2	4.2	4.3	4.7	4.9	4.9	5.0	4.9
	5% WB	MCDBR	10.4	9.2	8.7	7.2	6.0	5.2	5.1	6.7	7.7	8.6	8.9	9.5
		MCWBR	5.1	4.8	4.8	4.4	4.1	4.0	3.9	4.7	4.9	5.2	4.9	5.2
Clear-Sky Solar Irradiance	taub	0.335	0.313	0.290	0.281	0.271	0.261	0.260	0.267	0.290	0.293	0.306	0.309	
	taud	2.493	2.599	2.675	2.655	2.646	2.687	2.695	2.657	2.571	2.599	2.590	2.588	
	Ebn at Noon	999	1000	990	942	897	883	905	945	972	1011	1023	1031	
	Edh at Noon	114	98	84	76	66	59	62	74	92	97	103	105	
All-Sky Solar Radiation	RadAvg	7.50	6.49	5.43	3.95	2.68	2.03	2.19	3.05	4.41	5.87	6.78	7.52	
	RadStd	0.44	0.48	0.38	0.23	0.18	0.23	0.14	0.28	0.48	0.55	0.42	0.35	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.42	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	+121	+59	

Nomenclature: See separate page