

POUND CREEK, AustraliaWMO: **948860**Lat: **38.6297S**Lon: **145.8108E**Elev: **12**StdP: **14.69**Time Zone: **10.00 (AUS)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.2	37.5	33.7	28.3	38.2	35.5	30.5	41.7	29.0	51.0	25.8	51.6	1.7	0	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	91.2	69.0	85.7	67.9	81.4	67.0	71.9	84.0	70.0	81.3	68.3	78.3	10.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	103.9	75.2	66.4	97.4	73.9	64.8	91.8	72.2	35.6	84.8	34.0	81.4	32.6	78.0	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	22.2	19.9	DB	30.8	102.7	2.0	4.1	29.3	105.6	28.2	108.0	27.0	110.3	25.6	113.2	(4)
(5)			WB	30.4	77.2	2.1	3.1	28.9	79.5	27.6	81.3	26.4	83.0	24.9	85.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	65.3	65.7	63.6	58.7	54.2	50.4	49.9	50.5	53.2	55.6	59.1	61.8	(6)	
	DBStd	7.60	6.99	5.76	6.21	5.04	4.17	3.59	3.46	3.42	4.12	5.35	5.98	6.31	(7)	
	HDD50	139	0	0	0	1	8	38	44	33	10	5	0	0	(8)	
	HDD65	3122	80	55	105	200	335	437	468	449	353	297	199	144	(9)	
	CDD50	2803	473	439	421	262	139	51	41	50	107	180	274	366	(10)	
	CDD65	309	88	74	60	11	1	0	0	0	0	7	23	45	(11)	
	CDH74	3298	998	674	577	108	3	0	0	0	8	114	270	546	(12)	
	CDH80	1284	475	238	217	21	0	0	0	0	0	23	78	232	(13)	
(14) Wind	WSAvg	9.0	9.5	9.8	8.9	7.8	8.5	7.4	9.2	9.3	9.4	9.3	9.7	9.5	(14)	
(15) Precipitation	PrecAvg	35.9	1.7	1.5	2.3	3.0	3.9	3.7	4.1	4.1	3.6	3.5	2.6	2.5	(15)	
	PrecMax	46.7	3.9	7.4	7.4	6.5	10.0	7.5	7.6	6.6	7.7	6.5	5.4	5.4	(16)	
	PrecMin	22.1	0.1	0.0	0.2	0.6	0.8	1.5	1.3	1.1	0.7	1.0	0.7	0.4	(17)	
	PrecStd	6.1	0.9	1.5	1.5	1.5	1.8	1.6	1.9	1.3	1.5	1.6	1.1	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.9	93.8	94.6	82.8	72.7	63.2	63.4	66.4	74.5	83.3	87.0	94.7	(19)	
		MCWB	71.1	70.0	68.8	64.2	59.1	55.4	53.6	54.6	60.4	63.5	68.1	70.4	(20)	
	2%	DB	91.7	86.3	85.9	76.9	67.8	60.8	60.3	62.8	69.7	76.8	81.5	87.2	(21)	
		MCWB	69.6	68.2	67.0	64.4	57.8	54.9	53.1	53.9	57.5	62.3	67.3	68.7	(22)	
	5%	DB	84.4	82.1	80.1	72.4	64.6	59.0	58.0	59.6	65.3	72.1	76.0	79.7	(23)	
		MCWB	68.8	67.8	65.5	61.7	56.6	54.1	51.6	52.2	56.2	60.5	65.7	67.0	(24)	
	10%	DB	78.2	77.5	75.3	68.3	61.7	57.1	56.0	56.8	61.8	67.3	70.8	73.8	(25)	
		MCWB	67.2	66.5	64.4	60.5	55.7	52.6	50.9	51.1	54.4	59.0	63.5	65.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	72.8	71.9	67.6	61.0	58.1	57.0	57.3	61.6	66.9	71.7	73.6	(27)	
		MCDB	86.1	84.9	83.5	76.8	67.5	60.1	60.5	64.5	72.5	74.6	83.0	86.1	(28)	
	2%	WB	72.1	70.7	68.7	64.5	59.1	56.0	54.2	54.8	58.7	64.2	68.5	70.2	(29)	
		MCDB	86.2	81.0	79.1	71.8	64.9	59.3	58.0	60.2	66.9	74.1	78.0	80.9	(30)	
	5%	WB	69.9	68.9	66.9	62.8	57.7	54.5	52.7	53.1	56.9	61.6	66.2	67.8	(31)	
		MCDB	83.0	78.1	77.2	69.4	63.0	58.0	56.4	57.8	63.9	70.9	74.7	78.4	(32)	
	10%	WB	67.6	67.2	65.2	61.2	56.2	53.2	51.5	51.9	55.2	59.2	63.8	65.5	(33)	
		MCDB	78.1	75.6	74.3	66.7	60.7	56.5	55.1	55.9	60.8	66.4	70.5	73.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	19.6	19.2	17.5	13.9	13.4	12.2	12.4	14.6	17.6	17.5	18.7	(35)	
		MCDBR	32.7	28.8	28.8	24.6	18.9	17.0	15.2	17.4	22.0	27.8	28.5	31.7	(36)	
		MCWBR	14.4	13.2	13.7	13.0	11.5	12.2	10.3	10.3	12.5	15.8	15.9	15.8	(37)	
	5% WB	MCDBR	29.9	23.6	25.0	20.4	16.7	15.7	13.0	15.0	19.4	25.7	26.0	26.7	(38)	
		MCWBR	14.5	12.0	13.9	12.6	11.1	12.0	9.6	10.0	11.9	16.3	15.8	15.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.362	0.362	0.343	0.335	0.318	0.311	0.309	0.322	0.349	0.345	0.351	0.347	(40)	
	taud		2.476	2.490	2.541	2.542	2.569	2.575	2.574	2.529	2.448	2.477	2.484	2.514	(41)	
	Ebn at Noon		307	300	293	274	260	252	261	275	285	302	309	314	(42)	
	Edh at Noon		36	35	30	26	22	20	22	26	33	35	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2210	1920	1512	1053	698	558	628	891	1270	1699	1997	2218	(44)	
	RadStd		138	100	85	55	35	38	27	41	79	113	110	125	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	+0.92	N/A	N/A	+1.49	+0.74	N/A	-29	-252	+324	+106

Nomenclature: See separate page