

MOUNT BULLER, AustraliaWMO: **948940**Lat: **37.145S**Lon: **146.439E**Elev: **5600**StdP: **11.96**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	23.5	-5.5	5.0	40.2	2.5	7.7	40.6	44.7	35.0	40.1	34.6	9.1	180	0.778

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	72.8	55.9	69.7	54.8	66.9	53.3	59.9	66.6	57.9	64.6	56.2	63.2	12.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.8	88.0	61.8	55.6	81.0	60.1	53.5	75.0	58.4	29.1	66.8	27.6	64.5	26.3	63.5	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.8	32.9	28.6	19.1	79.4	1.1	2.9	18.2	81.4	17.6	83.1	16.9	84.7	16.1	86.8
			18.3	62.2	1.6	2.6	17.2	64.1	16.2	65.6	15.3	67.1	14.1	69.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	55.5	54.9	50.3	43.3	37.7	33.6	30.6	31.4	35.3	40.9	46.9	50.9
	DBStd	10.94	8.68	7.63	7.53	6.52	5.14	4.38	3.69	4.36	5.70	7.64	8.39	8.41
	HDD50	3423	48	39	88	212	381	493	601	576	443	296	155	91
	HDD65	8224	309	289	458	651	845	943	1066	1041	892	746	544	440
	CDD50	700	219	176	98	11	0	0	0	0	0	15	61	120
	CDD65	26	15	5	2	0	0	0	0	0	0	0	0	4
	CDH74	65	44	14	1	0	0	0	0	0	0	0	1	5
	CDH80	3	2	1	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.4	11.3	10.5	11.0	11.8	14.1	12.9	12.7	13.2	13.6	13.3	12.5	12.1
Precipitation	PrecAvg	50.3	2.5	2.5	2.6	3.1	4.1	5.7	5.7	5.3	5.0	3.8	3.6	3.0
	PrecMax	73.4	6.5	8.7	7.2	7.6	9.3	10.0	11.6	10.1	9.8	8.3	7.2	7.8
	PrecMin	38.1	0.1	0.0	0.6	0.6	0.2	1.7	1.0	1.3	1.4	0.9	1.4	0.4
	PrecStd	9.4	1.9	2.3	1.7	1.9	2.4	2.3	2.2	2.5	2.1	2.0	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.8	76.4	71.7	60.5	52.0	47.6	42.9	45.8	53.5	63.0	69.1	74.0
		MCWB	58.6	58.1	55.0	49.9	43.1	36.6	38.3	40.2	43.2	48.7	52.6	55.8
	2%	DB	73.9	71.0	66.3	56.4	48.8	44.2	39.4	42.9	49.5	59.0	65.1	70.0
		MCWB	56.6	54.9	52.6	47.5	41.6	36.6	35.5	37.8	41.2	48.1	51.7	55.5
	5%	DB	70.5	67.5	63.2	53.7	46.5	42.2	37.7	40.3	46.7	55.5	62.1	66.4
		MCWB	55.1	54.0	51.9	46.2	40.6	35.6	34.6	36.3	40.5	45.9	50.1	52.5
	10%	DB	67.4	64.8	60.1	51.6	44.7	40.0	35.9	38.2	43.9	52.4	59.0	63.2
		MCWB	53.9	53.3	50.8	45.3	39.5	35.1	33.3	35.0	39.3	44.5	48.9	51.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.5	62.6	58.9	53.5	46.8	43.6	40.4	43.4	45.8	54.5	58.4	61.4
		MCDB	69.1	68.0	62.7	55.5	48.1	44.1	40.9	44.3	48.7	57.3	64.4	67.2
	2%	WB	59.7	59.3	55.9	50.2	44.6	40.9	38.0	39.7	43.5	50.6	54.4	58.1
		MCDB	68.7	64.6	62.0	53.8	46.5	41.7	38.5	41.1	46.4	54.9	61.2	64.1
	5%	WB	57.7	57.2	54.2	48.5	43.0	38.6	36.0	38.0	41.8	48.1	52.2	55.6
		MCDB	65.8	63.2	59.8	52.0	44.8	39.6	36.8	39.5	44.5	52.3	58.2	62.7
	10%	WB	56.2	55.5	52.5	46.9	41.6	36.9	34.2	35.9	39.9	46.2	50.5	53.5
		MCDB	64.2	62.1	57.8	50.5	43.6	38.0	34.8	37.4	42.6	50.7	56.8	60.6
Mean Daily Temperature Range	5% DB	MDBR	13.1	12.1	11.2	9.0	7.0	6.1	5.2	6.1	8.5	11.1	11.8	12.8
		MCDBR	14.4	13.5	12.9	10.6	8.7	8.7	7.3	8.2	11.4	13.1	13.5	14.0
		MCWBR	9.3	9.0	8.6	8.5	7.7	7.8	6.6	7.2	9.0	9.5	9.6	9.5
	5% WB	MCDBR	12.7	11.8	11.0	9.2	7.4	6.8	5.9	6.9	9.9	11.3	11.8	12.4
		MCWBR	9.7	8.9	8.4	8.0	7.0	7.1	5.9	6.8	8.8	9.5	9.6	9.9
Clear-Sky Solar Irradiance	taub	0.290	0.286	0.266	0.261	0.249	0.241	0.240	0.247	0.267	0.269	0.280	0.294	
	taud	2.618	2.648	2.728	2.692	2.711	2.737	2.739	2.712	2.624	2.657	2.648	2.586	
	Ebn at Noon	332	326	322	305	293	287	294	307	316	328	333	332	
	Edh at Noon	32	30	25	23	19	17	18	22	27	29	31	33	
All-Sky Solar Radiation	RadAvg	2309	2001	1646	1164	784	602	654	923	1323	1761	2059	2298	
	RadStd	151	138	102	74	55	66	43	70	124	156	128	122	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	+0.85	N/A	N/A	+1.57	N/A	N/A	-34	-211	+295	+119

Nomenclature: See separate page