

MOUNT BULLER, AustraliaWMO: **948940**Lat: **37.145S**Lon: **146.439E**Elev: **1707**StdP: **82.43**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-5.5	-4.7	-20.8	0.7	4.6	-16.4	1.1	4.8	20.0	1.7	17.9	1.5	4.1	180	0.778

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.3	22.7	13.3	20.9	12.7	19.4	11.8	15.5	19.2	14.4	18.1	13.4	17.3	5.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.6	16.6	13.1	11.6	15.6	11.9	10.7	14.7	49.9	19.3	46.3	18.0	43.4	17.5	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.7	12.8	DB	-7.2	26.3	0.6	1.6	-7.6	27.5	-8.0	28.4	-8.4	29.3	-8.8	30.4	(4)
(5)			WB	-7.6	16.8	0.9	1.5	-8.2	17.8	-8.8	18.7	-9.3	19.5	-9.9	20.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	13.1	12.7	10.2	6.3	3.2	0.9	-0.8	-0.3	1.8	5.0	8.3	10.5	(6)	
	DBStd	6.08	4.82	4.24	4.19	3.62	2.86	2.44	2.05	2.42	3.17	4.25	4.66	4.67	(7)	
	HDD10.0	1902	27	22	49	118	212	274	334	320	246	164	86	51	(8)	
	HDD18.3	4569	172	161	254	362	469	524	592	578	496	414	302	244	(9)	
	CDD10.0	389	122	98	54	6	0	0	0	0	0	8	34	67	(10)	
	CDD18.3	14	8	3	1	0	0	0	0	0	0	0	0	2	(11)	
	CDH23.3	36	24	8	1	0	0	0	0	0	0	0	1	3	(12)	
	CDH26.7	2	1	1	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.6	5.1	4.7	4.9	5.3	6.3	5.8	5.7	5.9	6.1	5.9	5.6	5.4	(14)	
(15) Precipitation	PrecAvg	1277	64	63	65	80	104	144	145	135	128	96	92	75	(15)	
	PrecMax	1865	164	221	182	194	235	253	295	257	249	210	182	197	(16)	
	PrecMin	968	2	0	15	16	6	43	26	33	36	22	36	9	(17)	
	PrecStd	238	47	59	44	47	60	59	57	64	54	50	47	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	24.6	22.0	15.8	11.1	8.7	6.0	7.6	11.9	17.2	20.6	23.3	(19)	
		MCWB	14.8	14.5	12.8	9.9	6.2	2.6	3.5	4.5	6.2	9.3	11.5	13.2	(20)	
	2%	DB	23.3	21.7	19.1	13.6	9.3	6.8	4.1	6.1	9.7	15.0	18.4	21.1	(21)	
		MCWB	13.6	12.7	11.4	8.6	5.3	2.5	1.9	3.2	5.1	8.9	10.9	13.1	(22)	
	5%	DB	21.4	19.7	17.3	12.1	8.1	5.7	3.2	4.6	8.2	13.1	16.7	19.1	(23)	
		MCWB	12.8	12.2	11.1	7.9	4.8	2.0	1.4	2.4	4.7	7.7	10.1	11.4	(24)	
	10%	DB	19.6	18.2	15.6	10.9	7.1	4.4	2.2	3.4	6.6	11.3	15.0	17.3	(25)	
		MCWB	12.2	11.8	10.5	7.4	4.2	1.7	0.7	1.6	4.1	6.9	9.4	11.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.0	17.0	14.9	11.9	8.2	6.5	4.7	6.3	7.7	12.5	14.7	16.4	(27)	
		MCDB	20.6	20.0	17.0	13.1	8.9	6.7	4.9	6.9	9.3	14.0	18.0	19.6	(28)	
	2%	WB	15.4	15.2	13.3	10.1	7.0	5.0	3.3	4.3	6.4	10.3	12.5	14.5	(29)	
		MCDB	20.4	18.1	16.7	12.1	8.1	5.4	3.6	5.1	8.0	12.7	16.2	17.8	(30)	
	5%	WB	14.3	14.0	12.3	9.1	6.1	3.7	2.2	3.3	5.4	8.9	11.2	13.1	(31)	
		MCDB	18.8	17.3	15.4	11.1	7.1	4.2	2.6	4.2	6.9	11.3	14.6	17.1	(32)	
	10%	WB	13.4	13.1	11.4	8.3	5.3	2.7	1.2	2.2	4.4	7.9	10.3	11.9	(33)	
		MCDB	17.9	16.7	14.4	10.3	6.4	3.3	1.5	3.0	5.9	10.4	13.8	15.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	6.7	6.2	5.0	3.9	3.4	2.9	3.4	4.7	6.2	6.6	7.1	(35)	
		MCDBR	8.0	7.5	7.2	5.9	4.9	4.9	4.1	4.6	6.3	7.3	7.5	7.8	(36)	
	5% WB	MCWBR	5.2	5.0	4.8	4.7	4.3	4.4	3.6	4.0	5.0	5.3	5.4	5.3	(37)	
		MCWBR	7.1	6.5	6.1	5.1	4.1	3.8	3.3	3.8	5.5	6.3	6.6	6.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.290	0.286	0.266	0.261	0.249	0.241	0.240	0.247	0.267	0.269	0.280	0.294	(40)	
		taud	2.618	2.648	2.728	2.692	2.711	2.737	2.739	2.712	2.624	2.657	2.648	2.586	(41)	
	Ebn at Noon		1046	1029	1015	963	923	906	926	967	996	1035	1050	1046	(42)	
		Edh at Noon	100	93	79	72	61	55	58	69	86	91	97	105	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.28	6.31	5.19	3.67	2.47	1.90	2.06	2.91	4.17	5.55	6.49	7.24	(44)	
	RadStd		0.47	0.43	0.32	0.23	0.17	0.21	0.14	0.22	0.39	0.49	0.41	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	+0.47	N/A	N/A	+0.87	N/A	N/A	-19	-117	+164	+66

Nomenclature: See separate page