

FALLS CREEK, Australia

WMO: 949030

Lat: 36.8708S

Lon: 147.2756E

Elev: 1771

StdP: 81.78

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-6.1	-5.2	-18.2	0.9	3.4	-13.8	1.4	3.1	19.4	1.1	17.2	1.0	6.1	170	0.797

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.1	22.2	13.6	20.5	12.9	19.1	12.4	15.5	19.2	14.6	18.1	13.7	17.2	5.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.6	16.5	13.3	11.9	15.8	12.4	11.2	14.9	49.8	19.1	47.0	18.1	44.4	17.3	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.8	12.3	DB	-7.7	24.5	0.9	1.8	-8.3	25.8	-8.8	26.8	-9.3	27.8	-9.9	29.1	(4)
(5)			WB	-8.0	17.0	0.9	1.2	-8.7	17.8	-9.2	18.6	-9.8	19.3	-10.4	20.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	13.1	12.5	10.1	6.2	3.0	0.6	-1.0	-0.5	1.8	5.0	8.4	10.4	(6)	
	DBStd	6.00	4.31	3.94	3.90	3.47	3.02	2.56	2.02	2.63	3.13	4.02	4.36	4.13	(7)	
	HDD10.0	1906	21	20	48	118	216	283	341	327	245	161	80	46	(8)	
	HDD18.3	4598	168	166	257	364	474	533	599	585	495	412	298	246	(9)	
	CDD10.0	359	117	90	49	5	0	0	0	0	0	7	32	59	(10)	
	CDD18.3	9	6	2	1	0	0	0	0	0	0	0	0	1	(11)	
	CDH23.3	18	12	6	0	0	0	0	0	0	0	0	0	1	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.6	5.5	4.9	5.1	5.2	5.7	6.0	6.2	5.8	6.4	5.5	5.2	5.2	(14)	
(15) Precipitation	PrecAvg	1121	73	74	67	61	85	129	123	125	124	107	93	76	(15)	
	PrecMax	1514	222	277	177	159	223	255	226	283	278	220	187	192	(16)	
	PrecMin	509	0	0	3	0	11	45	1	28	18	11	28	9	(17)	
	PrecStd	234	50	62	41	38	56	53	51	62	54	62	44	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.0	24.3	21.3	15.8	11.7	8.9	5.9	8.2	11.7	16.8	20.7	22.1	(19)	
		MCWB	14.6	15.0	12.5	10.2	6.3	2.9	2.1	3.2	6.6	9.6	12.1	12.9	(20)	
	2%	DB	22.8	21.2	19.0	13.6	9.7	6.8	3.9	6.3	9.5	14.4	18.5	20.1	(21)	
		MCWB	14.0	13.7	11.9	9.0	5.8	2.7	1.1	2.8	5.3	8.7	11.4	12.6	(22)	
	5%	DB	21.0	19.7	17.3	12.1	8.4	5.4	2.9	4.7	8.0	12.7	16.6	18.2	(23)	
		MCWB	13.1	13.1	11.2	8.2	5.4	2.3	0.9	2.3	5.2	7.8	10.3	11.5	(24)	
	10%	DB	19.5	18.2	15.6	10.8	7.2	4.2	1.9	3.4	6.6	11.1	14.9	16.7	(25)	
		MCWB	12.7	12.5	10.7	7.7	4.9	2.0	0.7	1.6	4.3	7.2	9.7	11.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.9	16.8	14.8	11.7	9.2	6.2	4.3	5.8	8.0	11.7	14.2	15.0	(27)	
		MCDB	21.3	20.4	17.5	13.6	9.5	6.5	4.6	6.4	9.3	13.9	17.5	18.2	(28)	
	2%	WB	15.7	15.5	13.6	10.1	7.6	4.6	2.7	4.1	6.7	10.1	12.7	13.8	(29)	
		MCDB	20.0	18.7	16.2	12.3	8.4	5.3	3.1	4.9	8.4	12.5	16.0	17.6	(30)	
	5%	WB	14.8	14.5	12.6	9.1	6.6	3.5	1.8	3.0	5.7	8.9	11.7	12.8	(31)	
		MCDB	18.8	17.5	15.2	11.1	7.5	4.2	2.2	3.8	7.2	11.4	14.8	16.5	(32)	
	10%	WB	13.9	13.6	11.7	8.3	5.5	2.6	1.1	1.9	4.6	7.9	10.7	11.8	(33)	
		MCDB	17.8	16.6	14.4	10.2	6.6	3.3	1.5	2.9	6.1	10.3	13.7	15.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	7.7	7.1	5.7	4.5	3.7	3.3	3.9	5.1	6.8	7.4	8.0	(35)	
		MCDBR	8.7	8.5	8.3	6.8	5.9	5.4	4.7	5.5	6.6	8.0	8.3	8.5	(36)	
	5% WB	MCWBR	5.2	5.3	5.3	4.9	5.1	4.8	4.1	4.7	5.2	5.6	5.7	5.5	(37)	
		MCWBR	7.7	7.1	6.7	5.7	4.9	4.3	3.7	4.6	5.9	7.2	7.3	7.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.330	0.292	0.264	0.259	0.246	0.238	0.237	0.244	0.262	0.269	0.279	0.294	(40)	
		taud	2.454	2.622	2.744	2.701	2.721	2.752	2.757	2.724	2.647	2.656	2.654	2.588	(41)	
	Ebn at Noon		1004	1023	1018	967	929	913	933	973	1003	1036	1051	1046	(42)	
		Edh at Noon	118	96	78	71	60	54	57	68	84	92	96	104	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.22	6.25	5.21	3.76	2.56	1.97	2.15	3.00	4.29	5.67	6.53	7.27	(44)	
	RadStd		0.46	0.47	0.36	0.24	0.17	0.20	0.14	0.24	0.43	0.50	0.43	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-67	+128	+56

Nomenclature: See separate page