

OMEQ, Australia

WMO: 949080

Lat: 37.1017S

Lon: 147.6008E

Elev: 690

StdP: 93.30

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.9	-1.8	-3.9	3.0	0.7	-2.9	3.2	1.4	10.4	9.8	9.5	9.2	1.2	340	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.8	32.1	17.6	29.8	17.2	27.8	16.7	19.6	27.2	18.7	25.8	18.0	24.6	5.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	13.7	21.1	16.6	12.9	20.6	15.6	12.1	20.1	58.9	27.2	56.0	26.1	53.3	24.7	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.2	7.3	-5.0	35.8	0.9	1.8	-5.7	37.1	-6.3	38.2	-6.8	39.2	-7.5	40.5		
			-5.4	21.3	0.9	1.0	-6.0	22.0	-6.6	22.6	-7.1	23.1	-7.8	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	18.8	17.5	15.8	12.0	8.5	6.0	5.6	6.4	8.8	11.5	14.4	16.2
	DBStd	5.42	3.79	3.48	3.36	2.82	2.48	2.03	2.03	2.16	2.70	3.32	3.52	3.49
	HDD10.0	531	0	1	1	12	61	122	138	114	55	22	4	2
	HDD18.3	2525	41	51	92	191	306	371	395	370	286	212	126	85
	CDD10.0	1171	273	212	182	72	13	1	1	2	19	69	136	192
	CDD18.3	125	56	29	14	1	0	0	0	0	0	1	7	18
	CDH23.3	1981	807	391	223	14	0	0	0	0	1	36	167	343
	CDH26.7	696	349	129	61	1	0	0	0	0	0	5	38	112
Wind	WSAvg	3.4	3.6	3.3	3.1	2.9	3.1	2.9	3.7	3.6	3.6	3.6	3.5	3.5
Precipitation	PrecAvg	680	55	45	51	45	50	51	53	62	62	70	73	63
	PrecMax	1120	158	148	139	124	179	169	111	132	112	140	181	203
	PrecMin	417	4	2	6	4	5	11	10	11	20	16	10	2
	PrecStd	152	37	33	29	29	37	33	29	29	22	33	39	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.3	33.8	31.2	25.3	18.6	14.0	14.0	16.7	21.0	27.3	30.6	33.5
		MCWB	18.7	18.8	17.3	15.2	11.8	9.5	9.5	10.5	11.7	13.7	16.4	17.3
	2%	DB	33.1	30.1	28.4	22.4	16.6	12.4	12.1	14.3	18.8	23.8	27.4	29.9
		MCWB	18.0	17.3	16.6	14.1	11.4	8.8	8.1	9.0	11.1	13.8	15.5	16.9
	5%	DB	30.6	27.8	25.8	20.4	15.1	11.3	10.9	12.7	16.9	21.7	25.2	27.3
		MCWB	17.7	17.2	15.9	13.3	10.6	8.2	7.5	8.2	10.5	13.3	15.2	16.2
	10%	DB	28.0	25.6	23.3	18.4	13.7	10.1	9.7	11.2	15.1	19.5	22.8	24.7
		MCWB	17.4	16.6	15.5	12.6	9.9	7.7	6.8	7.5	9.7	12.3	15.0	15.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	20.9	19.5	16.7	13.6	10.8	10.5	11.0	13.2	16.3	19.0	19.5
		MCDB	30.1	28.5	26.6	22.2	15.7	13.1	12.6	15.0	17.7	21.5	25.0	26.0
	2%	WB	19.7	19.3	18.1	15.0	12.1	9.6	8.9	9.6	12.1	14.9	17.6	18.2
		MCDB	28.5	25.8	23.9	20.6	15.8	11.5	10.9	13.6	17.2	20.7	24.1	25.2
	5%	WB	18.9	18.4	17.2	14.0	11.0	8.7	7.9	8.7	11.1	13.9	16.4	17.2
		MCDB	26.8	24.4	22.9	18.4	14.3	10.6	10.1	11.9	16.0	20.0	22.3	24.4
	10%	WB	18.1	17.4	16.2	13.1	10.1	7.9	7.1	7.7	10.1	13.0	15.4	16.3
		MCDB	25.6	23.2	21.7	17.3	13.1	9.8	9.3	10.8	14.5	18.5	21.1	23.3
Mean Daily Temperature Range	5% DB	MDBR	14.8	13.5	12.9	12.2	10.3	8.8	8.4	9.6	11.6	13.4	13.7	14.2
		MCDBR	20.0	18.2	17.7	15.9	12.7	10.8	10.0	12.2	14.3	17.4	18.5	19.2
		MCWBR	7.2	7.2	7.3	8.2	7.8	7.4	6.6	7.6	7.9	8.8	8.2	8.1
	5% WB	MCDBR	15.9	13.8	14.0	12.9	11.2	9.6	8.5	11.3	12.9	15.0	14.3	15.1
	MCWBR	6.6	6.2	6.6	7.1	7.2	6.8	5.9	7.4	7.7	8.3	7.4	7.1	
Clear-Sky Solar Irradiance	taub	0.401	0.343	0.304	0.295	0.281	0.268	0.266	0.277	0.303	0.310	0.321	0.349	
	taud	2.298	2.515	2.637	2.625	2.633	2.675	2.684	2.634	2.547	2.559	2.560	2.468	
	Ebn at Noon	933	967	971	921	879	867	891	929	956	991	1007	989	
	Edh at Noon	138	107	87	77	66	59	62	75	94	101	106	118	
All-Sky Solar Radiation	RadAvg	6.96	6.01	5.04	3.66	2.55	1.98	2.21	3.06	4.30	5.58	6.34	7.07	
	RadStd	0.48	0.47	0.39	0.26	0.15	0.17	0.13	0.21	0.40	0.45	0.46	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (27 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-81	+128	+52

Nomenclature: See separate page