

GELANTIPY, Australia

WMO: 949130

Lat: 37.2200S

Lon: 148.2625E

Elev: 756

StdP: 92.57

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.1	0.8	-4.6	2.8	7.0	-3.2	3.2	5.7	12.4	8.2	10.8	8.7	3.0	20	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	30.5	18.0	28.2	17.4	26.2	16.8	20.2	25.6	18.9	24.8	18.0	23.7	4.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	14.8	21.7	17.2	13.5	20.5	16.1	12.5	19.6	61.4	25.6	57.0	24.7	53.7	23.7	33.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.7	7.8	-1.8	34.5	0.8	1.9	-2.4	35.9	-2.8	37.0	-3.2	38.1	-3.8	39.5		
			-2.3	22.9	0.6	3.9	-2.8	25.7	-3.2	28.0	-3.5	30.2	-4.0	33.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	17.5	17.1	15.1	11.6	8.9	6.6	5.9	6.7	8.8	11.0	13.2	15.2
	DBStd	5.20	4.29	4.02	3.79	3.15	2.60	2.15	2.03	2.43	3.03	3.63	4.06	4.11
	HDD10.0	523	1	1	3	18	54	106	129	106	59	31	13	4
	HDD18.3	2633	69	66	116	201	294	353	386	359	287	227	160	114
	CDD10.0	1047	232	200	159	67	19	2	1	4	22	63	111	167
	CDD18.3	115	43	32	14	1	0	0	0	0	1	7	18	
	CDH23.3	1216	464	299	128	9	0	0	0	1	16	78	221	
	CDH26.7	371	173	91	29	1	0	0	0	1	14	63		
Wind	WSAvg	3.7	3.6	3.5	3.4	3.3	3.6	3.7	4.0	4.1	4.1	3.9	3.7	3.6
Precipitation	PrecAvg	762	66	71	59	57	43	74	52	56	62	74	79	69
	PrecMax	988	164	156	167	139	94	211	140	118	145	139	182	155
	PrecMin	474	15	6	9	9	14	15	13	18	30	13	14	22
	PrecStd	124	35	47	38	36	23	53	36	24	28	32	40	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.3	32.5	29.9	24.7	18.3	14.9	14.1	17.1	20.7	25.4	28.5	31.8
		MCWB	18.8	18.5	16.7	14.6	11.9	10.2	8.8	11.3	12.1	14.2	16.8	17.1
	2%	DB	30.9	29.3	26.9	21.0	16.2	12.9	12.1	14.4	18.3	22.5	25.5	28.5
		MCWB	17.9	18.4	16.5	14.0	11.4	8.9	7.6	9.1	11.0	13.7	15.8	17.2
	5%	DB	28.3	26.9	24.1	19.1	14.8	11.5	10.8	12.7	16.5	20.2	23.2	25.7
		MCWB	17.5	17.8	15.9	13.1	10.4	8.0	7.0	8.0	10.3	12.8	15.2	16.6
	10%	DB	25.7	24.7	21.7	17.2	13.4	10.2	9.6	11.2	14.6	18.1	20.8	23.2
		MCWB	17.3	17.2	15.5	12.3	9.7	7.2	6.3	7.0	9.5	12.1	14.8	15.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	26.2	20.4	17.0	13.7	11.4	9.9	12.6	13.9	17.0	19.4	20.5
		MCDB	27.0	26.7	23.9	19.9	15.1	13.5	12.1	15.8	17.2	21.2	22.6	24.8
	2%	WB	19.7	20.3	18.2	15.0	12.1	9.6	8.3	9.8	12.1	15.0	17.6	18.3
		MCDB	26.7	25.3	22.7	18.6	15.3	12.2	10.5	13.1	17.1	19.6	22.5	24.9
	5%	WB	18.7	18.9	17.1	13.8	11.1	8.6	7.5	8.6	11.0	13.7	16.3	17.2
		MCDB	25.5	24.3	21.6	17.0	14.0	10.7	9.8	11.9	15.4	18.5	21.2	23.3
	10%	WB	17.7	17.8	16.0	12.8	10.1	7.7	6.7	7.5	9.9	12.5	15.1	16.2
		MCDB	24.1	22.7	20.6	15.8	12.8	9.7	9.0	10.6	13.9	17.3	19.7	21.9
Mean Daily Temperature Range	5% DB	MDBR	11.6	10.8	9.7	8.7	7.1	6.0	6.3	7.3	8.6	9.9	10.3	11.2
		MCDBR	16.0	14.8	13.5	11.6	9.0	7.6	7.9	9.6	11.7	13.5	14.4	15.6
		MCWBR	6.2	6.0	5.6	5.7	5.4	5.0	5.1	5.7	6.2	6.8	6.7	7.0
	5% WB	MCDBR	13.8	12.1	11.1	9.8	8.0	6.7	6.9	9.0	10.8	11.7	12.0	13.0
		MCWBR	6.8	6.5	6.2	5.9	5.3	4.8	4.9	5.8	6.2	6.7	6.7	7.0
Clear-Sky Solar Irradiance	taub	0.404	0.351	0.307	0.297	0.278	0.268	0.263	0.273	0.299	0.310	0.320	0.339	
	taud	2.286	2.488	2.621	2.619	2.653	2.684	2.705	2.662	2.567	2.561	2.565	2.508	
	Ebn at Noon	929	958	967	917	883	867	895	935	960	991	1007	999	
	Edh at Noon	140	110	89	78	65	59	61	73	92	101	105	113	
All-Sky Solar Radiation	RadAvg	6.74	5.79	4.88	3.57	2.56	1.99	2.28	3.13	4.33	5.53	6.22	6.91	
	RadStd	0.48	0.45	0.39	0.28	0.13	0.15	0.14	0.19	0.34	0.39	0.47	0.46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+120	+33
(47)	Regional (29 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	-81	+128	+52

Nomenclature: See separate page