

PERISHER VALLEY, Australia

WMO: 949150

Lat: 36.4069S

Lon: 148.4056E

Elev: 1738

StdP: 82.12

Time Zone: 10.00 (AUS)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-7.5	-6.2	-19.8	0.8	2.6	-16.7	1.1	1.9	16.2	0.3	14.3	-0.6	1.1	230	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	23.6	13.7	21.8	12.8	20.1	12.2	15.2	19.9	14.3	18.9	13.5	17.9	3.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	12.1	16.0	12.8	11.4	15.6	11.8	10.7	15.3	48.9	19.6	46.2	18.9	43.8	18.0	17.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.3	8.7	DB	-11.4	26.4	1.5	1.9	-12.5	27.8	-13.4	28.9	-14.3	30.0	-15.4	31.3
			WB	-12.3	16.6	1.6	0.6	-13.4	17.0	-14.4	17.4	-15.2	17.7	-16.4	18.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	13.3	11.7	9.7	6.4	2.9	0.6	-0.5	-0.4	2.4	5.9	8.4	10.7
	DBStd	5.64	3.75	2.95	3.26	2.95	2.76	2.31	2.17	2.50	2.99	3.74	3.86	3.69
	HDD10.0	1811	14	14	45	113	222	283	326	323	227	135	74	35
	HDD18.3	4547	161	186	267	358	480	533	584	582	477	386	298	237
	CDD10.0	310	115	62	37	4	0	0	0	0	1	8	27	57
	CDD18.3	6	3	1	0	0	0	0	0	0	0	0	1	1
	CDH23.3	66	49	7	1	0	0	0	0	0	0	0	2	7
	CDH26.7	3	3	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.3	2.9	2.5	2.9	2.7	3.9	3.3	4.2	4.0	3.8	3.4	3.3	3.0
Precipitation	PrecAvg	1085	81	82	66	68	74	102	90	110	105	106	106	95
	PrecMax	1737	245	331	307	199	182	357	215	268	195	244	226	184
	PrecMin	556	6	6	0	0	0	32	25	29	15	22	31	33
	PrecStd	238	49	67	58	44	46	66	46	55	44	56	47	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	24.4	22.0	17.2	13.1	11.0	7.2	8.7	13.1	18.5	22.0	24.2
		MCWB	14.7	13.7	12.6	10.8	5.4	3.7	1.7	2.7	5.9	8.2	11.6	13.1
	2%	DB	24.7	21.9	19.8	15.1	11.3	8.2	5.9	6.5	10.7	16.2	19.1	21.9
		MCWB	14.1	12.9	12.4	8.9	5.4	1.4	1.6	1.6	5.0	8.1	11.0	12.4
	5%	DB	22.5	20.1	17.6	13.8	9.8	6.3	4.6	5.3	8.8	14.4	17.6	19.8
		MCWB	13.4	12.5	11.1	8.0	4.4	2.4	0.8	1.3	4.2	7.4	10.0	11.6
	10%	DB	20.7	18.4	15.8	12.2	8.0	4.7	3.4	4.0	7.5	12.9	15.7	18.1
		MCWB	12.6	11.8	10.4	7.5	3.6	1.7	0.6	0.5	3.4	6.8	9.4	11.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.4	16.2	14.4	12.2	9.7	6.1	5.2	4.6	7.1	11.1	14.0	15.1
		MCDB	22.5	19.1	18.3	15.4	10.8	6.6	6.0	6.4	9.9	14.6	17.0	17.5
	2%	WB	15.5	14.8	13.3	10.4	7.2	4.5	3.5	3.2	6.1	9.9	12.6	13.5
		MCDB	21.2	18.5	17.2	13.4	10.0	5.9	4.1	5.2	9.5	13.1	16.6	18.1
	5%	WB	14.7	13.9	12.4	9.2	5.7	3.3	2.4	2.2	5.2	8.8	11.4	12.8
		MCDB	20.0	17.4	16.0	12.2	7.8	4.6	3.3	3.9	8.4	12.5	15.7	18.0
	10%	WB	13.9	13.0	11.5	8.4	4.7	2.4	1.2	1.3	4.1	7.8	10.3	11.9
		MCDB	19.1	16.6	14.5	11.2	6.5	3.9	2.3	3.0	6.6	11.5	14.5	17.0
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.9	9.5	9.4	7.4	6.8	5.8	6.2	7.0	9.5	10.2	10.9
		MCDBR	13.9	13.8	12.8	12.5	11.7	11.0	9.0	8.6	9.2	12.3	12.8	13.8
		MCWBR	7.0	7.1	7.3	7.6	7.4	7.1	6.1	5.9	6.2	7.2	7.2	7.1
	5% WB	MCDBR	11.2	9.7	9.9	9.7	7.5	7.3	5.4	6.3	7.8	10.3	9.8	11.3
		MCWBR	6.4	6.1	6.0	6.6	5.9	5.8	4.8	5.1	5.8	7.0	6.3	6.3
Clear-Sky Solar Irradiance	taub	0.333	0.293	0.268	0.259	0.247	0.237	0.234	0.241	0.262	0.273	0.283	0.287	
	taud	2.452	2.628	2.722	2.703	2.700	2.746	2.763	2.727	2.635	2.626	2.633	2.627	
	Ebn at Noon	1002	1022	1015	969	930	917	940	978	1004	1032	1048	1054	
	Edh at Noon	119	95	80	72	62	55	57	68	86	95	98	101	
All-Sky Solar Radiation	RadAvg	7.22	6.14	5.22	3.83	2.73	2.08	2.30	3.18	4.51	5.82	6.58	7.33	
	RadStd	0.52	0.55	0.43	0.29	0.12	0.17	0.13	0.19	0.38	0.47	0.48	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.42	N/A	N/A	+0.98	N/A	N/A	N/A	N/A	+121	+57

Nomenclature: See separate page