

KHANCOBAN, AustraliaWMO: **949190**Lat: **36.2303S**Lon: **148.1406E**Elev: **1115**StdP: **14.11**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.7	31.3	28.1	23.0	39.1	29.8	24.9	38.8	18.6	50.9	16.4	50.6	1.0	170	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.0	95.5	66.3	91.6	65.3	88.3	64.4	70.8	82.0	69.2	81.4	67.7	80.5	8.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.5	109.1	71.9	66.3	101.1	71.1	64.3	93.9	69.9	35.4	81.2	33.9	81.6	32.7	80.4	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.5	14.1	11.9	DB	27.1	101.9	0.9	3.9	26.5	104.8	26.0	107.0	25.5	109.2	24.9	112.1
			WB	27.0	73.7	0.9	2.2	26.4	75.3	25.9	76.6	25.4	77.9	24.8	79.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	72.3	70.9	65.9	57.7	50.1	44.9	44.2	46.2	51.1	55.9	62.5	67.0	(6)
(7)		DBStd	11.00	6.23	5.68	5.69	4.93	4.41	4.06	3.83	3.61	4.35	5.33	6.11	5.82	(7)
(8)		HDD50	575	0	0	0	5	54	158	184	128	37	8	1	0	(8)
(9)		HDD65	3466	15	13	59	222	462	602	645	582	418	285	118	45	(9)
(10)		CDD50	3249	691	586	493	237	57	6	4	11	69	191	376	528	(10)
(11)		CDD65	664	240	179	86	4	0	0	0	0	0	4	43	108	(11)
(12)		CDH74	8863	3101	2119	1142	92	0	0	0	0	2	130	702	1575	(12)
(13)		CDH80	3807	1572	959	398	13	0	0	0	0	0	21	216	628	(13)
(14)	Wind	WSAvg	3.6	4.5	4.2	4.0	2.7	2.5	2.4	3.0	3.4	3.9	3.9	4.1	4.3	(14)
(15)	Precipitation	PrecAvg	37.8	2.5	1.8	2.2	2.4	3.3	3.4	4.0	4.5	3.9	3.9	3.1	2.9	(15)
(16)		PrecMax	56.0	7.6	4.9	7.4	7.8	8.9	8.8	10.4	8.6	8.6	9.4	6.5	7.0	(16)
(17)		PrecMin	15.4	0.0	0.0	0.1	0.1	0.1	0.6	0.7	0.9	0.9	0.4	0.2	0.2	(17)
(18)		PrecStd	8.9	1.8	1.4	1.7	1.7	2.0	1.7	2.2	2.0	1.7	2.1	1.7	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.9	99.4	93.2	81.6	69.0	60.5	60.4	64.9	73.1	82.8	90.2	97.1	(19)
(20)			MCWB	68.0	66.9	64.2	60.7	56.6	52.7	52.7	54.0	58.5	62.2	62.9	65.7	(20)
(21)		2%	DB	97.0	93.5	88.2	76.3	65.1	56.8	56.1	60.4	68.9	77.7	85.9	91.1	(21)
(22)			MCWB	67.2	66.0	63.7	59.7	55.2	50.8	50.1	51.5	57.3	60.8	64.0	65.0	(22)
(23)		5%	DB	92.8	89.6	84.3	72.9	62.0	54.6	53.5	57.4	65.4	73.3	81.8	86.9	(23)
(24)			MCWB	66.2	65.0	62.4	58.5	53.8	50.1	48.6	49.7	55.0	58.7	62.6	63.6	(24)
(25)		10%	DB	88.8	86.2	80.8	69.6	58.7	52.4	51.2	54.5	62.1	69.4	77.7	82.7	(25)
(26)			MCWB	65.2	64.2	61.4	57.1	52.6	49.0	47.4	48.3	53.2	57.7	61.8	62.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	73.3	69.9	64.9	60.3	55.0	54.8	55.7	60.7	65.6	70.3	71.0	(27)
(28)			MADB	84.8	80.7	79.3	72.7	63.4	57.5	57.5	61.9	69.2	75.3	79.1	80.7	(28)
(29)		2%	WB	70.8	70.7	67.5	62.3	57.0	52.6	51.3	53.0	58.5	62.9	67.4	68.7	(29)
(30)			MADB	85.2	79.2	77.5	70.6	62.2	54.8	54.8	58.3	65.9	72.3	78.5	79.2	(30)
(31)		5%	WB	69.2	68.7	65.8	60.6	55.0	51.0	49.3	50.8	56.5	61.0	65.4	66.8	(31)
(32)			MADB	84.4	79.8	75.8	68.1	59.7	53.4	52.2	55.4	63.1	69.8	75.9	79.4	(32)
(33)		10%	WB	67.8	66.9	64.1	58.9	53.3	49.4	47.7	49.1	54.3	59.1	63.5	65.1	(33)
(34)			MADB	82.5	79.7	74.7	67.0	57.7	51.8	50.4	53.3	60.6	67.4	73.3	78.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	30.0	27.8	26.7	24.4	19.2	15.7	15.2	17.7	21.0	24.4	26.5	28.3	(35)
(36)			MCDBR	35.8	33.3	32.2	28.9	23.9	19.1	18.3	23.6	26.8	31.7	33.1	34.9	(36)
(37)			MCWBR	10.8	10.4	11.4	13.4	13.7	12.9	12.2	14.2	15.4	16.2	13.5	12.1	(37)
(38)		5% WB	MCDBR	29.0	25.0	24.2	23.3	20.0	15.6	15.5	20.0	24.6	26.3	26.4	27.1	(38)
(39)			MCWBR	10.6	9.6	10.6	12.1	12.4	11.2	10.9	12.9	14.8	14.7	12.5	11.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.415	0.359	0.323	0.313	0.300	0.282	0.280	0.291	0.324	0.335	0.350	0.356	(40)	
(41)		taud	2.283	2.493	2.582	2.568	2.564	2.626	2.629	2.584	2.483	2.477	2.477	2.469	(41)	
(42)		Ebn at Noon	292	302	302	286	272	270	278	290	297	306	310	312	(42)	
(43)		Edh at Noon	45	35	30	26	23	20	21	25	32	35	36	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2330	1995	1687	1236	866	659	722	998	1426	1859	2115	2354	(44)	
(45)		RadStd	155	166	132	86	47	60	43	73	134	160	148	122	45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (31 neighbors)		+0.77	N/A	N/A	+1.80	N/A	N/A	N/A	+209	+101

Nomenclature: See separate page