

CANBERRA AP, Australia

WMO: 949260

Lat: 35.3089S

Lon: 149.2003E

Elev: 578

StdP: 94.58

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.6	-2.4	-6.0	2.4	6.6	-4.6	2.7	4.8	12.0	9.8	10.9	9.1	0.8	0	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	34.5	18.1	32.2	17.6	30.2	17.0	20.4	28.0	19.6	26.8	18.8	25.8	5.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	14.4	22.0	17.5	13.4	21.2	16.5	12.6	20.8	61.3	27.7	58.3	26.6	55.6	25.8	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.4	8.5	DB	-5.8	37.8	1.1	1.9	-6.6	39.2	-7.3	40.3	-7.9	41.4	-8.7	42.8	(4)
			WB	-6.2	21.9	1.1	1.0	-7.0	22.6	-7.6	23.2	-8.3	23.8	-9.1	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	21.5	20.5	17.9	13.7	9.7	7.1	6.2	7.3	10.3	13.4	16.8	19.5
	DBStd	6.04	3.47	3.18	2.95	2.84	2.66	2.30	2.24	2.25	2.54	3.11	3.71	3.30
	HDD10.0	373	0	0	0	4	38	90	119	89	26	6	1	0
	HDD18.3	2026	11	13	44	141	268	337	376	343	240	155	72	26
	CDD10.0	1694	355	294	244	115	29	4	2	4	36	111	204	295
	CDD18.3	304	108	74	31	2	0	0	0	0	2	26	62	
	CDH23.3	3726	1243	764	350	47	0	0	0	3	103	412	804	
	CDH26.7	1533	614	313	103	7	0	0	0	1	19	149	326	
Wind	WSAvg	3.5	3.7	3.5	3.2	2.8	2.9	3.1	3.4	3.9	4.0	3.9	3.8	3.9
Precipitation	PrecAvg	614	58	56	50	43	37	39	42	47	57	57	66	58
	PrecMax	977	218	216	244	187	134	144	121	156	151	161	137	160
	PrecMin	262	1	0	2	0	0	2	4	2	3	2	0	0
	PrecStd	149	46	47	46	41	29	32	30	28	33	38	36	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.9	36.2	32.5	27.7	21.2	16.5	15.6	19.0	23.3	29.1	33.9	35.8
		MCWB	18.5	19.3	17.1	15.3	12.9	11.2	10.4	11.0	12.9	14.6	16.3	17.3
	2%	DB	35.2	32.9	29.5	24.4	19.1	14.8	13.9	16.4	21.2	26.1	30.7	32.6
		MCWB	18.5	18.2	16.6	14.4	12.3	10.2	9.0	9.8	12.2	14.2	16.0	17.2
	5%	DB	32.9	30.4	27.1	22.4	17.5	13.5	12.7	14.8	19.2	23.8	27.9	30.2
		MCWB	18.1	17.7	16.3	13.9	11.6	9.4	8.4	9.0	11.3	13.5	15.5	16.6
	10%	DB	30.1	28.1	24.9	20.4	15.9	12.4	11.5	13.2	17.4	21.4	25.2	28.0
		MCWB	17.5	17.4	16.0	13.1	10.9	8.9	7.6	8.2	10.7	13.0	14.9	16.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	22.0	20.0	17.3	15.3	12.6	12.1	12.5	14.7	17.2	19.4	20.3
		MCDB	30.2	29.9	25.3	23.1	17.6	14.3	13.4	16.1	20.0	23.2	26.5	27.1
	2%	WB	20.5	20.4	18.8	15.9	13.6	11.3	10.1	10.8	13.6	15.8	18.1	19.0
		MCDB	29.4	26.8	24.1	21.1	17.0	13.4	12.5	15.1	18.7	21.8	25.7	26.3
	5%	WB	19.6	19.4	17.8	15.0	12.4	10.2	9.0	9.7	12.5	14.8	17.0	18.2
		MCDB	27.9	26.1	23.5	19.7	16.4	12.6	11.6	13.8	17.5	20.8	24.1	26.0
	10%	WB	18.8	18.6	16.9	14.1	11.5	9.4	8.1	8.7	11.3	13.8	16.1	17.3
		MCDB	26.5	25.2	22.5	18.9	15.2	11.8	10.8	12.7	16.3	19.7	23.0	24.6
Mean Daily Temperature Range	5% DB	MDBR	14.4	13.3	13.0	13.3	12.7	10.9	11.1	12.2	13.0	13.8	14.0	14.4
		MCDBR	19.4	17.5	16.9	16.1	14.9	12.7	12.9	14.8	17.0	18.6	19.0	18.7
		MCWBR	5.9	5.6	6.3	7.6	8.7	8.3	8.5	8.8	9.1	8.4	7.1	6.3
	5% WB	MCDBR	15.5	13.7	13.0	13.5	12.4	10.3	10.7	13.2	14.5	14.5	15.0	14.8
		MCWBR	5.6	5.3	5.7	6.9	7.5	7.2	7.5	8.5	8.5	7.4	6.5	6.0
Clear-Sky Solar Irradiance	taub	0.384	0.346	0.317	0.297	0.288	0.273	0.268	0.280	0.306	0.325	0.337	0.340	
	taud	2.374	2.528	2.589	2.615	2.580	2.647	2.657	2.601	2.520	2.484	2.495	2.503	
	Ebn at Noon	952	968	961	926	878	872	898	932	957	978	992	999	
	Edh at Noon	129	106	93	80	72	63	66	79	97	110	113	114	
All-Sky Solar Radiation	RadAvg	7.08	6.07	5.16	3.96	2.97	2.27	2.57	3.47	4.79	5.94	6.54	7.24	
	RadStd	0.54	0.54	0.43	0.32	0.15	0.18	0.17	0.23	0.39	0.50	0.54	0.47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.43	N/A	N/A	+1.36	+0.64	+0.66	N/A	N/A	N/A	N/A
Regional (29 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	+58

Nomenclature: See separate page