

BRAIDWOOD, Australia

WMO: 949270

Lat: 35.4253S

Lon: 149.7836E

Elev: 2185

StdP: 13.57

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.7	27.1	20.9	17.0	39.2	23.2	19.0	37.7	31.3	47.8	27.4	47.0	0.8	140	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.4	91.1	64.1	86.4	63.0	82.3	62.3	68.3	80.0	66.6	77.6	65.3	75.7	12.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	101.4	71.1	63.6	95.4	69.7	62.0	90.0	68.2	33.8	80.3	32.5	77.6	31.3	75.3	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	21.7	18.7	DB	19.9	98.1	2.0	3.6	18.4	100.6	17.2	102.7	16.1	104.7	14.6	107.3	(4)
(5)			WB	19.4	71.7	2.0	1.6	17.9	72.9	16.8	73.8	15.6	74.7	14.2	75.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	66.4	65.1	61.1	54.5	48.3	44.1	42.7	44.5	49.4	53.9	58.7	63.1	(6)	
	DBStd	9.86	6.58	6.02	5.52	5.35	4.74	4.00	3.94	4.53	5.18	6.03	6.82	6.60	(7)	
	HDD50	806	0	0	0	16	89	182	230	181	72	26	8	2	(8)	
	HDD65	4202	65	66	145	316	516	628	692	636	467	345	211	115	(9)	
	CDD50	2363	507	424	345	152	38	4	3	10	55	149	268	408	(10)	
	CDD65	284	107	70	25	2	0	0	0	0	0	3	20	57	(11)	
	CDH74	3644	1281	733	306	45	0	0	0	0	1	100	398	780	(12)	
	CDH80	1392	586	286	80	5	0	0	0	0	0	14	127	294	(13)	
(14) Wind	WSAvg	7.1	7.3	6.8	6.5	5.7	6.1	6.9	7.2	8.1	8.1	7.8	7.7	7.3	(14)	
(15) Precipitation	PrecAvg	28.4	2.9	3.4	2.0	1.7	1.7	3.6	1.6	2.3	1.9	2.1	2.6	2.4	(15)	
	PrecMax	35.2	7.2	8.6	6.9	5.1	6.3	10.7	5.3	9.1	4.1	6.8	5.4	6.0	(16)	
	PrecMin	18.7	0.1	0.2	0.1	0.0	0.3	0.9	0.0	0.1	0.0	0.1	0.5	0.5	(17)	
	PrecStd	4.9	1.7	2.1	1.7	1.3	1.6	3.0	1.3	2.4	1.0	1.5	1.5	1.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.0	94.0	87.6	79.9	69.0	61.2	60.0	66.4	72.6	82.2	90.5	94.0	(19)	
		MCWB	64.7	65.1	62.7	58.5	54.3	51.2	48.4	51.7	54.8	57.1	60.7	62.1	(20)	
	2%	DB	92.0	87.7	81.5	73.4	64.9	57.4	56.4	61.2	68.8	76.6	83.2	87.6	(21)	
		MCWB	64.5	64.1	61.7	57.4	52.9	49.5	46.9	48.8	53.0	57.0	60.3	61.7	(22)	
	5%	DB	86.8	82.7	76.8	69.5	61.8	55.0	53.9	57.8	65.2	72.3	78.3	82.6	(23)	
		MCWB	64.0	64.1	61.2	56.2	51.9	48.2	46.0	47.3	51.7	55.9	59.4	61.6	(24)	
	10%	DB	81.3	77.6	72.4	65.7	58.7	52.8	51.8	54.8	61.3	67.5	73.4	77.6	(25)	
		MCWB	63.8	63.6	60.3	55.1	51.1	47.1	44.9	46.0	50.5	54.2	58.6	60.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	70.7	67.4	62.4	58.5	54.5	52.2	54.7	58.0	62.6	66.3	68.2	(27)	
		MCDB	81.5	82.3	76.9	70.7	62.6	57.6	55.6	61.0	66.3	73.6	78.1	79.4	(28)	
	2%	WB	68.5	68.2	65.0	59.7	56.1	51.6	49.3	51.0	55.6	59.6	63.7	65.8	(29)	
		MCDB	81.1	79.1	73.9	67.9	60.4	55.3	53.4	58.7	64.0	69.8	75.7	77.5	(30)	
	5%	WB	66.8	66.5	63.2	58.1	53.8	49.6	47.4	48.8	53.7	57.6	61.7	64.1	(31)	
		MCDB	79.1	75.9	71.3	65.1	59.3	53.3	51.6	55.5	61.6	67.4	73.0	75.5	(32)	
	10%	WB	65.3	64.9	61.7	56.6	52.0	47.9	45.8	46.9	51.7	55.7	59.8	62.4	(33)	
		MCDB	76.7	73.7	69.2	63.1	57.5	51.7	50.4	53.1	59.3	64.8	70.3	73.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.4	21.6	20.7	22.2	21.7	18.3	19.4	21.1	22.1	23.0	23.1	23.7	(35)	
		MCDBR	35.5	31.1	28.9	28.4	26.4	22.7	22.7	26.0	28.5	31.3	33.1	33.2	(36)	
		MCWBR	11.9	11.5	11.9	14.0	15.6	15.1	14.5	15.0	14.9	14.3	13.5	11.6	(37)	
	5% WB	MCDBR	27.4	24.4	22.1	22.6	20.9	17.5	17.8	22.0	23.1	24.9	26.8	26.4	(38)	
		MCWBR	11.7	10.6	10.8	12.1	13.1	12.3	12.5	13.6	13.2	13.0	12.8	11.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.379	0.343	0.319	0.297	0.283	0.271	0.266	0.274	0.300	0.321	0.338	0.340	(40)	
	taud		2.401	2.549	2.597	2.638	2.621	2.669	2.684	2.648	2.556	2.516	2.503	2.517	(41)	
	Ebn at Noon		303	308	304	294	281	277	286	298	305	312	314	317	(42)	
	Edh at Noon		40	33	29	25	22	20	20	24	30	34	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2124	1820	1556	1217	946	729	847	1129	1534	1843	1991	2183	(44)	
	RadStd		177	164	127	106	46	56	63	64	108	145	167	155	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-128	+216	+101

Nomenclature: See separate page