

GABO ISLAND, AustraliaWMO: **949330**Lat: **37.568S**Lon: **149.916E**Elev: **15**StdP: **101.14**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	8.2	0.6	3.9	11.7	2.0	4.4	11.6	19.5	11.8	17.9	11.2	6.3	290	0.693

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.3	24.3	20.0	23.3	19.6	22.6	19.2	21.1	23.1	20.5	22.4	20.0	21.7	8.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	15.1	22.2	19.8	14.5	21.7	19.2	14.0	21.2	61.4	23.3	59.3	22.4	57.4	21.8	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	16.1	14.7	6.3	28.4	0.5	2.7	6.0	30.4	5.7	32.0	5.4	33.5	5.1	35.5 (4)		
(5)			4.0	22.4	0.8	1.1	3.4	23.1	3.0	23.8	2.6	24.4	2.0	25.2 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	19.1	19.3	18.6	16.7	14.5	12.6	11.7	11.9	13.1	14.4	15.9	17.5
	DBStd	3.25	1.88	1.85	1.93	1.94	1.82	1.46	1.43	1.63	1.82	2.13	2.09	2.14
	HDD10.0	5	0	0	0	0	0	1	2	2	1	0	0	0
	HDD18.3	1196	13	11	21	57	120	171	205	199	157	124	76	42
	CDD10.0	1983	283	259	266	199	138	80	54	61	94	136	178	233
	CDD18.3	132	38	37	28	6	1	0	0	0	1	2	4	17
	CDH23.3	102	25	25	11	5	0	0	0	1	3	12	5	16
CDH26.7	11	1	1	1	2	0	0	0	0	1	3	2	2	
Wind	WSAvg	7.3	8.1	7.5	7.4	6.7	6.6	6.4	6.5	6.8	7.7	7.7	8.1	8.2
Precipitation	PrecAvg	958	73	61	75	88	93	80	92	73	78	74	83	79
	PrecMax	1503	377	191	259	413	383	298	305	186	181	212	256	265
	PrecMin	584	6	2	9	9	14	16	11	5	12	17	0	6
	PrecStd	246	67	47	54	81	66	56	69	39	45	49	58	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	25.5	24.5	23.2	21.1	18.1	17.9	19.5	22.1	24.4	23.0	25.2
		MCWB	20.6	21.0	20.3	17.9	15.5	14.1	11.9	12.9	14.2	14.9	18.1	19.0
	2%	DB	24.0	24.0	23.2	21.5	19.6	16.9	16.1	17.0	18.6	20.3	21.2	23.0
		MCWB	20.2	20.6	19.5	17.7	15.6	13.9	11.8	12.5	14.3	15.9	17.7	19.2
	5%	DB	23.0	23.1	22.3	20.5	18.5	16.0	15.1	15.8	17.3	18.9	20.2	21.8
		MCWB	19.7	20.0	19.1	17.3	15.1	13.2	11.6	12.3	14.0	15.8	17.2	18.6
	10%	DB	22.2	22.3	21.5	19.7	17.5	15.2	14.3	14.9	16.3	17.8	19.2	20.9
		MCWB	19.3	19.6	18.7	17.0	14.5	12.6	11.2	11.8	13.4	15.2	16.6	18.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	22.4	21.3	19.7	17.9	15.9	14.1	15.2	16.2	17.9	19.2	20.6
		MCDB	23.9	23.9	23.2	21.3	19.0	17.0	15.4	16.6	18.0	19.6	21.4	23.0
	2%	WB	20.9	21.5	20.5	18.8	16.9	14.8	13.2	14.0	15.4	17.1	18.4	19.7
		MCDB	22.9	23.2	22.2	20.4	18.3	16.1	14.6	15.9	17.4	18.8	20.3	21.8
	5%	WB	20.3	20.7	19.8	18.2	15.9	13.9	12.5	13.1	14.6	16.4	17.7	19.1
		MCDB	22.2	22.5	21.5	19.8	17.8	15.3	14.2	14.9	16.7	18.1	19.6	21.1
	10%	WB	19.7	20.1	19.2	17.5	15.0	13.2	11.8	12.2	13.8	15.6	17.0	18.6
		MCDB	21.6	21.7	21.0	19.3	17.2	14.8	13.8	14.4	15.9	17.5	18.9	20.5
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.3	4.4	4.7	4.6	4.3	4.6	5.0	5.0	5.1	4.5	4.5
		MCDBR	5.4	5.3	5.2	5.8	5.8	5.2	5.9	6.5	6.8	7.2	5.9	5.8
		MCWBR	3.3	3.5	3.3	3.7	4.1	3.7	4.2	4.4	4.5	4.4	3.7	3.6
	5% WB	MCDBR	4.7	4.9	4.5	5.0	5.0	4.5	4.9	5.6	5.8	6.1	5.3	5.1
		MCWBR	3.3	3.7	3.2	3.6	4.1	3.6	3.9	4.5	4.6	4.2	3.8	3.6
Clear-Sky Solar Irradiance	taub	0.419	0.381	0.353	0.336	0.320	0.307	0.298	0.308	0.341	0.350	0.365	0.373	
	taud	2.345	2.499	2.562	2.590	2.590	2.622	2.643	2.611	2.513	2.516	2.501	2.494	
	Ebn at Noon	915	929	916	872	826	812	846	890	913	949	961	965	
	Edh at Noon	132	109	94	81	70	63	65	77	97	105	112	115	
All-Sky Solar Radiation	RadAvg	6.54	5.60	4.70	3.47	2.49	1.98	2.30	3.13	4.34	5.49	6.17	6.68	
	RadStd	0.43	0.40	0.31	0.23	0.13	0.13	0.16	0.17	0.28	0.27	0.43	0.45	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	+116	+43

Nomenclature: See separate page