

GREEN CAPE, Australia

WMO: 949340

Lat: 37.2622S

Lon: 150.0503E

Elev: 66

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.3	46.5	33.9	28.6	50.9	36.3	31.5	52.3	39.8	54.1	35.0	51.7	14.0	250	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.2	77.3	71.0	75.7	69.6	74.3	68.7	72.6	76.0	71.5	74.5	70.4	73.3	13.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	116.1	74.5	70.4	112.2	73.7	69.2	107.7	72.6	36.4	76.4	35.4	74.5	34.4	73.6	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.7	32.1	29.3	DB	42.9	83.6	1.4	4.4	41.9	86.7	41.1	89.3	40.4	91.8	39.4	95.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	67.7	68.4	66.9	63.2	59.0	55.2	53.6	53.9	56.4	59.3	61.4	65.1
	DBStd	6.18	3.49	3.30	3.67	3.67	3.44	2.73	2.61	3.08	3.14	3.65	3.58	3.90
	HDD50	8	0	0	0	0	0	1	2	4	1	0	0	0
	HDD65	1901	14	8	23	75	187	294	352	346	258	181	116	47
	CDD50	3951	550	515	524	396	280	157	115	124	193	288	342	467
	CDD65	367	99	104	82	20	1	0	0	0	0	4	8	49
	CDH74	392	112	121	67	23	1	0	0	0	0	21	1	46
	CDH80	17	1	2	1	5	0	0	0	0	0	7	0	1
Wind	WSAvg	14.7	15.9	14.5	15.3	14.2	13.7	13.3	13.4	14.0	15.2	15.0	16.3	15.9
Precipitation	PrecAvg	28.5	2.7	2.2	2.5	2.8	2.4	2.3	1.9	1.8	2.0	2.3	3.1	2.3
	PrecMax	48.1	15.1	9.8	6.9	15.1	7.6	13.0	7.0	5.7	4.5	7.2	8.3	5.8
	PrecMin	13.2	0.3	0.1	0.2	0.4	0.2	0.2	0.0	0.1	0.2	0.2	0.0	0.2
	PrecStd	8.7	2.8	2.3	1.6	3.0	1.8	2.4	1.7	1.2	1.3	1.7	2.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	79.5	78.2	76.2	70.6	64.4	64.6	65.5	67.2	74.6	73.2	77.4
		MCWB	73.1	71.9	72.1	67.6	61.5	58.4	55.3	54.8	60.2	63.4	66.6	70.3
	2%	DB	76.7	77.1	75.9	72.4	68.0	62.6	61.6	62.6	65.0	69.4	71.0	75.2
		MCWB	71.1	70.6	70.2	65.9	61.4	57.7	54.0	55.5	58.8	63.2	64.3	68.9
	5%	DB	75.0	75.4	74.0	70.6	66.4	61.3	59.9	60.9	63.4	67.2	69.3	73.1
		MCWB	69.7	69.2	68.7	64.9	60.3	56.6	53.6	54.6	57.7	61.7	63.5	67.5
	10%	DB	73.4	73.9	72.4	69.1	64.8	60.0	58.5	59.4	61.8	65.3	67.6	71.2
		MCWB	68.9	68.5	67.8	64.3	59.3	55.4	53.0	54.0	56.8	60.4	62.5	66.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.0	73.6	72.8	69.3	65.7	62.3	57.7	58.6	61.9	66.6	68.2	71.9
		MCDB	78.8	77.5	76.9	72.9	67.9	62.8	61.4	61.4	64.6	71.0	71.7	76.2
	2%	WB	73.0	72.0	71.6	68.0	63.8	60.2	56.5	57.2	60.6	64.8	66.5	70.6
		MCDB	76.0	74.9	74.9	70.7	66.5	61.9	60.1	60.8	63.4	68.5	69.5	74.5
	5%	WB	71.9	70.8	70.4	66.6	62.0	58.2	55.1	55.8	59.5	63.3	65.3	69.2
		MCDB	74.8	73.6	73.1	69.7	65.7	61.0	59.2	59.2	62.6	66.5	68.5	72.6
	10%	WB	70.5	69.6	69.2	65.6	60.4	56.6	53.9	54.7	57.9	61.9	64.1	67.9
		MCDB	73.2	72.9	71.7	68.9	64.8	59.9	58.2	58.4	61.2	64.9	67.5	70.6
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.2	9.2	10.1	8.8	8.0	8.9	9.7	9.5	10.2	9.8	9.6
		MCDBR	10.9	10.8	11.1	12.4	11.2	9.8	11.1	12.1	11.7	13.0	11.8	12.0
		MCWBR	6.8	7.0	6.4	7.5	8.6	6.9	8.2	8.3	8.5	8.8	7.9	7.6
	5% WB	MCDBR	9.4	9.3	8.9	9.9	10.1	8.0	9.6	10.5	10.1	11.5	10.3	10.2
		MCWBR	6.4	6.7	5.5	7.1	8.7	6.8	8.1	8.0	8.7	8.2	7.6	7.3
Clear-Sky Solar Irradiance	taub	0.423	0.382	0.353	0.335	0.318	0.306	0.296	0.307	0.340	0.349	0.369	0.374	
	taud	2.337	2.501	2.567	2.595	2.595	2.622	2.647	2.610	2.515	2.522	2.491	2.494	
	Ebn at Noon	289	294	291	278	264	259	270	283	290	302	304	306	
	Edh at Noon	42	34	30	25	22	20	21	24	31	33	36	36	
All-Sky Solar Radiation	RadAvg	2073	1780	1501	1119	815	644	753	1015	1405	1758	1961	2120	
	RadStd	143	130	99	78	41	43	56	53	91	90	137	139	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+77

Nomenclature: See separate page