

GREEN CAPE, Australia

WMO: 949340

Lat: 37.2622S

Lon: 150.0503E

Elev: 20

StdP: 101.08

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	8.1	1.0	4.1	10.5	2.4	4.5	11.3	17.8	12.3	15.6	11.0	6.3	250	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.1	25.2	21.7	24.3	20.9	23.5	20.4	22.6	24.4	22.0	23.6	21.3	23.0	5.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.9	16.6	23.6	21.3	16.0	23.1	20.7	15.4	22.6	66.8	24.7	64.4	23.6	62.2	23.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	14.3	13.1	6.1	28.6	0.8	2.4	5.5	30.4	5.1	31.8	4.7	33.2	4.1	35.0		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	19.8	20.2	19.4	17.3	15.0	12.9	12.0	12.1	13.6	15.2	16.3	18.4	(6)
	DBStd	3.43	1.94	1.84	2.04	2.04	1.91	1.51	1.45	1.71	1.74	2.03	1.99	2.16	(7)
	HDD10.0	4	0	0	0	0	0	1	1	2	1	0	0	0	(8)
	HDD18.3	1056	8	4	13	42	104	163	196	192	143	101	64	26	(9)
	CDD10.0	2195	306	286	291	220	156	87	64	69	107	160	190	259	(10)
	CDD18.3	204	55	58	46	11	1	0	0	0	0	2	4	27	(11)
	CDH23.3	218	62	67	37	13	1	0	0	0	0	12	1	26	(12)
	CDH26.7	9	1	1	1	3	0	0	0	0	0	4	0	1	(13)
(14) Wind	WSAvg	6.6	7.1	6.5	6.8	6.4	6.1	6.0	6.0	6.3	6.8	6.7	7.3	7.1	(14)
(15) Precipitation	PrecAvg	723	69	56	63	71	61	59	49	46	50	58	79	58	(15)
	PrecMax	1222	384	249	174	383	194	329	178	145	115	184	212	147	(16)
	PrecMin	335	7	2	5	9	4	4	1	3	4	6	0	5	(17)
	PrecStd	221	70	59	41	77	45	61	43	30	32	44	56	39	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	26.4	25.7	24.5	21.4	18.0	18.1	18.6	19.5	23.7	22.9	25.2	(19)
		MCWB	22.8	22.2	22.3	19.8	16.4	14.7	12.9	12.6	15.7	17.5	19.2	21.3	(20)
	2%	DB	24.9	25.0	24.4	22.5	20.0	17.0	16.4	17.0	18.3	20.8	21.7	24.0	(21)
		MCWB	21.7	21.4	21.2	18.8	16.3	14.3	12.2	13.1	14.9	17.3	18.0	20.5	(22)
	5%	DB	23.9	24.1	23.3	21.4	19.1	16.3	15.5	16.1	17.5	19.6	20.7	22.8	(23)
		MCWB	20.9	20.7	20.4	18.3	15.7	13.7	12.0	12.6	14.3	16.5	17.5	19.7	(24)
	10%	DB	23.0	23.3	22.5	20.6	18.2	15.5	14.7	15.2	16.5	18.5	19.8	21.8	(25)
		MCWB	20.5	20.3	19.9	17.9	15.2	13.0	11.6	12.2	13.8	15.8	17.0	19.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.9	23.1	22.7	20.7	18.7	16.8	14.3	14.8	16.6	19.2	20.1	22.2	(27)
		MCDB	26.0	25.3	25.0	22.7	19.9	17.1	16.3	16.3	18.1	21.7	22.1	24.5	(28)
	2%	WB	22.8	22.2	22.0	20.0	17.7	15.7	13.6	14.0	15.9	18.2	19.2	21.4	(29)
		MCDB	24.5	23.8	23.8	21.5	19.2	16.6	15.6	16.0	17.4	20.3	20.8	23.6	(30)
	5%	WB	22.2	21.5	21.3	19.2	16.7	14.5	12.8	13.2	15.3	17.4	18.5	20.6	(31)
		MCDB	23.8	23.1	22.8	21.0	18.7	16.1	15.1	15.1	17.0	19.2	20.3	22.6	(32)
	10%	WB	21.4	20.9	20.7	18.7	15.8	13.7	12.2	12.6	14.4	16.6	17.8	19.9	(33)
		MCDB	22.9	22.7	22.0	20.5	18.2	15.5	14.5	14.6	16.2	18.3	19.7	21.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.1	5.1	5.6	4.9	4.4	4.9	5.4	5.3	5.7	5.5	5.3	(35)
		MCDBR	6.1	6.0	6.2	6.9	6.2	5.4	6.2	6.7	6.5	7.2	6.6	6.7	(36)
		MCWBR	3.8	3.9	3.6	4.2	4.8	3.8	4.6	4.6	4.7	4.9	4.4	4.2	(37)
	5% WB	MCDBR	5.2	5.2	4.9	5.5	5.6	4.4	5.4	5.8	5.6	6.4	5.7	5.7	(38)
		MCWBR	3.5	3.7	3.1	3.9	4.8	3.8	4.5	4.5	4.8	4.6	4.2	4.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.423	0.382	0.353	0.335	0.318	0.306	0.296	0.307	0.340	0.349	0.369	0.374	(40)
	taud		2.337	2.501	2.567	2.595	2.595	2.622	2.647	2.610	2.515	2.522	2.491	2.494	(41)
	Ebn at Noon		911	928	918	875	831	816	851	893	915	951	958	964	(42)
	Edh at Noon		133	108	94	80	70	63	65	77	97	105	113	115	(43)
(44) All-Sky Solar Radiation	RadAvg		6.54	5.61	4.73	3.53	2.57	2.03	2.37	3.20	4.43	5.54	6.18	6.68	(44)
	RadStd		0.45	0.41	0.31	0.24	0.13	0.13	0.18	0.17	0.29	0.28	0.43	0.44	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+43

Nomenclature: See separate page