

MALLACOOTA, Australia

WMO: 949350

Lat: 37.5975S

Lon: 149.7289E

Elev: 72

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.0	40.7	31.3	25.6	49.9	33.4	28.0	48.5	21.7	53.8	19.0	53.3	7.6	300	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	84.1	68.7	80.5	68.0	77.5	67.0	71.1	79.4	69.7	77.2	68.4	75.1	11.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	104.4	74.5	67.1	99.8	73.4	65.8	95.6	72.3	35.0	79.6	33.8	77.4	32.7	74.9	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.1	16.3	DB	35.3	96.0	1.3	4.6	34.4	99.2	33.6	101.9	32.9	104.5	32.0	107.8	(4)
(5)			WB	33.9	74.6	1.3	2.3	32.9	76.3	32.2	77.7	31.5	79.0	30.5	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	67.0	66.9	64.6	60.1	55.7	52.2	50.7	51.5	54.5	57.3	60.6	63.5
	DBStd	7.32	5.85	5.36	4.96	4.39	3.66	3.10	2.91	3.53	4.30	5.06	5.44	5.77
	HDD50	68	0	0	0	0	2	13	26	21	5	1	0	0
	HDD65	2666	43	35	69	159	288	385	444	420	317	249	157	100
	CDD50	3228	528	473	452	302	180	77	47	67	140	226	318	418
	CDD65	348	105	88	56	11	0	0	0	0	2	9	24	53
	CDH74	1632	541	374	195	36	2	0	0	1	19	56	121	287
	CDH80	385	142	84	31	7	0	0	0	0	5	16	28	72
Wind	WSAvg	8.6	9.3	8.9	8.4	7.9	7.9	7.9	7.8	8.1	8.6	9.1	9.5	9.4
Precipitation	PrecAvg	39.0	2.8	3.5	2.8	3.1	3.5	4.2	3.5	3.1	3.1	2.9	3.3	3.3
	PrecMax	49.6	9.4	7.7	8.4	11.2	7.6	12.5	11.1	7.0	8.2	7.6	7.5	6.8
	PrecMin	27.7	0.4	0.6	0.3	0.2	1.3	1.1	1.1	1.1	1.1	0.9	0.8	0.9
	PrecStd	5.5	2.0	2.2	2.1	2.6	1.5	2.9	2.2	1.5	1.7	1.4	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.7	87.4	83.9	77.9	71.6	65.8	66.0	69.9	75.6	80.8	83.5	87.5
		MCWB	70.3	70.1	68.3	65.3	60.0	55.9	53.8	55.0	58.3	62.5	66.8	68.2
	2%	DB	83.6	82.0	79.0	73.3	68.2	62.6	62.1	64.7	69.7	73.6	76.9	80.7
		MCWB	69.9	69.3	67.6	63.3	59.2	55.4	52.7	53.7	58.0	61.0	64.4	67.7
	5%	DB	79.6	78.4	75.4	70.0	65.2	60.6	59.5	61.5	66.1	69.8	72.8	76.6
		MCWB	68.7	68.5	66.5	62.3	57.9	54.1	51.7	52.8	57.1	59.7	63.3	66.4
	10%	DB	76.2	75.1	72.4	67.6	62.9	58.9	57.4	59.1	63.0	66.3	69.4	72.9
		MCWB	67.6	67.3	65.5	61.3	56.9	53.3	50.9	51.8	55.4	58.7	61.8	65.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	73.3	71.1	67.1	63.0	59.3	56.7	58.2	61.7	65.3	68.8	71.0
		MCDB	83.4	81.7	78.3	74.0	66.8	62.5	60.9	63.6	69.1	73.8	78.3	80.9
	2%	WB	71.1	71.0	69.1	65.0	61.0	57.1	54.9	56.0	59.6	63.0	66.2	68.8
		MCDB	80.0	78.7	76.0	70.1	65.8	60.8	59.2	61.7	66.8	70.2	74.1	77.4
	5%	WB	69.7	69.3	67.5	63.6	59.3	55.4	53.3	54.2	57.9	61.3	64.4	67.1
		MCDB	77.2	76.0	73.5	68.3	64.2	59.3	57.9	59.7	64.3	67.9	71.0	74.5
	10%	WB	68.4	68.0	66.3	62.1	57.5	53.9	51.8	52.7	56.2	59.4	62.8	65.6
		MCDB	75.1	73.8	71.7	66.9	62.0	58.0	56.4	58.2	62.2	65.6	68.4	72.1
Mean Daily Temperature Range	5% DB	MDBR	14.0	13.4	13.4	13.9	13.8	13.5	14.4	15.3	15.3	15.2	13.9	14.3
		MCDBR	20.1	18.7	17.8	17.9	17.8	16.5	18.3	19.8	20.9	21.3	19.6	20.4
		MCWBR	9.3	8.8	8.9	10.1	11.1	10.6	11.5	11.7	11.6	11.2	10.4	9.9
	5% WB	MCDBR	17.3	16.5	15.1	14.9	15.2	14.1	15.9	17.3	18.6	19.2	17.3	17.9
MCWBR		9.0	8.9	8.5	9.1	10.3	10.1	10.9	11.2	11.4	11.1	10.0	9.7	
Clear-Sky Solar Irradiance	taub	0.417	0.380	0.352	0.336	0.319	0.305	0.297	0.307	0.339	0.349	0.362	0.372	
	taud	2.346	2.496	2.555	2.582	2.588	2.624	2.642	2.613	2.515	2.514	2.507	2.492	
	Ebn at Noon	291	295	291	276	262	258	269	283	290	301	306	306	
	Edh at Noon	42	35	30	26	22	20	21	24	31	34	35	36	
All-Sky Solar Radiation	RadAvg	2072	1775	1486	1099	791	626	727	991	1376	1734	1952	2115	
	RadStd	138	127	101	75	42	42	50	55	90	89	135	148	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.58	N/A	N/A	+1.42	N/A	N/A	N/A	+295	+117
(47) Regional (17 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	-158	+227	+86

Nomenclature: See separate page