

MONTAGUE ISLAND, Australia

WMO: 949390

Lat: 36.252S

Lon: 150.227E

Elev: 177

StdP: 14.60

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	48.1	49.3	29.7	23.9	55.5	32.2	26.8	55.4	42.3	55.5	38.5	55.3	17.3	230	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	77.0	69.6	75.3	69.4	74.0	68.8	72.7	74.5	71.6	73.7	70.6	72.9	16.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.2	119.8	73.6	70.8	114.4	72.7	69.7	110.1	72.1	36.6	74.8	35.5	73.7	34.6	73.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.3	32.6	29.5	DB	46.0	86.8	1.1	5.6	45.2	90.8	44.6	94.1	44.0	97.2	43.2	101.2	(4)
(5)			WB	39.8	73.5	1.0	1.6	39.2	74.7	38.6	75.6	38.1	76.5	37.4	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.2	68.7	69.1	67.7	64.2	60.4	56.9	55.5	56.0	58.5	60.6	63.1	66.0
	DBStd	5.74	3.06	3.08	2.97	3.22	3.29	2.82	2.77	3.10	3.64	4.07	3.44	3.33
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1484	5	4	10	51	149	243	294	280	198	147	76	27
	CDD50	4449	581	534	549	426	321	207	171	186	256	329	393	496
	CDD65	456	121	117	94	27	5	0	0	4	11	19	58	
	CDH74	367	112	90	43	14	2	0	0	7	39	18	42	
	CDH80	57	23	8	5	2	0	0	0	0	10	3	6	
Wind	WSAvg	14.6	15.6	14.8	14.1	14.2	13.9	14.7	14.0	14.5	14.8	14.8	15.1	15.0
Precipitation	PrecAvg	36.1	2.7	3.3	4.3	3.2	3.1	4.3	1.9	2.1	2.6	2.7	3.1	2.8
	PrecMax	66.5	6.7	18.5	13.0	17.4	7.0	16.5	6.0	5.7	7.6	12.8	9.1	9.5
	PrecMin	12.1	0.2	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.4
	PrecStd	13.1	1.9	3.6	3.3	3.9	2.0	4.3	1.7	1.6	2.1	2.4	2.2	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.3	78.8	77.2	75.9	72.6	67.3	66.8	69.0	74.4	79.1	76.1	78.3
		MCWB	71.3	72.0	71.1	64.2	60.5	58.1	55.2	55.0	57.5	60.9	65.1	68.3
	2%	DB	76.1	76.1	74.9	72.4	69.5	65.0	63.6	65.3	69.6	72.0	71.7	74.2
		MCWB	70.7	71.0	69.8	65.5	60.5	57.3	54.9	55.2	57.7	60.5	66.4	68.8
	5%	DB	74.6	74.8	73.6	70.8	67.3	63.2	61.9	63.1	66.4	68.4	69.8	72.5
		MCWB	69.8	70.2	69.3	65.0	59.9	55.8	53.9	54.7	58.3	61.8	65.4	68.0
	10%	DB	73.3	73.7	72.4	69.5	65.6	61.6	60.3	61.3	64.3	66.3	68.3	71.1
		MCWB	68.8	69.4	68.3	64.3	59.1	54.7	52.7	53.8	58.3	61.2	64.2	67.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	74.6	73.9	70.0	65.9	63.1	60.0	61.0	63.7	66.4	69.6	72.0
		MCDB	76.2	76.9	74.6	71.7	67.2	64.9	63.0	63.5	65.8	69.4	71.6	74.2
	2%	WB	72.1	73.0	71.9	68.2	63.9	59.6	57.6	58.8	62.0	64.8	67.8	70.4
		MCDB	74.5	74.7	73.3	70.4	66.5	62.7	61.2	62.5	64.7	67.3	70.0	72.7
	5%	WB	71.0	71.8	70.7	66.7	62.1	58.0	56.1	56.9	60.7	63.6	66.5	69.2
		MCDB	73.6	73.8	72.6	69.4	65.6	61.2	59.8	61.0	64.3	66.3	69.0	71.6
	10%	WB	70.1	70.6	69.5	65.4	60.4	56.6	54.4	55.4	59.1	62.1	65.0	67.9
		MCDB	72.6	73.0	71.8	68.5	64.4	59.9	58.5	59.7	63.1	65.5	67.7	70.5
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.2	7.2	7.6	7.6	7.2	7.8	8.5	9.2	8.7	7.9	7.6
		MCDBR	9.5	8.2	8.2	9.1	9.6	8.8	9.6	10.7	13.0	12.9	10.0	9.0
		MCWBR	6.5	5.7	6.3	6.4	7.1	6.3	7.0	7.7	7.5	7.8	6.6	6.2
	5% WB	MCDBR	9.0	7.7	7.4	7.9	8.1	7.4	7.9	8.8	10.0	9.7	8.7	8.1
		MCWBR	6.9	6.2	6.5	6.6	7.2	6.3	7.2	7.6	7.6	7.3	6.5	6.6
Clear-Sky Solar Irradiance	taub	0.425	0.388	0.352	0.328	0.311	0.299	0.290	0.300	0.334	0.347	0.371	0.378	
	taud	2.337	2.486	2.574	2.617	2.609	2.638	2.658	2.624	2.524	2.520	2.487	2.484	
	Ebn at Noon	289	293	292	282	268	264	274	287	293	303	304	305	
	Edh at Noon	42	35	30	25	22	20	21	24	31	34	36	37	
All-Sky Solar Radiation	RadAvg	2058	1780	1516	1169	895	695	820	1089	1488	1804	1957	2114	
	RadStd	165	141	107	90	44	49	66	53	101	111	141	135	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-135	+225	+94

Nomenclature: See separate page