

MONTAGUE ISLAND, Australia

WMO: 949390

Lat: 36.252S

Lon: 150.227E

Elev: 54

StdP: 100.68

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	9.6	-1.3	3.4	13.1	0.1	3.8	13.0	18.9	13.0	17.2	12.9	7.8	230	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.0	25.0	20.9	24.0	20.8	23.3	20.4	22.6	23.6	22.0	23.2	21.4	22.7	7.2	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.1	23.1	21.6	16.3	22.6	21.0	15.7	22.3	67.2	23.8	64.7	23.2	62.7	22.8	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.6	13.2	7.8	30.4	0.6	3.1	7.3	32.7	7.0	34.5	6.6	36.2	6.2	38.5		
(5)			4.4	23.1	0.5	0.9	4.0	23.7	3.7	24.2	3.4	24.7	3.0	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	20.4	20.6	19.8	17.9	15.8	13.8	13.1	13.3	14.7	15.9	17.3	18.9		
	DBStd	3.19	1.70	1.71	1.65	1.79	1.83	1.57	1.54	1.72	2.02	2.26	1.91	1.85		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	824	3	2	6	28	83	135	163	156	110	82	42	15		
	CDD10.0	2472	323	297	305	237	178	115	95	103	142	183	218	276		
	CDD18.3	253	67	65	52	15	3	0	0	0	2	6	11	32		
	CDH23.3	204	62	50	24	8	1	0	0	0	4	22	10	23		
	CDH26.7	32	13	4	3	1	0	0	0	0	0	6	2	3		
(14) Wind	WSAvg	6.5	7.0	6.6	6.3	6.3	6.2	6.6	6.2	6.5	6.6	6.6	6.8	6.7		
(15) Precipitation	PrecAvg	917	68	85	109	81	78	108	47	53	66	68	78	72		
	PrecMax	1689	170	471	330	441	177	419	153	145	194	326	230	241		
	PrecMin	308	6	0	2	6	0	1	0	0	1	5	6	9		
	PrecStd	332	47	91	84	99	52	108	44	41	53	60	56	55		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	26.0	25.1	24.4	22.5	19.6	19.3	20.5	23.5	26.2	24.5	25.7		
		MCWB	21.8	22.2	21.7	17.9	15.8	14.5	12.9	12.8	14.2	16.0	18.4	20.2		
	2%	DB	24.5	24.5	23.8	22.4	20.8	18.4	17.6	18.5	20.9	22.2	22.0	23.4		
		MCWB	21.5	21.7	21.0	18.6	15.8	14.1	12.7	12.9	14.3	15.8	19.1	20.5		
	5%	DB	23.7	23.8	23.1	21.6	19.6	17.4	16.6	17.3	19.1	20.2	21.0	22.5		
		MCWB	21.0	21.2	20.7	18.3	15.5	13.2	12.2	12.6	14.6	16.5	18.6	20.0		
	10%	DB	22.9	23.2	22.5	20.8	18.7	16.5	15.7	16.3	17.9	19.1	20.2	21.7		
		MCWB	20.5	20.8	20.1	17.9	15.0	12.6	11.5	12.1	14.6	16.2	17.9	19.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	23.7	23.3	21.1	18.8	17.3	15.5	16.1	17.6	19.1	20.9	22.2		
		MCDB	24.6	24.9	23.6	22.0	19.6	18.3	17.2	17.5	18.8	20.8	22.0	23.4		
	2%	WB	22.3	22.8	22.1	20.1	17.7	15.3	14.2	14.9	16.7	18.2	19.9	21.3		
		MCDB	23.6	23.7	22.9	21.3	19.2	17.0	16.2	17.0	18.1	19.6	21.1	22.6		
	5%	WB	21.7	22.1	21.5	19.3	16.7	14.4	13.4	13.8	15.9	17.5	19.1	20.7		
		MCDB	23.1	23.2	22.5	20.8	18.7	16.2	15.5	16.1	18.0	19.1	20.5	22.0		
	10%	WB	21.1	21.5	20.8	18.5	15.8	13.7	12.5	13.0	15.1	16.7	18.3	20.0		
		MCDB	22.6	22.8	22.1	20.3	18.0	15.5	14.7	15.4	17.3	18.6	19.8	21.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.0	4.0	4.2	4.2	4.0	4.4	4.7	5.1	4.8	4.4	4.2		
		MCDBR	5.3	4.5	4.6	5.0	5.3	4.9	5.3	5.9	7.2	7.2	5.5	5.0		
	5% WB	MCWBR	3.6	3.2	3.5	3.6	3.9	3.5	3.9	4.3	4.2	4.3	3.7	3.4		
		MCWBR	5.0	4.3	4.1	4.4	4.5	4.1	4.4	4.9	5.5	5.4	4.8	4.5		
(40) Clear-Sky Solar Irradiance	taub	taub	0.425	0.388	0.352	0.328	0.311	0.299	0.290	0.300	0.334	0.347	0.371	0.378		
		taud	2.337	2.486	2.574	2.617	2.609	2.638	2.658	2.624	2.524	2.520	2.487	2.484		
	Ebn at Noon	Ebn at Noon	911	924	922	888	846	833	865	906	925	954	957	961		
		Edh at Noon	133	111	94	79	70	63	65	77	97	106	114	116		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.49	5.61	4.78	3.69	2.82	2.19	2.58	3.43	4.69	5.69	6.17	6.66		
	RadStd	RadStd	0.52	0.45	0.34	0.28	0.14	0.16	0.21	0.17	0.32	0.35	0.45	0.43		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-75	+125	+52

Nomenclature: See separate page