

HOGAN ISLAND, Australia

WMO: 949490

Lat: 39.222S

Lon: 146.984E

Elev: 384

StdP: 14.49

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	45.0	46.2	34.5	29.6	48.3	36.4	31.9	48.8	63.5	51.1	58.9	50.6	29.7	260	0.966

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.5	77.6	64.6	73.4	64.8	71.0	64.6	68.8	72.1	67.5	70.6	66.2	69.4	15.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.9	104.1	69.6	66.6	99.2	68.6	65.1	94.2	67.6	33.2	72.6	32.2	70.9	31.2	69.2	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	50.0	45.5	42.0	87.8	1.4	5.6	41.1	91.8	40.3	95.1	39.5	98.3	38.5	102.4
			39.2	71.2	1.3	1.2	38.2	72.1	37.5	72.8	36.7	73.5	35.8	74.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	64.0	64.1	63.0	59.9	56.3	53.2	51.5	51.4	52.9	55.2	58.3	61.4
	DBStd	5.70	4.13	3.46	3.88	3.44	2.91	2.51	2.23	2.57	2.87	3.59	3.99	3.64
	HDD50	33	0	0	0	0	0	4	10	13	5	1	0	0
	HDD65	2825	66	51	86	157	269	355	418	421	363	306	208	125
	CDD50	2796	435	396	402	298	196	99	57	57	93	162	249	352
	CDD65	112	36	28	24	4	0	0	0	0	0	2	6	12
	CDH74	329	135	30	65	9	0	0	0	0	0	10	25	55
	CDH80	79	41	4	16	0	0	0	0	0	0	0	3	15
(14) Wind	WSAvg	22.9	20.9	21.8	21.4	20.8	24.0	23.0	25.5	24.7	24.7	22.7	22.8	22.4
(15) Precipitation	PrecAvg	37.8	2.1	2.0	2.3	2.9	3.4	4.4	4.8	4.7	3.6	2.9	2.6	2.1
	PrecMax	50.0	6.4	5.4	9.5	7.5	6.6	8.8	10.4	11.5	7.4	5.9	5.1	4.6
	PrecMin	22.9	0.2	0.4	0.6	0.9	0.9	0.7	1.4	1.5	1.1	0.4	0.4	0.7
	PrecStd	7.7	1.5	1.3	1.7	1.5	1.8	1.9	2.0	2.4	1.6	1.5	1.3	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.1	78.2	81.4	74.7	65.7	61.1	59.4	61.4	67.1	74.7	78.3	80.8
		MCWB	67.1	66.6	65.3	60.6	57.6	55.8	51.7	53.2	56.2	59.5	63.1	64.6
	2%	DB	77.0	73.3	73.5	69.1	63.7	59.2	57.1	58.7	61.4	66.8	71.4	72.5
		MCWB	66.4	66.6	64.8	60.9	57.3	54.9	51.6	52.5	54.7	57.1	61.7	63.5
	5%	DB	72.5	71.3	70.2	66.3	62.0	58.0	55.8	56.7	58.9	62.8	67.2	69.2
		MCWB	66.2	66.1	65.0	60.8	57.1	54.1	51.3	51.6	53.8	57.0	60.6	63.0
	10%	DB	69.9	69.3	68.3	64.4	60.6	56.7	54.8	55.2	57.1	60.3	64.0	66.8
		MCWB	65.0	64.7	64.1	60.0	56.8	53.2	50.8	50.8	52.7	56.3	59.7	61.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	70.0	69.6	64.8	61.3	58.3	54.8	54.9	58.2	61.6	65.1	67.1
		MCDB	75.8	72.9	72.3	67.2	62.3	59.1	55.6	57.2	61.6	66.8	71.0	72.4
	2%	WB	68.7	68.7	67.9	63.1	59.5	56.5	53.3	53.8	55.7	59.6	63.0	65.3
		MCDB	72.7	71.3	70.6	65.7	61.3	58.1	54.9	56.6	60.0	63.3	68.0	70.3
	5%	WB	67.3	67.5	66.2	62.0	58.2	54.9	52.3	52.8	54.4	58.1	61.7	63.9
		MCDB	71.1	69.8	68.7	64.8	60.7	57.1	54.5	55.7	58.0	61.7	65.5	67.9
	10%	WB	65.9	66.2	64.3	60.7	57.1	53.9	51.6	51.8	53.3	56.6	60.1	62.6
		MCDB	69.6	68.5	67.8	64.0	60.1	56.3	54.2	54.5	56.4	60.0	63.2	65.9
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	8.5	8.3	7.0	5.5	4.9	5.1	6.0	7.1	8.6	9.0	9.6
		MCDBR	14.2	10.6	11.1	9.3	7.0	5.8	5.9	7.7	10.1	12.7	13.6	13.6
	5% WB	MCWBR	7.0	6.1	6.1	5.4	4.8	4.4	4.3	4.9	6.1	6.6	7.1	7.1
		MCWBR	12.4	9.3	10.7	8.4	6.0	5.3	5.1	7.1	8.8	10.7	11.6	11.9
(40) Clear-Sky Solar Irradiance	taub		0.358	0.355	0.335	0.324	0.310	0.304	0.302	0.311	0.337	0.338	0.343	0.345
		taud	2.519	2.547	2.601	2.610	2.617	2.617	2.627	2.601	2.524	2.540	2.547	2.553
	Ebn at Noon		308	302	295	278	262	254	263	279	289	304	312	314
		Edh at Noon	35	33	28	24	21	19	20	24	30	32	34	34
(44) All-Sky Solar Radiation	RadAvg		2214	1914	1509	1046	701	556	634	906	1298	1735	2043	2271
	RadStd		133	93	78	55	33	39	27	43	86	97	121	124

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.81	N/A	N/A	N/A	+0.70	N/A	N/A	-209	+281	+90

Nomenclature: See separate page