

STRAHAN, Australia

WMO: 949560

Lat: 42.1533S

Lon: 145.2923E

Elev: 72

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.4	36.3	31.7	26.1	41.3	33.2	27.8	41.5	34.5	49.4	31.2	49.6	4.2	40	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.1	81.0	64.3	76.9	62.4	73.2	61.3	66.2	76.5	64.3	73.1	62.7	70.9	14.7	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	85.7	68.6	60.9	80.0	67.2	59.2	75.4	65.8	30.9	76.6	29.5	73.0	28.3	71.1	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.8	25.5	22.9	DB	30.5	91.1	1.5	3.1	29.4	93.4	28.5	95.2	27.6	97.0	26.5	99.2	(4)
(5)			WB	30.4	71.1	1.5	3.3	29.3	73.5	28.4	75.4	27.6	77.3	26.5	79.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	59.9	60.2	58.1	54.4	51.3	48.6	47.6	48.3	50.1	52.1	55.0	57.4
	DBStd	6.29	5.06	5.28	5.04	4.49	4.17	3.80	3.63	3.85	4.07	4.66	5.11	5.00
	HDD50	358	0	0	1	9	34	70	90	79	46	22	6	1
	HDD65	4244	178	153	225	320	423	491	538	519	447	400	306	244
	CDD50	1654	305	286	251	141	75	29	17	26	49	89	155	231
	CDD65	67	19	19	10	2	0	0	0	0	0	2	5	10
	CDH74	706	196	191	100	8	0	0	0	0	2	20	70	119
	CDH80	172	53	49	21	0	0	0	0	0	0	3	14	32
Wind	WSAvg	10.9	10.7	9.9	9.8	10.0	10.8	10.0	11.0	11.7	12.6	11.9	11.3	11.6
Precipitation	PrecAvg	81.6	4.6	3.8	5.7	6.1	7.9	8.2	9.0	9.4	8.3	7.2	5.9	5.5
	PrecMax	104.2	8.1	10.2	11.1	10.2	16.6	16.2	14.9	17.0	14.1	11.5	9.3	11.9
	PrecMin	68.3	1.7	1.3	2.4	1.6	1.7	2.9	5.0	3.5	2.9	1.1	1.3	1.7
	PrecStd	8.8	1.8	2.0	1.9	2.1	3.6	3.3	2.4	3.5	2.8	2.3	2.2	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.5	86.3	82.4	74.9	66.0	61.1	59.0	63.5	69.0	76.5	81.8	84.7
		MCWB	66.4	66.1	65.4	61.4	57.0	54.0	52.2	53.0	56.1	59.6	62.1	62.6
	2%	DB	79.1	79.5	76.4	69.4	62.4	58.1	56.4	59.7	63.5	70.0	74.5	76.6
		MCWB	64.0	64.8	62.5	59.0	55.3	52.8	51.3	51.8	53.8	56.3	59.7	61.5
	5%	DB	74.3	74.9	71.6	65.4	59.9	56.3	54.9	56.9	60.1	64.8	69.1	71.5
		MCWB	62.5	63.2	61.5	57.6	54.8	52.1	50.6	51.1	52.6	55.0	58.3	60.2
	10%	DB	70.0	70.7	67.6	62.2	57.8	54.9	53.6	54.6	57.2	60.5	64.6	67.1
		MCWB	60.7	61.5	60.0	56.6	54.0	51.5	49.8	50.1	51.4	53.5	56.3	58.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	68.7	66.9	62.9	58.5	55.6	54.5	54.8	58.6	61.0	64.8	66.4
		MCDB	78.8	80.8	78.3	70.7	62.1	57.9	56.8	59.1	64.5	71.0	74.7	77.2
	2%	WB	65.8	66.0	64.2	60.2	57.0	54.3	52.8	53.1	55.4	58.1	61.8	63.3
		MCDB	76.1	76.0	72.5	66.2	60.1	56.7	54.9	56.9	60.3	66.0	71.2	73.0
	5%	WB	63.5	64.1	62.4	58.6	55.7	53.1	51.5	52.0	53.6	55.9	59.3	61.1
		MCDB	72.3	72.4	69.4	64.1	58.7	55.6	53.9	55.4	58.2	63.0	67.6	69.8
	10%	WB	61.6	62.3	60.6	57.1	54.5	52.0	50.3	50.8	52.3	54.1	57.0	59.1
		MCDB	69.2	69.8	67.1	61.8	57.4	54.4	52.9	54.2	56.5	59.7	63.2	65.9
Mean Daily Temperature Range	5% DB	MDBR	16.8	17.1	15.5	13.8	10.8	10.9	11.0	11.8	13.0	14.7	15.5	15.5
		MCDBR	26.2	25.2	23.3	19.3	12.2	11.5	11.6	14.3	17.6	22.8	25.3	25.0
		MCWBR	13.3	12.7	12.4	11.6	8.4	8.5	8.2	9.1	10.4	12.0	12.9	12.4
	5% WB	MCDBR	23.1	21.6	20.9	16.5	10.3	9.8	9.8	11.8	14.3	19.4	21.8	21.5
		MCWBR	12.6	12.2	12.1	10.7	8.2	8.0	7.9	8.6	9.4	11.2	12.6	11.9
Clear-Sky Solar Irradiance	taub	0.344	0.341	0.328	0.317	0.314	0.316	0.305	0.334	0.349	0.341	0.338	0.338	
	taud	2.538	2.554	2.600	2.608	2.593	2.559	2.603	2.510	2.464	2.503	2.532	2.548	
	Ebn at Noon	312	304	294	276	253	239	254	264	281	301	312	315	
	Edh at Noon	34	32	28	23	20	19	20	25	31	33	34	34	
All-Sky Solar Radiation	RadAvg	2001	1766	1273	865	515	411	461	686	1017	1485	1855	1984	
	RadStd	139	132	83	63	45	39	38	57	62	99	148	148	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+1.01	+0.97	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.56	N/A	N/A	+1.17	+0.58	+0.72	N/A	-176	+187	+22

Nomenclature: See separate page