

OUSE, Australia

WMO: 949570

Lat: 42.4842S

Lon: 146.7100E

Elev: 300

StdP: 14.54

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.5	28.4	25.8	20.0	28.1	27.7	21.9	29.8	20.9	52.8	18.2	51.9	0.8	0	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	87.4	64.1	82.9	63.0	79.0	61.9	66.9	80.3	65.1	77.6	63.4	75.4	10.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	86.5	69.6	60.6	79.9	68.8	58.6	74.1	68.0	31.6	80.1	30.2	77.5	28.9	75.3	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	17.6	15.7	23.1	96.1	1.9	4.0	21.8	99.0	20.7	101.4	19.6	103.7	18.3	106.6
			22.8	70.3	2.0	1.4	21.4	71.4	20.3	72.2	19.2	73.0	17.7	74.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	63.1	62.5	58.9	52.4	48.2	43.8	43.6	45.7	49.0	52.1	56.2	59.7
	DBStd	8.55	5.74	5.74	5.63	5.06	5.26	5.55	4.77	4.40	4.40	5.02	5.34	5.68
	HDD50	791	0	0	3	31	97	196	205	147	70	33	7	2
	HDD65	4549	106	107	203	380	521	637	665	598	481	401	267	183
	CDD50	1840	406	350	279	102	41	9	5	14	40	98	195	301
	CDD65	122	47	37	14	1	0	0	0	0	1	4	18	
	CDH74	2204	790	551	237	17	0	0	0	0	2	39	172	396
	CDH80	707	294	177	60	2	0	0	0	0	0	6	42	126
(14) Wind	WSAvg	6.7	8.0	7.2	6.6	5.6	5.8	4.9	5.3	6.1	7.3	7.4	7.6	8.1
(15) Precipitation	PrecAvg	21.4	1.4	1.1	1.4	1.8	1.7	1.7	2.0	2.2	2.2	2.2	2.0	1.6
	PrecMax	33.9	3.6	4.5	3.3	6.1	5.4	4.2	5.5	5.4	5.4	9.4	5.9	4.5
	PrecMin	13.7	0.2	0.0	0.2	0.2	0.2	0.3	0.5	0.4	0.4	0.1	0.3	
	PrecStd	4.3	0.8	1.0	0.8	1.1	1.2	1.0	1.1	1.3	1.2	1.4	1.2	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	91.4	86.7	76.0	66.8	61.1	60.0	64.4	69.4	79.0	85.4	89.9
		MCWB	65.9	64.6	64.4	60.4	55.9	53.4	51.5	53.4	56.4	59.5	62.8	63.3
	2%	DB	88.0	85.5	80.1	70.3	62.8	58.0	56.6	60.0	64.7	72.2	78.8	83.4
		MCWB	64.2	64.6	62.9	58.3	54.2	51.4	49.8	51.4	53.8	58.2	61.3	62.6
	5%	DB	82.4	80.9	75.6	66.6	60.2	55.8	54.5	57.3	61.6	67.8	74.0	77.9
		MCWB	62.8	62.7	61.2	56.5	52.9	50.1	48.6	50.1	52.4	56.3	59.8	61.3
	10%	DB	77.5	76.4	71.4	63.3	57.6	53.7	52.4	54.9	58.8	63.7	69.3	73.7
		MCWB	60.8	61.3	59.3	54.8	51.4	48.9	47.4	48.7	50.9	54.4	57.8	59.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	69.3	67.1	62.2	57.4	55.2	52.3	54.6	58.1	62.4	66.0	67.4
		MCDB	85.9	79.3	79.7	73.0	63.8	58.8	57.6	61.4	66.0	70.8	77.1	80.8
	2%	WB	66.5	66.8	64.7	59.4	55.1	52.4	50.4	52.3	55.2	59.4	63.3	64.8
		MCDB	81.2	79.8	76.3	67.6	61.3	56.9	55.6	58.8	62.9	68.9	75.2	77.6
	5%	WB	64.3	64.6	62.6	57.4	53.5	50.5	49.0	50.4	53.1	56.9	61.0	62.7
		MCDB	77.6	76.3	72.2	65.1	59.1	55.2	53.8	56.4	60.0	66.2	71.9	75.0
	10%	WB	62.2	62.6	60.6	55.5	52.0	49.0	47.7	49.0	51.5	54.7	58.4	60.5
		MCDB	75.2	74.6	69.9	62.0	57.1	53.3	51.9	54.4	58.2	63.1	68.5	72.1
(35) Mean Daily Temperature Range	5% DB	MDBR	25.2	24.6	22.7	21.8	17.5	16.3	16.2	18.0	19.0	21.0	22.9	23.6
		MCDBR	36.7	34.7	31.6	28.3	20.5	18.2	18.3	21.3	24.2	30.0	33.1	34.6
		MCWBR	15.4	14.9	15.4	16.7	13.2	12.4	12.5	13.8	14.9	17.3	16.9	16.0
	5% WB	MCDBR	30.7	27.8	27.2	25.4	19.9	17.2	17.3	20.3	22.0	27.4	30.0	29.9
		MCWBR	14.3	13.7	14.1	15.9	13.5	12.2	12.4	13.5	14.3	16.4	16.6	15.1
(40) Clear-Sky Solar Irradiance	taub		0.344	0.332	0.331	0.314	0.303	0.290	0.291	0.308	0.334	0.338	0.337	0.336
	taud		2.487	2.540	2.531	2.562	2.573	2.594	2.594	2.545	2.456	2.459	2.486	2.502
	Ebn at Noon		311	307	292	275	256	249	258	273	286	301	312	316
	Edh at Noon		36	32	30	24	20	18	19	24	31	35	36	36
(44) All-Sky Solar Radiation	RadAvg		2064	1778	1318	892	542	429	487	730	1082	1529	1861	2023
	RadStd		166	105	78	55	38	35	25	54	66	97	148	132

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+0.59	N/A	N/A	+1.22	+0.58	N/A	N/A	-176	+191	+22

Nomenclature: See separate page