

OUSE, Australia

WMO: 949570

Lat: 42.4842S

Lon: 146.7100E

Elev: 91

StdP: 100.23

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.1	-2.0	-3.4	2.9	-2.2	-2.4	3.1	-1.2	9.4	11.6	8.1	11.0	0.3	0	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	30.8	17.8	28.3	17.2	26.1	16.6	19.4	26.8	18.4	25.3	17.4	24.1	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.4	20.9	15.9	11.4	20.4	14.8	10.6	20.0	55.7	26.7	52.4	25.3	49.4	24.0	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.9	7.9	7.0	DB	-5.0	35.6	1.0	2.2	-5.7	37.2	-6.3	38.6	-6.9	39.8	-7.6	41.4	(4)
			WB	-5.1	21.3	1.1	0.8	-5.9	21.9	-6.5	22.3	-7.1	22.8	-7.9	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	17.3	16.9	14.9	11.3	9.0	6.5	6.4	7.6	9.4	11.2	13.5	15.4
	DBStd	4.75	3.19	3.19	3.13	2.81	2.92	3.08	2.65	2.44	2.44	2.79	2.97	3.16
	HDD10.0	439	0	0	2	17	54	109	114	82	39	18	4	1
	HDD18.3	2527	59	59	113	211	289	354	369	332	267	223	148	102
	CDD10.0	1022	226	194	155	57	23	5	3	8	22	54	108	167
	CDD18.3	68	26	21	8	1	0	0	0	0	1	2	10	
	CDH23.3	1224	439	306	132	9	0	0	0	1	22	96	220	
	CDH26.7	393	163	98	33	1	0	0	0	0	3	23	70	
Wind	WSAvg	3.0	3.6	3.2	2.9	2.5	2.6	2.2	2.4	2.7	3.3	3.3	3.4	3.6
Precipitation	PrecAvg	544	35	29	35	45	44	43	52	57	57	55	50	41
	PrecMax	862	92	115	84	154	137	107	140	138	136	240	151	114
	PrecMin	348	5	1	6	4	4	7	12	13	9	11	2	7
	PrecStd	108	20	25	20	27	30	25	29	32	31	36	30	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	33.0	30.4	24.4	19.3	16.2	15.6	18.0	20.8	26.1	29.7	32.2
		MCWB	18.8	18.1	18.0	15.8	13.3	11.9	10.8	11.9	13.5	15.3	17.1	17.4
	2%	DB	31.1	29.7	26.7	21.3	17.1	14.5	13.7	15.6	18.2	22.4	26.0	28.5
		MCWB	17.9	18.1	17.2	14.6	12.3	10.8	9.9	10.8	12.1	14.6	16.3	17.0
	5%	DB	28.0	27.2	24.2	19.2	15.7	13.2	12.5	14.1	16.5	19.9	23.3	25.5
		MCWB	17.1	17.1	16.2	13.6	11.6	10.1	9.2	10.0	11.3	13.5	15.4	16.3
	10%	DB	25.3	24.7	21.9	17.4	14.2	12.0	11.3	12.7	14.9	17.6	20.7	23.1
		MCWB	16.0	16.3	15.2	12.7	10.8	9.4	8.5	9.3	10.5	12.4	14.4	15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	20.7	19.5	16.8	14.1	12.9	11.3	12.5	14.5	16.9	18.9	19.7
		MCDB	30.0	26.3	26.5	22.8	17.7	14.9	14.2	16.3	18.9	21.6	25.1	27.1
	2%	WB	19.2	19.3	18.1	15.2	12.9	11.3	10.2	11.3	12.9	15.2	17.4	18.2
		MCDB	27.3	26.5	24.6	19.8	16.3	13.8	13.1	14.9	17.1	20.5	24.0	25.3
	5%	WB	18.0	18.1	17.0	14.1	12.0	10.3	9.5	10.2	11.7	13.8	16.1	17.0
		MCDB	25.3	24.6	22.3	18.4	15.0	12.9	12.1	13.5	15.6	19.0	22.2	23.9
	10%	WB	16.8	17.0	15.9	13.1	11.1	9.4	8.7	9.4	10.8	12.6	14.7	15.8
		MCDB	24.0	23.6	21.1	16.7	13.9	11.8	11.0	12.4	14.6	17.3	20.3	22.3
Mean Daily Temperature Range	5% DB	MDBR	14.0	13.7	12.6	12.1	9.7	9.1	9.0	10.0	10.6	11.7	12.7	13.1
		MCDBR	20.4	19.3	17.5	15.7	11.4	10.1	10.1	11.9	13.5	16.7	18.4	19.2
		MCWBR	8.5	8.3	8.6	9.3	7.3	6.9	7.0	7.7	8.3	9.6	9.4	8.9
	5% WB	MCDBR	17.1	15.4	15.1	14.1	11.0	9.5	9.6	11.3	12.2	15.2	16.7	16.6
MCWBR		8.0	7.6	7.9	8.8	7.5	6.8	6.9	7.5	7.9	9.1	9.2	8.4	
Clear-Sky Solar Irradiance	taub	0.344	0.332	0.331	0.314	0.303	0.290	0.291	0.308	0.334	0.338	0.337	0.336	
	taud	2.487	2.540	2.531	2.562	2.573	2.594	2.594	2.545	2.456	2.459	2.486	2.502	
	Ebn at Noon	981	967	921	868	806	786	814	861	902	950	983	996	
	Edh at Noon	112	101	93	77	64	57	61	77	98	109	112	112	
All-Sky Solar Radiation	RadAvg	6.51	5.61	4.15	2.81	1.71	1.35	1.53	2.30	3.41	4.82	5.87	6.38	
	RadStd	0.52	0.33	0.24	0.17	0.12	0.11	0.08	0.17	0.21	0.31	0.47	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)		+0.33	N/A	N/A	+0.68	+0.32	N/A	N/A	-98	+106	+12

Nomenclature: See separate page