

MAATSUYKER ISLAND LH, Australia

WMO: 949620

Lat: 43.657S

Lon: 146.272E

Elev: 148

StdP: 99.56

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	5.5	-1.4	3.4	7.9	-0.3	3.7	7.8	29.9	9.3	27.7	8.8	11.2	320	0.915

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.5	23.7	15.3	21.4	14.8	19.5	14.4	16.9	20.6	16.0	19.5	15.2	18.3	7.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.3	17.7	14.7	10.6	16.9	13.9	10.1	16.3	48.1	20.9	45.4	19.5	43.2	18.5	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.4	24.0	21.8	3.5	28.2	0.7	1.4	2.9	29.2	2.5	30.0	2.1	30.8	1.6	31.8		
(5)			1.5	18.6	0.5	1.2	1.1	19.5	0.8	20.1	0.5	20.8	0.1	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	14.0	14.3	13.5	12.1	10.9	9.7	9.2	9.0	9.6	10.3	11.3	12.6		
	DBStd	2.87	2.55	2.52	2.50	2.25	1.98	1.75	1.59	1.84	2.13	2.35	2.49	2.56		
	HDD10.0	186	1	0	1	4	12	26	34	41	32	22	11	3		
	HDD18.3	2558	138	118	151	187	231	258	283	288	263	249	212	180		
	CDD10.0	682	125	119	111	67	39	17	9	12	19	31	49	83		
	CDD18.3	15	4	4	3	1	0	0	0	0	0	1	1	2		
	CDH23.3	70	21	20	13	1	0	0	0	0	0	1	4	9		
	CDH26.7	6	2	2	1	0	0	0	0	0	0	0	0	1		
(14) Wind	WSAvg	9.9	9.2	8.3	8.8	9.4	10.7	9.3	9.9	10.9	11.1	10.8	9.7	10.2		
(15) Precipitation	PrecAvg	1377	86	78	88	119	127	133	150	139	129	117	98	100		
	PrecMax	1931	193	172	165	269	249	253	330	255	278	210	194	271		
	PrecMin	891	13	19	30	40	45	22	67	51	41	45	18	23		
	PrecStd	270	38	39	34	51	54	46	58	47	48	43	39	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	26.9	25.2	21.8	18.7	15.8	14.3	16.1	19.1	22.2	23.7	24.5		
		MCWB	16.4	16.6	15.4	14.0	12.3	11.4	9.8	10.4	11.3	13.1	13.8	15.0		
	2%	DB	22.6	22.8	21.4	18.7	16.4	14.1	13.0	14.2	15.8	18.5	19.9	21.0		
		MCWB	15.9	16.4	15.0	13.1	12.0	10.4	9.5	9.8	10.2	12.0	13.3	14.4		
	5%	DB	19.8	20.1	18.9	16.9	15.0	13.1	12.2	12.8	14.0	15.8	17.1	18.3		
		MCWB	15.0	15.6	14.6	12.7	11.7	10.2	9.4	9.5	10.0	11.3	12.6	14.2		
	10%	DB	17.7	18.1	17.0	15.3	13.7	12.2	11.5	11.7	12.5	13.7	14.8	16.1		
		MCWB	14.4	14.8	14.2	12.5	11.4	9.9	9.2	9.2	9.6	10.9	11.8	13.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	18.4	17.4	15.3	13.9	12.7	11.6	11.8	12.5	14.3	15.5	16.8		
		MCDB	22.5	22.9	20.8	18.3	15.5	14.0	12.5	13.5	15.6	18.9	20.0	20.0		
	2%	WB	16.5	17.0	16.1	14.3	13.1	11.6	10.7	10.7	11.4	13.0	14.1	15.2		
		MCDB	20.5	21.0	19.0	16.7	14.8	13.0	12.0	12.6	13.7	16.3	18.1	19.3		
	5%	WB	15.6	16.1	15.3	13.5	12.4	10.9	10.1	10.1	10.6	12.0	13.1	14.2		
		MCDB	19.2	19.4	17.9	15.8	14.2	12.2	11.5	11.9	12.8	14.9	16.0	17.6		
	10%	WB	14.6	15.2	14.3	12.7	11.7	10.3	9.6	9.9	9.9	11.0	12.1	13.3		
		MCDB	17.4	17.8	16.9	15.0	13.5	11.8	11.0	11.3	12.1	13.3	14.5	15.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	4.5	4.0	3.5	3.0	2.7	2.8	3.2	3.7	4.1	4.2	4.3		
		MCDBR	9.5	8.3	7.7	6.3	4.7	3.6	3.5	4.8	6.4	8.2	8.8	8.5		
	5% WB	MCWBR	4.7	4.2	4.1	3.5	3.2	2.8	2.8	3.1	3.6	4.2	4.3	4.5		
		MCWBR	8.2	6.9	6.1	5.1	3.7	2.9	2.9	3.8	5.0	6.7	7.2	7.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.341	0.333	0.335	0.317	0.314	0.302	0.308	0.319	0.345	0.339	0.334	0.336		
		taud	2.547	2.576	2.568	2.598	2.580	2.593	2.579	2.562	2.471	2.507	2.537	2.550		
	Ebn at Noon	Ebn at Noon	983	963	913	859	783	758	781	843	885	946	984	995		
		Edh at Noon	105	97	89	73	62	56	61	74	96	103	106	106		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.12	5.26	3.75	2.48	1.48	1.18	1.36	2.06	3.16	4.60	5.67	6.19		
	RadStd	RadStd	0.39	0.45	0.23	0.14	0.12	0.10	0.10	0.14	0.15	0.24	0.43	0.38		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.50	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	-103	+108	+12

Nomenclature: See separate page