

BUSHY PARK, AustraliaWMO: **949640**Lat: **42.7097S**Lon: **146.8983E**Elev: **89**StdP: **14.65**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.0	30.7	30.5	24.7	46.6	31.7	26.2	42.2	25.2	54.9	22.5	53.2	2.0	330	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.2	86.0	63.9	81.7	62.7	77.8	61.2	66.6	79.2	64.8	76.5	63.1	74.1	11.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	85.9	68.9	60.7	79.6	68.0	58.6	73.8	66.9	31.2	78.8	29.9	76.6	28.6	74.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.4	19.9	17.2	25.7	95.6	1.8	3.4	24.4	98.1	23.4	100.1	22.4	102.0	21.1	104.5		
(5)			30.4	70.1	1.7	1.4	29.2	71.1	28.1	72.0	27.1	72.8	25.9	73.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	62.9	62.3	58.9	53.0	48.7	44.4	44.1	46.1	49.6	52.6	56.7	59.8
	DBStd	8.22	5.64	5.58	5.53	4.90	4.91	4.96	4.38	4.15	4.17	5.06	5.33	5.57
	HDD50	702	0	0	3	24	83	177	189	133	57	29	6	1
	HDD65	4415	108	110	202	360	505	617	648	584	462	384	255	180
	CDD50	1877	401	343	279	115	43	10	6	13	45	111	207	304
	CDD65	116	44	33	14	1	0	0	0	0	0	1	5	18
	CDH74	1763	639	428	182	11	0	0	0	0	2	35	147	319
	CDH80	526	222	125	40	1	0	0	0	0	6	35	97	
Wind	WSAvg	6.8	8.2	7.6	6.7	5.6	5.7	4.9	5.4	6.4	7.6	7.7	7.8	8.3
Precipitation	PrecAvg	23.3	1.5	1.3	1.6	1.9	1.9	1.7	2.3	2.4	2.3	2.2	2.1	1.9
	PrecMax	34.6	3.7	5.1	3.7	6.2	4.5	3.7	5.8	5.0	6.0	7.2	5.1	5.6
	PrecMin	14.1	0.2	0.1	0.3	0.2	0.3	0.5	0.7	0.6	0.7	0.7	0.2	0.1
	PrecStd	4.1	0.8	1.1	0.9	1.1	1.2	0.9	1.3	1.2	1.2	1.1	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.6	90.4	85.1	75.4	67.2	61.7	60.4	64.6	69.9	78.4	84.8	89.0
		MCWB	65.4	65.9	63.8	59.7	55.5	53.9	50.9	52.8	54.8	58.2	62.0	63.2
	2%	DB	86.0	84.2	78.9	70.1	63.2	58.4	57.1	60.3	65.1	72.2	78.1	81.9
		MCWB	64.2	64.4	62.1	57.7	53.9	51.1	49.3	51.0	53.2	57.4	60.5	62.4
	5%	DB	80.9	79.6	74.5	66.5	60.3	56.0	54.7	57.6	62.0	67.7	73.0	76.6
		MCWB	62.4	62.3	60.6	56.1	52.3	49.7	48.3	49.6	51.7	55.2	58.7	60.7
	10%	DB	76.3	75.4	70.8	63.4	57.9	53.6	52.6	55.2	59.3	63.8	68.9	72.6
		MCWB	60.6	60.9	59.1	54.4	51.1	48.3	47.2	48.3	50.4	53.6	57.0	58.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	69.6	66.9	62.0	57.4	56.2	52.2	54.3	56.8	62.3	66.0	66.9
		MCDB	84.4	80.5	78.5	70.5	64.4	59.2	57.2	60.5	66.3	70.7	75.2	80.1
	2%	WB	66.2	66.6	64.3	59.3	55.0	52.2	50.4	52.1	54.5	59.1	62.7	64.5
		MCDB	79.6	79.1	74.2	66.7	60.9	57.1	56.0	58.8	62.3	68.2	74.5	75.5
	5%	WB	64.1	64.5	62.2	57.2	53.4	50.4	49.0	50.4	52.8	56.4	60.2	62.3
		MCDB	76.5	76.3	71.8	64.5	58.9	55.3	54.2	56.6	60.5	65.7	70.5	74.1
	10%	WB	61.9	62.5	60.3	55.4	51.8	48.9	47.7	48.9	51.2	54.2	57.8	60.1
		MCDB	73.8	72.5	69.2	62.2	57.2	53.5	52.4	54.6	58.6	63.2	67.3	70.8
Mean Daily Temperature Range	5% DB	MDBR	24.2	23.6	22.0	21.3	17.3	16.0	16.3	18.1	19.5	20.6	21.6	22.4
		MCDBR	34.8	32.3	29.4	26.8	20.3	18.5	18.8	21.5	24.4	28.7	31.2	31.8
		MCWBR	14.2	13.6	13.9	14.7	12.1	11.6	11.3	12.1	13.3	14.7	15.2	14.0
	5% WB	MCDBR	29.1	26.4	25.7	24.2	19.3	17.3	16.6	19.9	22.2	25.7	27.7	27.5
		MCWBR	13.2	12.8	13.2	14.2	12.3	11.7	11.1	12.1	13.1	14.5	14.9	13.5
Clear-Sky Solar Irradiance	taub	0.350	0.336	0.339	0.317	0.308	0.294	0.294	0.310	0.336	0.341	0.339	0.343	
	taud	2.476	2.533	2.512	2.559	2.565	2.588	2.590	2.548	2.457	2.456	2.486	2.488	
	Ebn at Noon	309	305	289	273	253	246	256	272	285	300	311	314	
	Edh at Noon	36	32	30	24	20	18	19	24	31	35	36	36	
All-Sky Solar Radiation	RadAvg	2051	1761	1304	882	537	426	487	728	1089	1534	1853	2030	
	RadStd	161	106	75	53	37	35	25	51	60	92	145	127	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	+0.58	N/A	N/A	+1.19	N/A	N/A	N/A	-171	+185	+22

Nomenclature: See separate page