

HOBART ELLERSLIE ROAD, Australia

WMO: 949700

Lat: 42.8899S Lon: 147.3276E Elev: 169 StdP: 14.61 Time Zone: 10.00 (AUS) Period: 94-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.4	38.1	27.4	21.5	50.4	29.3	23.5	48.8	30.4	55.2	27.0	55.1	8.3	330	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	83.3	62.7	78.5	61.7	74.9	60.3	65.7	76.7	64.0	74.0	62.5	71.3	14.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.4	84.9	68.8	60.5	79.3	67.3	58.6	74.0	66.2	30.7	76.8	29.4	74.4	28.2	71.5	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.4	22.3	19.9	DB	33.6	95.9	1.4	4.4	32.6	99.0	31.8	101.6	31.0	104.0	30.0	107.2	
			WB	32.5	69.5	1.1	1.8	31.7	70.8	31.1	71.9	30.5	72.9	29.7	74.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	62.9	62.7	60.4	55.9	52.3	48.4	47.9	49.2	51.7	54.4	57.3	60.3
	DBStd	7.19	5.66	5.52	5.30	4.92	4.53	4.04	3.56	4.17	4.62	5.35	5.62	5.47
	HDD50	309	0	0	0	6	26	78	84	67	32	13	3	0
	HDD65	3703	109	101	162	275	393	498	529	490	400	333	244	169
	CDD50	2224	399	356	324	184	98	30	21	41	82	150	221	318
	CDD65	142	43	36	21	3	0	0	0	0	5	12	22	22
	CDH74	1056	324	239	142	17	0	0	0	3	47	107	177	177
	CDH80	323	107	73	42	1	0	0	0	0	9	29	62	62
(14) Wind	WSAvg	10.0	10.4	9.6	9.3	9.5	9.8	9.3	9.8	10.2	10.7	10.5	10.3	10.5
(15) Precipitation	PrecAvg	23.2	1.7	1.6	1.6	1.9	1.7	1.6	2.1	2.4	2.0	2.2	2.0	2.1
	PrecMax	32.6	4.1	6.7	4.7	9.8	3.9	3.3	6.2	5.8	5.2	5.9	5.0	8.1
	PrecMin	15.4	0.3	0.1	0.2	0.2	0.2	0.1	0.4	0.4	0.6	0.4	0.1	0.0
	PrecStd	4.6	1.1	1.5	1.1	1.7	1.0	0.8	1.3	1.3	1.1	1.3	1.1	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.0	89.1	85.0	76.2	68.8	62.1	61.0	65.4	71.4	79.9	84.1	88.0
		MCWB	65.1	65.3	63.3	59.0	55.6	52.7	50.4	52.0	55.4	56.6	60.4	62.3
	2%	DB	81.6	80.5	77.3	71.1	64.7	59.4	58.3	61.6	65.9	72.6	76.1	78.2
		MCWB	63.3	63.4	61.4	57.5	53.8	51.1	49.2	50.5	52.7	56.0	59.1	61.1
	5%	DB	76.5	75.8	72.7	67.3	62.0	57.4	56.3	58.9	62.8	67.3	70.6	73.2
		MCWB	61.8	62.3	60.1	56.0	52.8	49.8	48.3	49.2	51.2	54.5	57.3	59.4
	10%	DB	72.5	72.0	69.1	64.2	59.7	55.3	54.4	56.6	60.0	63.5	66.3	69.5
		MCWB	59.7	60.9	58.8	55.0	51.6	48.7	47.4	48.3	50.0	52.9	55.6	57.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	68.3	66.4	61.6	57.9	55.7	52.5	53.8	57.4	60.6	64.1	65.8
		MCDB	81.0	78.6	75.4	70.8	63.6	58.4	56.8	59.9	67.1	69.6	75.9	77.8
	2%	WB	65.4	65.9	63.8	59.3	55.7	52.1	50.4	51.8	54.4	58.2	61.2	63.1
		MCDB	77.3	76.7	72.3	66.4	61.9	57.1	56.0	59.5	62.3	68.1	71.9	72.8
	5%	WB	63.4	64.0	62.0	57.4	54.1	50.7	49.1	50.2	52.5	55.9	59.0	61.2
		MCDB	73.4	73.4	70.2	64.8	60.3	55.8	54.9	57.3	60.3	65.5	68.3	70.3
	10%	WB	61.5	62.2	60.2	55.8	52.5	49.3	48.0	48.9	51.0	53.9	56.8	59.4
		MCDB	70.4	70.3	68.0	63.1	58.7	54.4	53.7	55.9	58.6	62.2	64.5	68.1
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	14.9	14.4	13.7	11.7	10.8	11.2	12.6	14.0	15.0	14.7	15.2
		MCDBR	23.7	21.5	20.8	18.2	14.2	12.6	12.9	15.4	18.2	21.8	22.5	22.0
		MCWBR	10.3	9.4	9.1	8.7	8.0	7.5	7.5	8.2	9.2	10.4	10.4	10.0
	5% WB	MCDBR	20.5	18.6	17.3	16.3	12.8	11.1	11.7	14.1	16.0	19.3	19.5	19.1
		MCWBR	10.4	9.7	8.7	8.8	8.2	7.4	7.5	8.0	9.5	10.3	10.4	10.1
(40) Clear-Sky Solar Irradiance	taub		0.343	0.331	0.330	0.311	0.304	0.292	0.293	0.305	0.325	0.329	0.332	0.337
	taud		2.517	2.573	2.567	2.599	2.595	2.610	2.609	2.582	2.511	2.518	2.532	2.527
	Ebn at Noon		312	307	292	276	255	248	257	274	289	304	313	315
	Edh at Noon		35	31	28	23	20	18	19	23	30	32	34	35
(44) All-Sky Solar Radiation	RadAvg		2062	1757	1310	889	547	434	501	746	1125	1567	1862	2069
	RadStd		155	96	72	51	34	34	23	50	55	87	144	119

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	+0.81	N/A	N/A	N/A	N/A	+0.90	-56	-299	+272	+38
(47) Regional (29 neighbors)	+0.58	N/A	N/A	+1.22	N/A	N/A	N/A	-180	+191	+25

Nomenclature: See separate page