

SCOTTSDALE, Australia

WMO: 949720

Lat: 41.171S

Lon: 147.488E

Elev: 650

StdP: 14.35

Time Zone: 10.00 (AUS)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	36.1	25.7	20.2	44.8	27.8	22.2	44.4	23.4	50.7	21.8	50.9	5.1	150	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.6	80.0	64.6	76.5	63.6	73.4	61.7	67.1	75.0	65.5	72.9	64.0	70.9	10.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	93.3	69.5	62.9	87.9	68.4	61.2	82.7	67.4	32.0	74.8	30.7	73.1	29.6	71.2	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.4	16.3	DB	30.1	87.4	1.3	4.5	29.1	90.6	28.3	93.3	27.6	95.8	26.6	99.1	(4)
(5)			WB	30.6	70.6	1.3	1.8	29.6	71.8	28.9	72.9	28.1	73.8	27.2	75.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	62.1	62.3	59.9	54.9	50.4	47.4	46.2	46.6	48.6	51.5	55.7	58.9
	DBStd	7.17	5.12	4.57	5.21	4.33	3.75	3.48	3.00	3.33	3.55	4.18	4.84	4.80
	HDD50	480	0	0	1	9	40	92	122	113	67	30	5	1
	HDD65	4221	119	98	176	305	453	527	582	569	492	418	282	200
	CDD50	1819	376	345	308	155	52	15	5	9	25	77	177	275
	CDD65	86	30	24	18	1	0	0	0	0	0	0	4	9
	CDH74	611	268	123	98	2	0	0	0	0	0	1	36	83
	CDH80	114	67	16	14	0	0	0	0	0	0	0	3	14
Wind	WSAvg	7.9	8.5	8.0	7.6	7.2	7.4	7.3	7.7	8.2	8.3	8.2	8.1	8.5
Precipitation	PrecAvg	39.8	2.4	1.6	2.0	3.3	4.0	4.3	4.8	4.7	3.9	3.5	2.7	2.7
	PrecMax	56.1	5.3	4.3	5.7	8.0	7.1	8.8	11.3	10.6	9.0	6.0	5.2	8.6
	PrecMin	26.7	0.4	0.1	0.2	0.7	0.3	2.1	1.3	1.6	0.6	1.3	0.6	0.5
	PrecStd	6.8	1.3	1.0	1.5	1.9	2.1	1.7	2.4	2.2	2.0	1.5	1.1	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.2	82.6	81.9	72.1	63.7	59.4	56.7	58.9	64.3	71.5	79.0	81.8
		MCWB	66.4	67.1	64.9	61.2	57.0	54.9	50.9	52.2	55.3	59.1	62.7	63.9
	2%	DB	80.5	77.7	76.6	67.2	60.7	57.1	54.9	56.4	60.2	65.7	72.9	75.8
		MCWB	65.1	65.0	64.0	59.0	55.4	52.3	50.1	50.2	52.4	56.2	61.1	62.7
	5%	DB	76.3	74.3	72.0	64.5	58.9	55.3	53.5	54.7	57.9	62.7	68.6	72.1
		MCWB	63.1	63.1	61.6	57.3	54.0	51.0	49.0	49.5	51.3	54.9	59.1	60.4
	10%	DB	72.6	71.4	68.8	62.5	57.4	53.8	52.3	53.0	55.9	60.2	65.4	68.9
		MCWB	61.1	61.1	59.7	56.2	53.1	50.2	48.5	48.5	50.2	53.3	56.7	58.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	68.8	67.2	63.3	58.7	56.7	53.0	53.5	56.7	60.9	65.5	67.2
		MCDB	78.4	77.5	76.2	68.4	61.2	58.8	54.7	56.2	61.5	66.2	74.5	76.0
	2%	WB	67.2	66.9	65.5	60.8	57.0	53.8	51.4	51.9	54.4	58.4	62.5	64.5
		MCDB	75.5	73.8	73.0	64.3	59.4	55.6	53.4	54.9	58.3	63.4	70.1	71.6
	5%	WB	65.3	65.2	63.7	59.2	55.4	52.3	50.4	50.5	52.6	56.3	60.3	62.6
		MCDB	73.3	71.5	69.8	63.0	57.9	54.3	52.5	53.3	56.4	60.9	66.5	69.7
	10%	WB	63.3	63.4	61.6	57.6	54.0	50.9	49.4	49.5	51.1	54.4	58.4	60.5
		MCDB	70.7	69.5	67.3	61.6	56.6	53.2	51.6	52.2	54.7	59.5	64.1	67.1
Mean Daily Temperature Range	5% DB	MDBR	18.6	16.9	16.7	14.5	13.1	12.1	11.8	12.8	14.5	16.2	17.3	17.9
		MCDBR	23.8	20.1	19.7	16.6	14.1	12.5	12.5	13.9	16.8	19.0	21.5	22.0
		MCWBR	10.8	9.7	9.2	9.9	10.0	9.0	8.9	9.3	10.9	11.5	11.6	11.2
	5% WB	MCDBR	19.5	17.0	17.4	14.2	11.3	10.1	10.0	11.8	14.7	16.4	18.4	19.0
		MCWBR	10.9	9.7	9.5	9.7	9.0	8.3	8.2	8.7	10.5	11.2	11.5	10.8
Clear-Sky Solar Irradiance	taub	0.339	0.332	0.321	0.314	0.301	0.293	0.293	0.307	0.326	0.332	0.336	0.334	
	taud	2.525	2.564	2.591	2.583	2.591	2.602	2.608	2.568	2.503	2.497	2.510	2.528	
	Ebn at Noon	314	308	298	278	260	252	261	276	291	305	313	317	
	Edh at Noon	35	32	28	24	21	19	20	24	30	33	35	35	
All-Sky Solar Radiation	RadAvg	2220	1881	1469	996	655	509	569	833	1230	1684	2013	2240	
	RadStd	148	76	70	43	36	41	25	63	80	80	134	134	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.61	N/A	N/A	+1.30	+0.65	+0.77	N/A	-189	+200	+31

Nomenclature: See separate page