

SCOTTSDALE, Australia

WMO: 949720

Lat: 41.171S

Lon: 147.488E

Elev: 198

StdP: 98.97

Time Zone: 10.00 (AUS)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 1.4	(c) 2.3	(d) -3.5	(e) 2.9	(f) 7.1	(g) -2.3	(h) 3.2	(i) 6.9	(j) 10.5	(k) 10.4	(l) 9.7	(m) 10.5	(n) 2.3	(o) 150	(p) 0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 10.3	(c) 26.7	(d) 18.1	(e) 24.7	(f) 17.5	(g) 23.0	(h) 16.5	(i) 19.5	(j) 23.9	(k) 18.6	(l) 22.7	(m) 17.8	(n) 21.6	(o) 4.5	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.3	20.8	17.2	12.6	20.2	16.2	11.8	19.7	56.5	23.8	53.6	22.8	51.0	21.8	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.3	(b) 8.2	(c) 7.3	(e) -1.1	(f) 30.8	(g) 0.7	(h) 2.5	(i) -1.6	(j) 32.6	(k) -2.1	(l) 34.0	(m) -2.5	(n) 35.4	(o) -3.0	(p) 37.3		
			DB													
			WB													
				(e) -0.8	(f) 21.4	(g) 0.7	(h) 1.0	(i) -1.3	(j) 22.1	(k) -1.7	(l) 22.7	(m) -2.1	(n) 23.2	(o) -2.7	(p) 24.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	16.7	16.8	15.5	12.7	10.2	8.6	7.9	8.1	9.2	10.8	13.2	14.9		
	DBStd	3.98	2.85	2.54	2.90	2.41	2.08	1.93	1.67	1.85	1.97	2.32	2.69	2.66		
	HDD10.0	267	0	0	1	5	22	51	68	63	37	17	3	1		
	HDD18.3	2345	66	54	98	169	252	293	323	316	273	232	157	111		
	CDD10.0	1011	209	192	171	86	29	8	3	5	14	43	98	153		
	CDD18.3	48	17	13	10	1	0	0	0	0	0	0	2	5		
	CDH23.3	339	149	68	54	1	0	0	0	0	0	1	20	46		
	CDH26.7	63	37	9	8	0	0	0	0	0	0	0	2	8		
(14) Wind	WSAvg	3.5	3.8	3.6	3.4	3.2	3.3	3.2	3.5	3.7	3.7	3.6	3.6	3.8		
(15) Precipitation	PrecAvg	1011	62	40	51	83	101	109	123	119	100	88	69	69		
	PrecMax	1426	134	109	146	204	181	224	288	269	228	153	132	218		
	PrecMin	678	9	2	5	19	8	54	33	40	14	32	14	12		
	PrecStd	173	33	25	39	48	53	44	60	55	50	38	28	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	28.1	27.7	22.3	17.6	15.2	13.7	14.9	17.9	22.0	26.1	27.6		
		MCWB	19.1	19.5	18.3	16.2	13.9	12.7	10.5	11.2	12.9	15.0	17.0	17.7		
	2%	DB	26.9	25.4	24.8	19.6	16.0	13.9	12.7	13.6	15.7	18.7	22.7	24.3		
		MCWB	18.4	18.3	17.8	15.0	13.0	11.3	10.1	10.1	11.3	13.4	16.2	17.1		
	5%	DB	24.6	23.5	22.2	18.1	15.0	12.9	12.0	12.6	14.4	17.1	20.3	22.3		
		MCWB	17.3	17.3	16.5	14.1	12.2	10.6	9.4	9.7	10.7	12.7	15.1	15.8		
	10%	DB	22.6	21.9	20.5	17.0	14.1	12.1	11.3	11.7	13.3	15.7	18.6	20.5		
		MCWB	16.2	16.2	15.4	13.4	11.7	10.1	9.2	9.1	10.1	11.8	13.7	14.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	20.5	19.5	17.4	14.8	13.7	11.7	12.0	13.7	16.0	18.6	19.6		
		MCDB	25.8	25.3	24.6	20.2	16.2	14.9	12.6	13.5	16.4	19.0	23.6	24.4		
	2%	WB	19.5	19.4	18.6	16.0	13.9	12.1	10.8	11.1	12.4	14.7	17.0	18.0		
		MCDB	24.1	23.2	22.8	17.9	15.2	13.1	11.9	12.7	14.6	17.4	21.2	22.0		
	5%	WB	18.5	18.5	17.6	15.1	13.0	11.3	10.2	10.3	11.5	13.5	15.7	17.0		
		MCDB	23.0	21.9	21.0	17.2	14.4	12.4	11.4	11.9	13.6	16.1	19.2	21.0		
	10%	WB	17.4	17.5	16.5	14.2	12.2	10.5	9.6	9.7	10.6	12.4	14.7	15.9		
		MCDB	21.5	20.8	19.6	16.5	13.7	11.8	10.9	11.2	12.6	15.3	17.8	19.5		
(35) Mean Daily Temperature Range	MDBR		10.3	9.4	9.3	8.1	7.3	6.7	6.5	7.1	8.1	9.0	9.6	10.0		
	5% DB	MCDBR	13.2	11.1	10.9	9.2	7.8	6.9	6.9	7.7	9.3	10.5	11.9	12.2		
		MCWBR	6.0	5.4	5.1	5.5	5.5	5.0	5.0	5.2	6.1	6.4	6.4	6.2		
	5% WB	MCDBR	10.8	9.4	9.7	7.9	6.3	5.6	5.6	6.5	8.2	9.1	10.2	10.6		
		MCWBR	6.1	5.4	5.3	5.4	5.0	4.6	4.6	4.9	5.8	6.2	6.4	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.339	0.332	0.321	0.314	0.301	0.293	0.293	0.307	0.326	0.332	0.336	0.334		
	taud		2.525	2.564	2.591	2.583	2.591	2.602	2.608	2.568	2.503	2.497	2.510	2.528		
	Ebn at Noon		989	970	939	877	821	796	824	871	916	960	986	999		
	Edh at Noon		109	100	89	77	65	59	62	76	95	105	110	110		
(44) All-Sky Solar Radiation	RadAvg		7.00	5.93	4.63	3.14	2.06	1.60	1.79	2.62	3.88	5.31	6.34	7.06		
	RadStd		0.47	0.24	0.22	0.13	0.11	0.13	0.08	0.20	0.25	0.25	0.42	0.42		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	+0.34	N/A	N/A	+0.72	+0.36	+0.43	N/A	-105	+111	+17

Nomenclature: See separate page