

HOBART INTL, Australia

WMO: 949750

Lat: 42.8339S

Lon: 147.5033E

Elev: 90

StdP: 14.65

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.6	37.3	26.9	20.9	52.0	28.7	22.8	50.1	29.2	51.5	25.6	52.7	7.1	310	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	84.2	62.8	79.1	61.8	75.4	60.6	66.2	77.5	64.4	74.6	62.8	72.1	15.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.6	85.3	69.4	60.7	79.5	68.1	58.8	74.3	66.9	31.0	77.9	29.6	75.4	28.4	72.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.1	23.0	20.7	DB	32.8	96.3	1.3	4.2	31.9	99.3	31.1	101.8	30.4	104.2	29.5	107.3	(4)
(5)			WB	31.5	69.8	1.2	1.6	30.6	70.9	29.9	71.9	29.2	72.7	28.3	73.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	63.4	63.1	60.6	56.0	52.2	48.5	47.8	49.0	51.6	54.6	57.6	60.6
	DBStd	7.28	5.60	5.47	5.33	4.83	4.45	3.93	3.46	4.10	4.53	5.19	5.57	5.40
	HDD50	310	0	0	0	5	26	74	88	70	32	12	3	0
	HDD65	3665	99	93	158	273	396	494	534	496	402	327	234	159
	CDD50	2273	414	366	330	185	95	30	19	39	81	153	231	330
	CDD65	153	48	39	22	3	0	0	0	0	0	4	13	24
	CDH74	1217	376	267	166	20	0	0	0	0	3	47	126	212
	CDH80	384	132	83	49	1	0	0	0	0	0	10	37	72
Wind	WSAvg	10.3	11.3	10.4	9.9	9.4	9.6	9.0	9.2	10.0	10.9	11.2	11.3	11.5
Precipitation	PrecAvg	19.1	1.6	1.4	1.4	1.6	1.4	1.2	1.7	1.7	1.7	1.8	1.7	2.0
	PrecMax	28.9	4.1	7.3	4.4	9.9	4.4	3.8	6.1	4.2	5.5	4.6	4.1	6.7
	PrecMin	11.7	0.1	0.1	0.1	0.3	0.1	0.2	0.2	0.3	0.3	0.3	0.1	0.0
	PrecStd	4.3	1.1	1.2	0.9	1.5	0.9	0.8	1.2	0.9	1.0	1.0	0.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	89.7	86.2	76.8	69.3	62.6	61.7	65.1	71.4	80.0	85.3	88.4
		MCWB	64.2	66.0	63.8	59.3	55.9	53.6	51.0	52.6	55.2	56.7	61.4	61.9
	2%	DB	82.7	80.9	78.1	71.6	65.3	60.1	58.8	61.7	66.3	72.2	77.0	79.1
		MCWB	63.8	64.1	61.7	57.7	54.2	51.5	49.8	50.9	53.3	56.2	60.1	61.5
	5%	DB	77.2	76.3	73.5	67.9	62.7	58.0	56.8	59.2	63.0	67.6	71.3	74.0
		MCWB	62.1	62.6	60.5	56.4	53.0	50.1	48.5	49.7	51.6	55.1	57.3	59.4
	10%	DB	73.2	72.5	69.8	64.7	60.4	55.8	54.9	57.1	60.4	63.9	67.0	70.1
		MCWB	60.0	60.9	59.1	55.1	52.0	48.9	47.8	48.6	50.2	53.2	55.8	57.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.7	68.9	66.9	62.0	58.2	55.7	53.1	54.3	57.6	61.0	64.4	66.1
		MCDB	81.6	79.6	76.7	71.1	64.6	59.5	57.9	61.3	67.4	69.6	76.8	77.6
	2%	WB	65.7	66.4	64.3	59.6	56.1	52.7	50.9	52.2	54.8	58.4	61.6	63.5
		MCDB	78.2	77.0	73.1	67.5	62.7	57.8	56.6	59.6	62.9	68.1	73.0	74.3
	5%	WB	63.6	64.4	62.4	57.8	54.3	51.1	49.5	50.5	52.9	56.2	59.3	61.4
		MCDB	74.1	73.8	70.9	65.5	60.9	56.5	55.3	57.6	60.6	65.6	68.8	71.2
	10%	WB	61.6	62.6	60.5	56.0	52.7	49.7	48.3	49.2	51.2	54.1	57.2	59.4
		MCDB	71.0	70.8	68.5	63.4	59.1	55.2	54.2	56.1	58.7	62.8	65.3	68.3
Mean Daily Temperature Range	5% DB	MDBR	17.2	16.5	16.3	15.7	14.1	13.3	13.7	14.5	15.4	16.4	16.3	16.9
		MCDBR	25.8	23.3	22.5	20.1	16.7	15.2	15.6	16.9	19.2	22.7	24.0	23.8
		MCWBR	11.3	10.7	10.5	9.9	9.6	9.2	9.5	9.5	10.4	11.3	11.2	11.1
	5% WB	MCDBR	22.8	20.0	19.5	18.3	15.5	13.7	14.5	15.8	17.5	20.2	21.3	21.4
		MCWBR	11.3	10.5	10.2	10.0	9.9	9.1	9.5	9.5	10.5	11.1	11.3	11.2
Clear-Sky Solar Irradiance	taub	0.347	0.334	0.334	0.314	0.305	0.293	0.294	0.307	0.329	0.332	0.336	0.340	
	taud	2.504	2.562	2.553	2.591	2.591	2.604	2.604	2.576	2.496	2.505	2.517	2.518	
	Ebn at Noon	310	306	291	275	254	247	256	273	287	303	312	315	
	Edh at Noon	35	31	29	23	20	18	19	23	30	33	34	35	
All-Sky Solar Radiation	RadAvg	2084	1772	1330	904	561	443	514	763	1151	1591	1876	2097	
	RadStd	159	89	71	52	33	34	22	50	55	87	146	118	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.72	N/A	-0.63	N/A	N/A	N/A	N/A	-216	+239
(47) Regional (28 neighbors)		+0.58	N/A	N/A	+1.28	N/A	N/A	N/A	-178	+193

Nomenclature: See separate page