

HOBART INTL, Australia

WMO: 949750

Lat: 42.8339S

Lon: 147.5033E

Elev: 27

StdP: 101.00

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.0	2.9	-2.9	3.0	11.1	-1.8	3.3	10.1	13.1	10.9	11.5	11.5	3.2	310	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.6	29.0	17.1	26.2	16.6	24.1	15.9	19.0	25.3	18.0	23.7	17.1	22.3	6.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	12.2	20.8	15.9	11.4	20.1	14.9	10.6	19.4	54.2	25.5	51.0	24.1	48.2	22.4	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.3	9.3	DB	0.4	35.7	0.7	2.4	-0.1	37.4	-0.5	38.8	-0.9	40.1	-1.4	41.8	(4)
(5)			WB	-0.3	21.0	0.7	0.9	-0.8	21.6	-1.2	22.1	-1.5	22.6	-2.1	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	17.4	17.3	15.9	13.3	11.2	9.2	8.8	9.4	10.9	12.5	14.2	15.9
	DBStd	4.05	3.11	3.04	2.96	2.69	2.47	2.18	1.92	2.28	2.52	2.88	3.09	3.00
	HDD10.0	172	0	0	0	3	14	41	49	39	18	7	2	0
	HDD18.3	2036	55	52	88	152	220	274	297	276	223	182	130	88
	CDD10.0	1263	230	203	183	103	53	17	11	22	45	85	128	183
	CDD18.3	85	27	22	12	2	0	0	0	0	0	2	7	13
	CDH23.3	676	209	148	92	11	0	0	0	0	2	26	70	118
	CDH26.7	213	73	46	27	1	0	0	0	0	6	21	40	
Wind	WSAvg	4.6	5.1	4.6	4.4	4.2	4.3	4.0	4.1	4.5	4.9	5.0	5.0	5.2
Precipitation	PrecAvg	484	40	35	36	40	36	31	42	44	42	45	44	50
	PrecMax	735	105	186	112	251	113	97	156	107	140	117	104	170
	PrecMin	296	3	3	2	7	3	4	4	7	8	7	2	0
	PrecStd	108	28	30	23	38	23	20	30	24	26	26	24	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	32.1	30.1	24.9	20.7	17.0	16.5	18.4	21.9	26.7	29.6	31.4
		MCWB	17.9	18.9	17.6	15.2	13.3	12.0	10.5	11.5	12.9	13.7	16.3	16.6
	2%	DB	28.2	27.1	25.6	22.0	18.5	15.6	14.9	16.5	19.1	22.3	25.0	26.2
		MCWB	17.6	17.8	16.5	14.3	12.3	10.8	9.9	10.5	11.9	13.4	15.6	16.4
	5%	DB	25.1	24.6	23.1	19.9	17.1	14.4	13.8	15.1	17.2	19.8	21.8	23.3
		MCWB	16.7	17.0	15.9	13.6	11.7	10.1	9.2	9.8	10.9	12.8	14.0	15.2
	10%	DB	22.9	22.5	21.0	18.2	15.8	13.2	12.7	13.9	15.8	17.7	19.4	21.2
		MCWB	15.5	16.1	15.1	12.8	11.1	9.4	8.8	9.2	10.1	11.8	13.2	14.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	20.5	19.4	16.7	14.5	13.1	11.7	12.4	14.2	16.1	18.0	19.0
		MCDB	27.6	26.4	24.8	21.7	18.1	15.3	14.4	16.3	19.7	20.9	24.9	25.3
	2%	WB	18.7	19.1	17.9	15.4	13.4	11.5	10.5	11.2	12.7	14.7	16.5	17.5
		MCDB	25.7	25.0	22.8	19.7	17.1	14.4	13.7	15.3	17.2	20.1	22.8	23.5
	5%	WB	17.6	18.0	16.9	14.3	12.4	10.6	9.7	10.3	11.6	13.4	15.2	16.3
		MCDB	23.4	23.2	21.6	18.6	16.1	13.6	12.9	14.2	15.9	18.7	20.5	21.8
	10%	WB	16.5	17.0	15.8	13.4	11.5	9.8	9.1	9.6	10.7	12.3	14.0	15.2
		MCDB	21.7	21.5	20.3	17.4	15.1	12.9	12.4	13.4	14.8	17.1	18.5	20.2
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.2	9.1	8.7	7.8	7.4	7.6	8.0	8.6	9.1	9.0	9.4
		MCDBR	14.3	12.9	12.5	11.2	9.3	8.4	8.7	9.4	10.6	12.6	13.3	13.2
		MCWBR	6.3	5.9	5.8	5.5	5.3	5.1	5.3	5.3	5.8	6.3	6.2	6.1
	5% WB	MCDBR	12.7	11.1	10.8	10.2	8.6	7.6	8.0	8.8	9.7	11.2	11.8	11.9
		MCWBR	6.3	5.8	5.7	5.6	5.5	5.1	5.3	5.3	5.8	6.2	6.3	6.2
Clear-Sky Solar Irradiance	taub	0.347	0.334	0.334	0.314	0.305	0.293	0.294	0.307	0.329	0.332	0.336	0.340	
	taud	2.504	2.562	2.553	2.591	2.591	2.604	2.604	2.576	2.496	2.505	2.517	2.518	
	Ebn at Noon	978	964	917	867	802	779	807	862	906	955	983	992	
	Edh at Noon	110	99	91	74	63	56	60	74	94	104	108	110	
All-Sky Solar Radiation	RadAvg	6.57	5.58	4.19	2.85	1.77	1.40	1.62	2.41	3.63	5.02	5.91	6.61	
	RadStd	0.50	0.28	0.22	0.17	0.10	0.11	0.07	0.16	0.17	0.28	0.46	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	-0.35	N/A	N/A	N/A	N/A	-120	+133	+20
(47) Regional (28 neighbors)		+0.32	N/A	N/A	+0.71	N/A	N/A	N/A	-99	+107	+16

Nomenclature: See separate page