

PORT ARTHUR PALMER, Australia

WMO: 949780

Lat: 43.167S

Lon: 147.833E

Elev: 633

StdP: 14.36

Time Zone: 10.00 (AUS)

Period: 90-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 38.1	(c) 39.4	(d) 28.4	(e) 22.9	(f) 43.6	(g) 30.1	(h) 24.8	(i) 43.1	(j) 30.0	(k) 48.7	(l) 29.0	(m) 46.9	(n) 12.4	(o) 250	(p) 0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 11.3	(c) 76.4	(d) 61.6	(e) 72.3	(f) 60.5	(g) 68.8	(h) 59.4	(i) 64.2	(j) 72.6	(k) 62.4	(l) 69.4	(m) 60.7	(n) 67.0	(o) 13.1	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	82.5	67.1	59.5	77.7	65.8	57.6	72.5	64.0	29.7	72.8	28.4	69.5	27.2	67.1	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.2	26.0	22.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			32.9	68.8	1.0	1.8	32.1	70.1	31.5	71.2	30.9	72.2	30.2	73.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	57.8	58.9	56.9	53.8	50.9	47.6	47.1	47.1	49.1	50.9	52.1	54.8
	DBStd	5.95	5.20	5.56	4.53	4.43	3.73	3.53	3.17	3.83	4.23	4.84	4.54	4.85
	HDD50	477	1	0	1	10	32	90	99	106	65	42	25	6
	HDD65	4712	235	186	258	337	438	523	554	554	478	437	389	323
	CDD50	1283	242	251	213	125	59	17	10	17	37	71	87	154
	CDD65	41	11	16	5	1	0	0	0	0	0	1	1	6
	CDH74	241	74	73	28	0	0	0	0	0	0	0	4	62
	CDH80	65	17	21	8	0	0	0	0	0	0	0	0	19
(14) Wind	WSAvg	11.6	11.6	11.4	11.2	11.5	10.8	11.0	11.4	12.4	11.9	11.7	12.7	11.9
(15) Precipitation	PrecAvg	45.9	3.5	2.5	3.6	3.7	3.3	4.3	4.4	4.9	3.9	4.1	3.3	3.9
	PrecMax	60.4	7.9	6.9	12.3	9.4	6.1	8.9	7.0	10.0	8.0	7.4	6.8	12.9
	PrecMin	37.1	0.7	0.6	1.2	1.6	0.6	1.7	1.9	1.1	1.2	1.5	0.7	0.6
	PrecStd	5.9	1.9	1.8	2.2	2.0	1.5	2.0	1.4	2.2	1.8	1.5	1.5	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.9	82.9	79.1	71.5	65.7	58.7	57.4	60.9	64.9	71.1	75.1	82.2
		MCWB	64.6	63.3	62.3	58.2	54.1	52.4	49.9	50.2	55.1	57.0	59.1	62.0
	2%	DB	75.1	75.2	70.6	67.1	61.6	56.5	55.1	57.6	61.0	66.8	67.6	72.7
		MCWB	62.7	62.3	59.2	56.9	54.2	51.3	49.2	49.3	53.0	57.4	55.8	60.1
	5%	DB	70.0	71.4	67.0	63.8	59.4	54.9	53.7	55.2	57.9	62.2	63.3	66.6
		MCWB	60.9	61.7	58.3	55.8	52.9	50.0	48.5	48.0	50.0	53.8	54.4	58.3
	10%	DB	66.1	67.4	64.0	61.2	57.3	53.3	52.4	53.5	55.7	58.5	59.7	62.8
		MCWB	58.9	60.1	57.6	54.6	50.9	48.0	47.6	47.2	48.8	51.5	52.8	56.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.7	67.3	64.2	60.9	57.6	54.0	52.8	53.5	56.9	62.1	60.8	63.9
		MCDB	79.0	75.8	71.7	67.1	61.8	57.0	54.0	56.3	61.7	66.4	71.6	74.3
	2%	WB	63.9	64.4	61.6	58.8	55.5	52.4	50.8	50.7	53.8	56.9	57.6	61.4
		MCDB	72.5	72.7	66.6	64.8	60.4	55.8	53.7	55.1	59.5	64.9	65.1	70.3
	5%	WB	61.7	62.6	59.9	56.9	53.3	50.3	49.4	49.1	51.3	54.8	55.7	59.0
		MCDB	69.0	69.2	65.3	62.5	58.8	54.4	52.9	54.1	56.5	60.9	61.9	65.6
	10%	WB	59.3	60.7	58.2	55.0	51.7	48.6	48.1	47.6	49.5	52.6	53.8	56.7
		MCDB	65.3	66.4	64.1	60.4	56.6	52.3	51.7	52.7	54.7	58.1	58.9	63.2
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.3	10.3	9.5	7.7	6.7	6.6	8.4	9.4	10.2	10.2	10.3
		MCDBR	18.2	17.5	15.3	13.1	10.5	8.1	8.0	11.2	12.5	15.9	16.4	17.3
		MCWBR	10.2	9.9	8.7	8.2	7.2	6.5	6.0	7.2	8.2	10.1	10.6	10.6
	5% WB	MCDBR	16.4	15.7	13.1	11.9	9.8	7.4	7.2	10.1	11.3	13.9	14.5	15.4
		MCWBR	10.3	10.3	8.7	8.3	7.3	6.5	6.2	7.2	8.4	9.7	10.1	10.4
(40) Clear-Sky Solar Irradiance	taub		0.339	0.330	0.325	0.309	0.297	0.291	0.294	0.304	0.325	0.326	0.328	0.333
	taud		2.552	2.594	2.604	2.622	2.629	2.618	2.616	2.599	2.531	2.548	2.563	2.560
	Ebn at Noon		313	307	294	277	258	247	256	274	289	305	314	317
	Edh at Noon		33	30	27	23	19	17	19	23	29	31	33	34
(44) All-Sky Solar Radiation	RadAvg		2033	1725	1286	874	538	429	499	744	1130	1578	1848	2078
	RadStd		138	92	68	50	34	33	23	49	55	79	141	106

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	+0.61	N/A	N/A	N/A	+1.28	N/A	N/A	N/A	-191	+198	+31

Nomenclature: See separate page