

FLINDERS ISLAND, Australia

WMO: 949800

Lat: 40.0911S

Lon: 148.0025E

Elev: 31

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.4	36.0	30.8	25.0	40.6	32.7	27.2	42.5	42.1	49.5	38.3	51.2	7.7	60	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.5	81.9	66.0	77.8	65.5	74.7	64.7	69.1	76.2	67.7	74.3	66.4	72.8	14.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.8	98.6	71.8	65.4	93.8	71.1	63.9	89.2	70.2	33.3	76.2	32.2	74.6	31.1	72.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.7	33.3	30.5	DB	29.9	93.4	1.1	5.4	29.2	97.3	28.5	100.5	27.9	103.5	27.2	107.4	(4)
(5)			WB	29.7	71.4	1.1	1.5	28.9	72.4	28.3	73.3	27.7	74.1	26.9	75.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.5	64.0	64.5	62.0	57.9	54.5	51.1	50.0	50.2	52.2	54.3	57.6	60.8	(6)	
	DBStd	7.01	5.45	5.12	5.15	4.81	4.60	4.41	4.07	4.28	4.48	4.95	5.16	5.16	(7)	
	HDD50	202	0	0	0	3	13	41	52	51	27	13	2	0	(8)	
	HDD65	3266	83	65	123	219	327	418	465	459	385	334	233	155	(9)	
	CDD50	2589	434	407	372	240	152	73	52	57	92	147	229	334	(10)	
	CDD65	179	52	53	30	6	1	0	0	0	0	3	10	24	(11)	
	CDH74	921	314	215	117	22	1	0	0	0	1	28	67	156	(12)	
	CDH80	250	101	50	26	2	0	0	0	0	0	6	16	49	(13)	
(14) Wind	WSAvg	14.9	14.8	14.0	14.2	13.6	15.0	13.5	14.7	15.1	16.1	15.7	15.5	16.1	(14)	
(15) Precipitation	PrecAvg	29.3	2.0	1.4	2.0	2.4	3.2	2.8	3.3	3.0	2.7	2.0	2.2	2.4	(15)	
	PrecMax	39.6	5.8	5.7	5.9	5.3	8.3	5.2	8.6	6.6	5.3	4.9	4.6	8.1	(16)	
	PrecMin	17.1	0.2	0.0	0.2	0.5	0.7	1.3	0.6	0.2	0.8	0.6	0.6	0.3	(17)	
	PrecStd	5.3	1.3	1.2	1.5	1.3	1.9	1.0	1.8	1.5	1.2	1.1	1.0	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	86.6	83.2	77.0	69.4	63.5	61.7	64.8	70.2	77.6	81.5	87.5	(19)	
		MCWB	68.3	66.5	66.5	60.4	57.6	56.5	52.3	53.8	56.0	58.4	64.4	65.5	(20)	
	2%	DB	80.9	79.2	76.6	71.9	66.0	60.9	59.1	61.2	65.2	70.4	73.9	78.0	(21)	
		MCWB	66.7	67.2	65.8	60.9	57.9	55.6	52.4	52.6	55.2	57.5	62.4	64.3	(22)	
	5%	DB	76.4	75.9	73.1	68.2	63.5	59.2	57.4	58.8	61.8	66.2	69.3	73.0	(23)	
		MCWB	66.2	66.6	64.9	60.7	57.3	54.3	52.1	52.2	54.7	57.3	61.5	63.5	(24)	
	10%	DB	72.9	72.8	70.4	65.7	61.5	57.8	56.1	56.7	59.1	62.7	65.8	69.4	(25)	
		MCWB	65.0	65.3	63.7	59.9	56.5	53.3	51.6	51.5	53.4	56.6	59.3	62.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	70.4	69.8	65.3	61.2	58.9	55.8	56.7	59.6	62.4	66.5	69.1	(27)	
		MCDB	80.4	77.4	76.2	70.2	64.7	61.5	58.5	60.1	64.9	67.1	76.3	76.8	(28)	
	2%	WB	69.0	69.1	67.8	63.4	59.7	56.6	54.2	54.7	57.4	60.3	63.9	66.5	(29)	
		MCDB	76.8	75.7	73.4	68.1	63.4	59.6	56.9	58.4	62.9	66.0	71.2	73.8	(30)	
	5%	WB	67.3	67.8	66.2	62.0	58.3	55.3	53.1	53.3	55.4	58.5	62.0	64.7	(31)	
		MCDB	74.7	73.7	71.8	66.7	62.1	58.4	56.1	57.3	60.1	64.3	67.5	70.9	(32)	
	10%	WB	65.6	66.4	64.3	60.4	57.0	54.0	52.1	52.1	54.0	56.8	60.2	62.8	(33)	
		MCDB	72.1	72.3	69.9	65.2	60.9	57.2	55.3	56.0	58.3	62.6	65.2	69.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	13.5	13.8	13.2	11.4	11.3	11.0	11.5	12.0	13.6	13.3	13.3	(35)	
		MCDBR	19.9	17.2	18.0	17.3	13.4	12.1	12.0	14.0	17.0	20.3	19.7	21.0	(36)	
		MCWBR	8.9	8.1	9.8	9.8	8.4	8.5	8.4	8.6	9.8	10.8	10.1	10.4	(37)	
	5% WB	MCDBR	17.3	14.7	15.5	14.8	11.5	10.1	10.8	11.9	14.2	16.9	16.3	18.2	(38)	
		MCWBR	9.3	8.1	9.4	9.7	8.2	8.1	8.6	8.5	9.4	10.5	9.8	10.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.355	0.351	0.336	0.324	0.311	0.303	0.304	0.314	0.340	0.341	0.345	0.346	(40)	
	taud		2.516	2.547	2.588	2.601	2.608	2.617	2.614	2.585	2.500	2.511	2.524	2.534	(41)	
	Ebn at Noon		309	302	294	277	260	252	260	276	287	302	310	314	(42)	
	Edh at Noon		35	32	29	24	21	19	20	24	30	33	35	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2195	1895	1500	1029	694	547	623	899	1304	1744	2044	2289	(44)	
	RadStd		131	91	76	45	36	39	23	54	82	79	123	122	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.90	N/A	+0.95	N/A	+1.06	+1.19	N/A	N/A	+189	+38	(46)
(47)	Regional (12 neighbors)	+0.61	N/A	+0.68	+1.19	+0.70	N/A	N/A	-148	+173	+29	(47)

Nomenclature: See separate page