

FLINDERS ISLAND, Australia

WMO: 949800

Lat: 40.0911S

Lon: 148.0025E

Elev: 10

StdP: 101.21

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.8	2.2	-0.7	3.6	4.8	0.4	3.9	5.8	18.8	9.7	17.1	10.6	3.5	60	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.5	27.7	18.9	25.5	18.6	23.7	18.1	20.6	24.5	19.9	23.5	19.1	22.6	6.3	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.1	22.1	18.5	13.4	21.7	17.7	12.7	21.2	59.5	24.6	56.9	23.7	54.5	22.7	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.9	13.6	-1.1	34.1	0.6	3.0	-1.6	36.3	-1.9	38.0	-2.3	39.7	-2.7	41.9		
(5)			-1.3	21.9	0.6	0.8	-1.7	22.5	-2.1	22.9	-2.4	23.4	-2.9	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	17.8	18.1	16.7	14.4	12.5	10.6	10.0	10.1	11.2	12.4	14.2	16.0
	DBStd	3.89	3.03	2.85	2.86	2.67	2.55	2.45	2.26	2.38	2.49	2.75	2.87	2.87
	HDD10.0	112	0	0	0	2	7	23	29	28	15	7	1	0
	HDD18.3	1814	46	36	68	122	182	232	258	255	214	186	129	86
	CDD10.0	1438	241	226	207	133	84	41	29	32	51	82	127	186
	CDD18.3	99	29	29	17	3	1	0	0	0	0	2	6	13
	CDH23.3	512	174	119	65	12	1	0	0	0	1	16	37	87
CDH26.7	139	56	28	14	1	0	0	0	0	0	3	9	27	
Wind	WSAvg	6.6	6.6	6.2	6.3	6.1	6.7	6.0	6.6	6.8	7.2	7.0	6.9	7.2
Precipitation	PrecAvg	745	51	35	51	62	81	72	85	76	68	51	55	60
	PrecMax	1007	147	145	151	135	212	131	219	167	134	124	118	205
	PrecMin	435	5	1	6	13	19	32	14	6	21	15	15	8
	PrecStd	134	34	31	39	34	49	26	46	38	30	27	25	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	30.3	28.4	25.0	20.8	17.5	16.5	18.2	21.2	25.4	27.5	30.8
		MCWB	20.2	19.2	19.2	15.8	14.2	13.6	11.3	12.1	13.4	14.7	18.0	18.6
	2%	DB	27.2	26.2	24.8	22.2	18.9	16.1	15.0	16.2	18.5	21.3	23.3	25.5
		MCWB	19.3	19.5	18.8	16.1	14.4	13.1	11.3	11.4	12.9	14.2	16.9	18.0
	5%	DB	24.7	24.4	22.8	20.1	17.5	15.1	14.1	14.9	16.6	19.0	20.7	22.8
		MCWB	19.0	19.2	18.3	15.9	14.1	12.4	11.2	11.2	12.6	14.1	16.4	17.5
	10%	DB	22.7	22.7	21.3	18.7	16.4	14.3	13.4	13.7	15.1	17.0	18.8	20.8
		MCWB	18.3	18.5	17.6	15.5	13.6	11.9	10.9	10.9	11.9	13.7	15.2	16.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	21.3	21.0	18.5	16.2	14.9	13.2	13.7	15.3	16.9	19.2	20.6
		MCDB	26.9	25.2	24.5	21.2	18.1	16.4	14.7	15.6	18.3	19.5	24.6	24.9
	2%	WB	20.6	20.6	19.9	17.4	15.4	13.7	12.3	12.6	14.1	15.7	17.7	19.2
		MCDB	24.9	24.3	23.0	20.0	17.4	15.3	13.9	14.6	17.2	18.9	21.8	23.2
	5%	WB	19.6	19.9	19.0	16.7	14.6	12.9	11.7	11.8	13.0	14.7	16.7	18.1
		MCDB	23.7	23.2	22.1	19.3	16.7	14.6	13.4	14.1	15.6	18.0	19.7	21.6
	10%	WB	18.7	19.1	18.0	15.8	13.9	12.2	11.2	11.2	12.2	13.8	15.7	17.1
		MCDB	22.3	22.4	21.1	18.4	16.1	14.0	12.9	13.3	14.6	17.0	18.5	20.5
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.5	7.6	7.4	6.4	6.3	6.1	6.4	6.7	7.6	7.4	7.4
		MCDBR	11.1	9.6	10.0	9.6	7.4	6.7	6.7	7.8	9.4	11.3	10.9	11.7
		MCWBR	5.0	4.5	5.4	5.5	4.7	4.7	4.7	4.8	5.5	6.0	5.6	5.8
	5% WB	MCDBR	9.6	8.1	8.6	8.2	6.4	5.6	6.0	6.6	7.9	9.4	9.1	10.1
		MCWBR	5.1	4.5	5.2	5.4	4.6	4.5	4.8	4.7	5.2	5.8	5.4	5.6
Clear-Sky Solar Irradiance	taub	0.355	0.351	0.336	0.324	0.311	0.303	0.304	0.314	0.340	0.341	0.345	0.346	
	taud	2.516	2.547	2.588	2.601	2.608	2.617	2.614	2.585	2.500	2.511	2.524	2.534	
	Ebn at Noon	974	953	926	872	820	795	819	870	906	952	978	989	
	Edh at Noon	110	102	90	77	65	60	64	77	96	105	109	109	
All-Sky Solar Radiation	RadAvg	6.92	5.97	4.73	3.24	2.19	1.72	1.96	2.83	4.11	5.50	6.44	7.21	
	RadStd	0.41	0.29	0.24	0.14	0.11	0.12	0.07	0.17	0.26	0.25	0.39	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.50	N/A	+0.53	N/A	+0.59	+0.66	N/A	N/A	+105	+21
(47) Regional (12 neighbors)		+0.34	N/A	+0.38	+0.66	+0.39	N/A	N/A	-82	+96	+16

Nomenclature: See separate page