

LORD HOWE ISLAND, Australia

WMO: 949950

Lat: 31.5422S

Lon: 159.0786E

Elev: 23

StdP: 14.68

Time Zone: 10.50 (AUH)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	51.6	54.3	41.2	38.1	59.8	42.6	40.3	59.9	35.9	62.1	32.2	62.0	0.9	130	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	80.1	72.9	78.8	71.9	77.8	71.0	75.0	78.1	73.8	77.3	72.8	76.5	11.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	126.2	77.2	72.7	121.2	76.6	71.5	116.2	75.9	38.5	78.3	37.5	77.5	36.5	76.6	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.4	27.6	24.4	47.0	82.0	1.6	1.9	45.8	83.3	44.9	84.4	44.0	85.5	42.8	86.8		
(5)			45.4	76.2	1.3	1.2	44.4	77.0	43.6	77.7	42.9	78.3	41.9	79.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	73.3	73.9	72.4	69.3	66.0	63.3	61.5	61.3	63.2	64.7	67.6	70.7
	DBStd	5.18	2.66	2.40	2.27	2.47	2.85	2.61	2.66	2.69	2.91	3.10	3.16	2.89
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	442	0	0	0	1	22	63	112	118	70	44	11	1
	CDD50	6290	723	669	695	578	496	398	357	351	395	456	529	643
	CDD65	1258	258	249	230	130	53	12	4	4	15	36	89	178
	CDH74	2284	734	765	414	65	6	0	0	0	0	1	42	257
	CDH80	40	15	22	1	0	0	0	0	0	0	0	0	2
Wind	WSAvg	12.0	12.9	13.0	12.4	11.2	12.0	12.6	12.4	12.0	11.9	11.2	11.4	11.5
Precipitation	PrecAvg	56.5	4.0	3.8	4.8	5.1	5.9	6.1	5.8	4.9	4.6	4.1	4.5	4.1
	PrecMax	72.1	18.9	10.9	11.4	21.4	12.7	12.9	11.1	11.3	8.4	8.9	15.8	11.8
	PrecMin	36.5	0.4	0.1	0.6	1.2	1.9	2.2	2.3	0.9	1.6	0.6	0.2	0.3
	PrecStd	9.2	3.2	2.7	3.1	3.3	2.6	2.5	2.2	2.2	1.7	1.9	3.0	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.8	82.3	79.7	77.3	74.9	71.1	69.7	70.0	71.5	73.3	77.2	79.6
		MCWB	73.2	75.3	72.5	69.0	67.7	63.5	62.9	63.8	66.0	67.2	70.0	72.6
	2%	DB	80.0	80.4	78.3	75.6	72.9	69.8	68.3	68.6	70.1	71.9	75.2	77.9
		MCWB	72.5	73.7	70.8	67.7	65.6	62.6	61.9	62.3	64.5	66.0	69.1	71.3
	5%	DB	78.7	79.0	77.3	74.5	71.8	68.7	67.3	67.4	69.0	70.8	73.7	76.5
		MCWB	71.9	72.2	69.8	66.9	64.7	61.5	60.7	60.8	63.5	65.0	68.0	70.3
	10%	DB	77.5	77.8	76.3	73.5	70.7	67.6	66.1	66.2	68.0	69.7	72.5	75.4
		MCWB	71.2	71.0	69.0	66.1	63.6	60.5	59.1	59.4	62.5	64.0	66.9	69.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.3	76.8	74.8	72.2	70.1	66.2	66.2	66.3	67.7	69.5	72.1	75.0
		MCDB	79.0	79.8	77.9	75.1	73.1	69.1	68.4	68.9	70.2	71.8	74.9	77.5
	2%	WB	74.7	75.2	73.4	69.8	67.7	64.7	63.9	64.0	66.1	67.5	70.9	73.2
		MCDB	78.0	78.6	76.7	74.2	71.8	68.2	67.0	67.4	69.0	70.6	73.7	76.2
	5%	WB	73.6	74.1	72.0	68.5	66.2	63.4	61.9	62.3	64.8	66.4	69.5	72.0
		MCDB	77.3	77.7	75.8	73.3	70.5	67.5	66.1	66.2	68.1	69.8	72.8	75.3
	10%	WB	72.5	72.9	70.8	67.3	64.7	61.9	60.3	60.6	63.5	65.2	68.0	70.8
		MCDB	76.5	76.8	75.1	72.4	69.7	66.6	65.2	65.2	67.3	68.9	71.6	74.6
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.4	6.8	7.2	7.3	6.9	7.1	7.6	7.6	7.7	7.0	6.8
		MCDBR	7.6	7.3	7.7	8.4	8.0	7.9	8.5	8.6	7.9	7.9	7.4	7.4
		MCWBR	4.9	4.7	4.7	5.4	5.5	5.9	6.6	6.8	6.4	6.3	5.3	5.3
	5% WB	MCDBR	6.5	6.4	6.5	7.5	6.7	6.6	6.8	7.2	7.2	7.2	6.7	6.9
		MCWBR	5.2	4.9	5.1	5.9	5.6	6.3	6.8	7.2	6.9	6.9	5.8	5.8
Clear-Sky Solar Irradiance	taub	0.374	0.355	0.342	0.332	0.321	0.319	0.313	0.324	0.352	0.358	0.353	0.366	
	taud	2.543	2.618	2.656	2.667	2.651	2.648	2.658	2.609	2.515	2.520	2.568	2.552	
	Ebn at Noon	306	306	300	287	274	267	275	285	292	302	311	310	
	Edh at Noon	35	31	28	25	23	22	23	26	32	34	34	35	
All-Sky Solar Radiation	RadAvg	2229	2047	1685	1333	1015	811	906	1193	1580	1895	2138	2242	
	RadStd	143	116	110	82	52	59	45	58	88	119	128	188	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.49	N/A	N/A	+0.67	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page