

LORD HOWE ISLAND, Australia

WMO: 949950

Lat: 31.5422S

Lon: 159.0786E

Elev: 7

StdP: 101.24

Time Zone: 10.50 (AUH)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	12.4	5.1	5.4	15.5	5.9	5.8	15.5	16.0	16.7	14.4	16.6	0.4	130	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.6	26.7	22.7	26.0	22.1	25.5	21.6	23.9	25.6	23.2	25.2	22.7	24.7	5.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.2	18.0	25.1	22.6	17.3	24.8	21.9	16.6	24.4	71.7	25.7	69.3	25.3	67.1	24.8	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.1	12.3	10.9	8.3	27.8	0.9	1.0	7.7	28.5	7.2	29.1	6.6	29.7	6.0	30.4		
			7.4	24.5	0.7	0.6	6.9	25.0	6.5	25.4	6.0	25.7	5.5	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	23.0	23.3	22.5	20.7	18.9	17.4	16.4	16.3	17.3	18.2	19.8	21.5
	DBStd	2.88	1.48	1.33	1.26	1.37	1.58	1.45	1.48	1.50	1.62	1.72	1.75	1.60
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	246	0	0	0	1	12	35	62	66	39	24	6	1
	CDD10.0	3494	402	372	386	321	276	221	198	195	219	253	294	357
	CDD18.3	699	143	138	128	72	29	7	2	2	8	20	49	99
	CDH23.3	1269	408	425	230	36	3	0	0	0	0	1	23	143
CDH26.7	22	8	12	1	0	0	0	0	0	0	0	0	1	
Wind	WSAvg	5.4	5.8	5.8	5.6	5.0	5.4	5.6	5.5	5.4	5.3	5.0	5.1	5.1
Precipitation	PrecAvg	1434	102	96	123	130	150	156	148	124	116	103	115	104
	PrecMax	1831	480	276	289	544	322	328	283	286	214	227	402	300
	PrecMin	926	11	3	16	31	48	56	58	23	40	14	6	8
	PrecStd	234	82	69	78	83	67	64	55	56	43	47	77	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.7	28.0	26.5	25.2	23.8	21.7	21.0	21.1	21.9	23.0	25.1	26.4
		MCWB	22.9	24.0	22.5	20.5	19.8	17.5	17.2	17.7	18.9	19.5	21.1	22.6
	2%	DB	26.7	26.9	25.7	24.2	22.7	21.0	20.2	20.3	21.1	22.2	24.0	25.5
		MCWB	22.5	23.1	21.6	19.9	18.7	17.0	16.6	16.8	18.0	18.9	20.6	21.9
	5%	DB	25.9	26.1	25.2	23.6	22.1	20.4	19.6	19.7	20.6	21.6	23.2	24.7
		MCWB	22.1	22.3	21.0	19.4	18.2	16.4	15.9	16.0	17.5	18.4	20.0	21.3
	10%	DB	25.3	25.4	24.6	23.1	21.5	19.8	18.9	19.0	20.0	21.0	22.5	24.1
		MCWB	21.8	21.7	20.6	18.9	17.5	15.8	15.1	15.2	16.9	17.8	19.4	20.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.9	23.8	22.3	21.2	19.0	19.0	19.1	19.8	20.8	22.3	23.9
		MCDB	26.1	26.6	25.5	23.9	22.8	20.6	20.2	20.5	21.2	22.1	23.8	25.3
	2%	WB	23.7	24.0	23.0	21.0	19.8	18.2	17.7	17.8	19.0	19.7	21.6	22.9
		MCDB	25.5	25.9	24.9	23.4	22.1	20.1	19.4	19.7	20.5	21.4	23.2	24.5
	5%	WB	23.1	23.4	22.2	20.3	19.0	17.5	16.6	16.9	18.2	19.1	20.8	22.2
		MCDB	25.2	25.4	24.3	22.9	21.4	19.7	18.9	19.0	20.1	21.0	22.6	24.1
	10%	WB	22.5	22.7	21.6	19.6	18.2	16.6	15.7	15.9	17.5	18.4	20.0	21.5
		MCDB	24.7	24.9	23.9	22.5	21.0	19.2	18.5	18.4	19.6	20.5	22.0	23.7
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.6	3.8	4.0	4.1	3.9	3.9	4.2	4.2	4.3	3.9	3.8
		MCDBR	4.2	4.1	4.3	4.7	4.4	4.4	4.7	4.8	4.4	4.4	4.1	4.1
		MCWBR	2.7	2.6	2.6	3.0	3.1	3.3	3.7	3.8	3.5	3.5	3.0	2.9
	5% WB	MCDBR	3.6	3.6	3.6	4.1	3.7	3.7	3.8	4.0	4.0	4.0	3.7	3.9
		MCWBR	2.9	2.7	2.9	3.3	3.1	3.5	3.8	4.0	3.8	3.9	3.2	3.2
Clear-Sky Solar Irradiance	taub	0.374	0.355	0.342	0.332	0.321	0.319	0.313	0.324	0.352	0.358	0.353	0.366	
	taud	2.543	2.618	2.656	2.667	2.651	2.648	2.658	2.609	2.515	2.520	2.568	2.552	
	Ebn at Noon	965	966	945	905	864	842	866	899	919	951	979	976	
	Edh at Noon	110	99	89	80	72	69	71	83	101	108	106	109	
All-Sky Solar Radiation	RadAvg	7.03	6.45	5.31	4.20	3.20	2.56	2.86	3.76	4.98	5.97	6.74	7.07	
	RadStd	0.45	0.36	0.35	0.26	0.16	0.19	0.14	0.18	0.28	0.38	0.40	0.59	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.27	N/A	N/A	+0.37	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page