

NORFOLK ISLAND, Norfolk Island

WMO: 949960

Lat: 29.0389S

Lon: 167.9408E

Elev: 383

StdP: 14.49

Time Zone: 11.00 (PCN)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	54.4	55.3	40.5	37.6	58.7	42.1	40.0	59.1	27.2	60.7	25.1	60.8	6.7	90	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.3	78.4	71.8	77.1	70.8	76.0	69.8	74.1	76.2	73.0	75.2	72.1	74.7	13.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.4	126.0	75.3	72.0	119.9	74.3	71.3	117.0	73.9	37.8	75.8	36.9	76.0	36.0	74.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	22.1	20.2	51.9	80.6	1.2	1.4	51.0	81.6	50.3	82.4	49.6	83.1	48.8	84.1
			46.2	75.4	1.2	1.5	45.3	76.5	44.7	77.4	44.0	78.2	43.2	79.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	71.3	72.4	71.4	68.8	65.8	63.0	61.2	60.6	62.0	63.6	65.8	69.3	(6)
	DBStd	4.62	2.09	2.11	2.00	2.11	2.28	2.15	2.18	2.18	2.15	2.18	2.33	2.51	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	506	0	0	0	1	17	68	118	136	93	55	17	1	(9)
	CDD50	5927	661	628	664	563	489	389	348	329	359	423	475	599	(10)
	CDD65	961	196	208	199	114	42	7	2	1	2	13	42	135	(11)
	CDH74	921	240	356	196	33	0	0	0	0	0	0	4	92	(12)
	CDH80	4	1	2	1	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	11.5	11.8	12.5	11.9	11.3	11.5	11.5	12.0	11.4	11.4	11.2	10.8	10.9	(14)
(15) Precipitation	PrecAvg	48.8	3.2	3.8	3.9	4.7	4.5	5.7	4.9	4.3	3.7	2.9	3.3	3.6	(15)
	PrecMax	79.1	11.9	17.2	13.8	16.9	12.9	15.8	11.3	9.5	13.2	13.1	17.6	18.6	(16)
	PrecMin	30.9	0.4	0.4	0.5	0.6	1.0	0.9	1.2	1.4	0.6	0.6	0.2	0.3	(17)
	PrecStd	13.4	2.7	3.5	2.6	3.6	2.8	3.0	2.4	2.0	2.4	2.2	2.9	3.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	80.3	78.9	77.0	73.4	70.1	68.4	68.2	69.9	71.8	74.8	77.4	(19)
		MCWB	71.7	74.2	72.2	71.6	67.7	65.0	63.5	62.4	63.9	66.2	67.8	71.3	(20)
	2%	DB	77.4	78.7	77.1	74.9	71.8	68.6	67.3	66.5	68.2	70.0	73.0	76.2	(21)
		MCWB	70.6	72.2	70.7	68.9	66.4	63.8	62.1	60.7	62.5	64.5	66.5	70.2	(22)
	5%	DB	76.6	77.2	75.7	73.5	70.4	68.0	66.2	65.9	66.9	68.8	71.6	75.1	(23)
		MCWB	70.0	71.2	69.3	67.4	65.2	63.3	60.7	60.1	61.1	63.2	65.7	69.1	(24)
	10%	DB	75.3	76.2	75.1	72.1	69.8	66.6	64.8	64.6	66.1	67.9	70.1	73.6	(25)
		MCWB	68.8	70.4	68.7	66.3	64.5	61.4	59.1	58.8	60.3	62.3	64.2	67.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	76.0	74.4	73.3	70.4	68.0	66.3	65.0	66.1	68.2	70.3	73.7	(27)
		MCDB	76.4	78.2	76.7	75.5	71.9	69.0	67.7	66.8	68.1	70.2	72.5	75.9	(28)
	2%	WB	73.2	74.5	73.0	71.2	68.7	66.2	63.9	63.4	64.4	66.5	68.7	72.3	(29)
		MCDB	75.2	76.6	75.3	73.4	70.5	67.8	66.1	65.4	66.8	68.7	71.1	74.8	(30)
	5%	WB	72.2	73.5	72.1	69.7	67.3	64.8	62.1	61.8	63.1	65.2	67.4	71.0	(31)
		MCDB	74.7	75.6	74.5	71.9	69.6	66.9	65.0	64.4	65.9	67.8	70.1	73.7	(32)
	10%	WB	71.0	72.2	70.9	68.3	65.7	63.2	60.8	60.3	61.7	63.7	66.0	70.0	(33)
		MCDB	73.9	75.0	73.7	71.2	68.7	66.1	63.9	63.5	64.9	66.8	69.2	72.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	7.3	7.3	7.2	6.9	6.7	6.9	7.6	7.8	7.9	8.5	8.3	(35)
		MCDBR	8.7	8.2	7.8	7.8	7.1	7.1	7.4	8.1	8.3	8.5	9.2	8.7	(36)
	5% WB	MCWBR	4.7	4.6	4.9	5.0	5.4	5.8	6.0	6.1	6.1	6.0	5.6	4.8	(37)
		MCWBR	7.0	6.3	6.9	6.5	5.6	5.7	6.7	6.9	7.7	7.6	7.9	7.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.358	0.351	0.342	0.330	0.314	0.312	0.306	0.313	0.328	0.334	0.333	0.346	(40)
		taud	2.604	2.640	2.659	2.683	2.702	2.688	2.696	2.659	2.596	2.594	2.623	2.636	(41)
	Ebn at Noon		312	309	302	291	281	275	281	292	301	311	318	316	(42)
		Edh at Noon	33	31	29	25	23	22	22	25	30	32	32	32	(43)
(44) All-Sky Solar Radiation	RadAvg		2225	2035	1734	1394	1064	902	1018	1302	1677	1993	2252	2286	(44)
	RadStd		172	167	110	68	58	73	53	70	90	124	107	191	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page