

HEARD ISLAND THE SPIT, Australia

WMO: 949970

Lat: 53.108S

Lon: 73.722E

Elev: 41

StdP: 14.67

Time Zone: 5.00 (E05)

Period: 03-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.5	24.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.3	55.2	N/A	51.3	N/A	48.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	18.3	65.6	3.1	5.0	16.0	69.1	14.2	72.0	12.5	74.8	10.2	78.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	40.7	41.2	41.1	39.1	36.3	34.1	33.9	32.7	33.1	34.5	36.5	39.2
	DBStd	4.98	2.99	3.12	4.00	4.04	4.25	3.88	4.20	5.04	4.55	3.98	3.15	3.07
	HDD50	4809	289	247	281	329	425	477	499	535	507	480	406	334
	HDD65	10278	754	666	742	778	890	927	964	1000	957	945	856	799
	CDD50	8	0	1	4	1	1	0	0	0	1	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	47.0	3.3	3.3	5.2	5.0	4.3	4.1	4.2	4.3	3.6	3.5	3.5	3.0
	PrecMax	55.8	4.6	5.1	7.2	7.6	5.7	6.5	5.7	5.9	5.2	4.5	5.4	3.9
	PrecMin	39.5	2.2	2.0	3.7	3.7	2.6	1.4	2.9	2.1	1.6	1.8	2.2	2.1
	PrecStd	3.8	0.7	0.7	0.8	0.8	0.9	1.0	0.7	0.9	1.0	0.7	0.7	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	55.2	61.2	57.4	56.2	49.0	50.2	53.7	55.9	55.9	50.0	55.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	49.6	50.5	52.7	50.1	47.9	43.1	44.6	45.6	45.6	45.2	45.1	49.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	46.9	48.0	48.4	46.1	43.6	40.5	41.5	41.1	41.0	41.7	42.7	45.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	44.8	45.7	45.7	43.7	41.0	38.7	39.1	38.8	38.4	39.5	40.9	43.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.8	8.3	8.5	8.3	7.3	7.0	7.5	8.2	7.7	8.0	7.8	8.4
		MCDBR	13.0	12.6	13.3	13.7	13.0	10.3	12.3	12.9	13.2	12.0	11.3	12.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.354	0.346	0.343	0.331	0.332	0.331	0.347	0.356	0.346	0.355	0.342	0.346	
	taud	2.432	2.468	2.442	2.387	2.201	2.120	2.109	2.183	2.326	2.349	2.438	2.446	
	Ebn at Noon	300	291	270	237	184	154	170	217	263	284	302	306	
	Edh at Noon	36	32	29	23	20	18	22	28	31	36	35	36	
All-Sky Solar Radiation	RadAvg	1491	1211	844	472	242	144	178	353	688	1052	1457	1665	
	RadStd	110	85	44	30	15	8	10	26	42	65	101	77	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page