

TRUSCOTT, Australia

WMO: 951010

Lat: 14.0900S

Lon: 126.3867E

Elev: 172

StdP: 14.60

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	61.3	63.3	27.6	21.7	75.8	31.4	25.8	75.1	16.6	79.0	15.6	79.7	5.0	140	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.3	95.2	75.5	93.9	76.0	92.8	76.1	81.4	88.1	80.8	87.7	80.1	87.0	10.6	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	155.9	84.2	79.1	151.8	84.1	78.4	148.2	83.8	45.3	88.2	44.6	87.8	44.0	87.3	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.9	13.8	57.2	98.9	3.3	1.4	54.9	99.9	52.9	100.8	51.0	101.5	48.6	102.6		
(5)			46.5	82.5	2.0	0.5	45.1	82.9	43.9	83.2	42.8	83.4	41.4	83.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	83.2	83.5	83.4	83.1	79.7	76.3	76.0	77.1	81.0	84.5	86.5	85.9
	DBStd	4.40	2.57	2.62	2.23	2.44	3.01	3.72	3.16	2.43	2.81	1.99	1.88	2.83
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11558	1028	939	1037	992	920	790	807	841	930	1068	1094	1112
	CDD65	6083	563	519	572	542	455	340	342	376	480	603	644	647
	CDH74	66781	6654	6100	6647	6027	4206	2646	2703	3153	4764	7097	8405	8379
	CDH80	28012	2557	2391	2571	2470	1665	891	938	1191	1943	3092	4208	4095
Wind	WSAvg	6.9	8.7	7.4	6.6	5.9	6.5	6.8	6.6	6.5	6.7	7.0	7.0	7.2
Precipitation	PrecAvg	49.4	12.2	10.7	8.0	2.6	0.8	0.1	0.1	0.0	0.3	1.6	3.5	9.4
	PrecMax	77.9	27.6	21.7	18.3	11.6	6.1	2.2	1.2	0.2	1.2	9.0	7.7	19.8
	PrecMin	30.0	5.8	4.1	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.2	1.1	2.3
	PrecStd	10.9	4.6	4.4	4.8	3.0	1.4	0.4	0.2	0.0	0.3	1.9	1.6	5.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.5	94.2	94.1	93.8	92.3	90.9	90.3	91.3	94.6	96.3	96.9	96.8
		MCWB	78.5	78.7	77.5	72.8	70.9	70.8	66.3	64.7	68.8	69.0	75.4	76.8
	2%	DB	91.5	92.4	91.9	92.2	90.8	88.6	88.7	89.2	92.4	94.0	94.9	94.8
		MCWB	79.0	78.9	77.7	73.8	69.8	69.0	65.8	64.8	69.3	72.7	76.8	78.0
	5%	DB	90.0	90.8	90.5	91.1	89.5	86.9	87.1	87.8	90.6	92.2	93.6	93.4
		MCWB	78.8	78.9	78.0	74.3	69.6	67.9	65.6	65.1	70.2	74.3	76.9	78.3
	10%	DB	88.5	89.2	89.0	89.9	88.0	85.2	85.3	86.2	88.8	90.7	92.3	91.9
		MCWB	78.4	78.5	78.1	74.3	69.6	66.9	65.1	65.2	70.8	74.9	77.0	78.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.7	82.1	81.8	81.0	78.2	76.3	74.1	75.0	77.7	79.9	81.0	81.9
		MCDB	88.3	88.9	86.8	86.3	83.6	83.0	80.6	81.7	85.1	88.8	89.7	89.2
	2%	WB	80.7	81.2	80.9	79.9	77.2	74.5	72.6	73.8	76.5	78.9	80.1	81.0
		MCDB	87.6	88.0	86.7	86.1	82.4	81.7	79.3	80.8	83.8	87.1	88.1	88.4
	5%	WB	80.0	80.3	80.1	78.9	76.1	72.9	71.3	72.8	75.8	78.1	79.5	80.4
		MCDB	86.5	86.9	86.2	85.6	82.2	80.5	78.8	79.9	83.0	86.0	87.6	87.9
	10%	WB	79.3	79.5	79.5	78.0	74.7	71.2	69.8	71.8	75.1	77.4	79.0	79.8
		MCDB	85.6	85.8	85.5	84.5	81.9	79.9	78.5	78.8	82.2	85.0	87.0	87.4
Mean Daily Temperature Range	5% DB	MDBR	9.8	10.2	11.0	13.8	16.8	17.7	19.6	20.4	17.0	14.0	13.3	11.8
		MCDBR	12.0	12.8	13.1	15.2	18.1	18.0	20.5	21.6	18.6	15.9	14.5	13.6
		MCWBR	4.7	5.4	5.0	5.4	7.2	7.3	7.7	7.4	6.4	5.3	5.1	4.6
	5% WB	MCDBR	10.7	11.7	11.7	12.5	13.5	16.6	17.7	16.5	14.7	13.0	13.1	12.2
MCWBR		5.0	5.5	5.1	4.7	4.9	5.9	6.4	5.2	4.7	4.6	5.1	4.8	
Clear-Sky Solar Irradiance	taub	0.423	0.414	0.393	0.377	0.370	0.345	0.341	0.355	0.412	0.439	0.438	0.417	
	taud	2.485	2.510	2.572	2.571	2.535	2.566	2.561	2.510	2.393	2.341	2.383	2.486	
	Ebn at Noon	293	293	293	287	279	281	285	290	283	282	286	294	
	Edh at Noon	37	36	33	31	30	29	29	33	39	42	41	37	
All-Sky Solar Radiation	RadAvg	1803	1840	1860	1840	1701	1624	1710	1934	2138	2225	2213	1960	
	RadStd	215	265	224	153	102	67	55	42	60	88	78	169	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page