

PORT KEATS AF, Australia

WMO: 951110

Lat: 14.2494S

Lon: 129.5283E

Elev: 29

StdP: 100.98

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.5	15.0	-4.4	2.6	25.2	-2.5	3.1	25.1	7.6	24.3	7.3	24.7	1.5	160	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.0	35.5	23.2	34.8	23.7	34.2	24.0	28.3	31.2	27.6	31.1	27.1	31.0	4.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.6	23.7	29.7	26.7	22.4	29.2	26.1	21.6	29.2	91.7	30.9	87.9	31.2	85.9	30.9	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.4	5.8	10.9	37.7	1.9	0.9	9.6	38.4	8.5	38.9	7.4	39.4	6.1	40.1 (4)		
(5)			7.3	28.4	1.1	0.5	6.5	28.7	5.9	29.0	5.3	29.2	4.5	29.6 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	28.6	28.3	28.8	28.4	26.1	23.9	23.9	24.3	26.7	28.9	29.6	29.3
	DBStd	2.63	1.38	1.37	1.13	1.29	2.04	2.41	1.95	1.62	1.74	1.25	1.18	1.48
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDD10.0	6289	575	513	582	551	498	418	432	444	502	586	589	599
	CDD18.3	3248	317	280	324	301	239	169	174	186	252	327	339	341
	CDH23.3	36474	3703	3154	3698	3377	2441	1484	1607	1795	2652	3981	4332	4250
CDH26.7	16145	1532	1252	1626	1611	1107	558	616	718	1153	1853	2117	2002	
Wind	WSAvg	2.6	2.7	2.5	2.0	2.1	2.8	3.1	2.9	2.7	2.5	2.8	2.7	2.7
Precipitation	PrecAvg	1376	335	317	224	86	27	10	5	2	5	31	74	259
	PrecMax	2268	587	651	558	310	171	77	15	14	25	163	119	537
	PrecMin	735	122	106	57	11	1	1	1	1	1	1	16	40
	PrecStd	337	126	144	148	74	35	14	3	3	6	34	24	125
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	34.9	35.7	35.9	34.7	33.2	33.1	33.6	35.2	36.4	36.2	36.0
		MCWB	24.5	25.8	24.5	22.8	21.0	20.5	19.0	17.4	19.0	19.9	23.3	25.3
	2%	DB	33.8	33.8	34.6	34.9	33.8	32.1	32.0	32.2	33.8	34.9	34.9	34.7
		MCWB	26.4	25.9	24.9	22.9	20.8	20.0	18.4	18.0	20.3	22.2	24.6	25.8
	5%	DB	32.9	32.9	33.7	34.1	33.0	31.1	31.1	31.3	32.7	33.8	34.1	33.9
		MCWB	26.5	26.1	25.2	23.1	21.0	19.4	18.4	18.0	21.4	23.5	25.0	26.1
	10%	DB	32.0	31.8	32.8	33.3	32.1	30.1	30.1	30.4	31.7	33.0	33.4	33.0
		MCWB	26.5	26.2	25.4	23.3	20.8	18.8	18.2	18.2	21.7	23.8	25.1	26.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.2	29.1	27.8	27.6	26.0	24.2	23.3	23.9	25.4	26.6	28.0	28.6
		MCDB	31.5	30.1	31.9	31.7	30.3	28.7	28.6	29.0	29.9	31.1	31.0	32.2
	2%	WB	28.6	27.9	27.2	26.7	25.2	23.1	22.4	23.1	24.8	26.1	27.1	27.5
		MCDB	30.9	31.0	31.5	31.0	29.1	27.9	27.7	28.3	29.2	30.5	31.3	31.7
	5%	WB	27.5	27.2	26.8	26.1	24.5	22.1	21.4	22.5	24.4	25.7	26.6	27.1
		MCDB	30.5	30.8	31.0	30.6	28.5	27.6	26.8	27.5	28.9	30.0	31.1	31.4
	10%	WB	27.0	26.7	26.4	25.6	23.6	20.9	20.3	21.9	24.0	25.4	26.2	26.7
		MCDB	30.1	30.3	30.5	29.8	28.1	27.0	26.4	26.6	28.5	29.8	30.7	31.0
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.7	8.4	10.4	12.2	12.4	13.0	13.2	11.0	9.1	8.0	7.3
		MCDBR	8.0	8.5	10.1	11.7	13.0	12.7	13.8	14.3	11.8	10.2	8.8	8.3
		MCWBR	3.4	3.6	3.7	4.0	4.6	5.0	5.2	5.4	4.3	3.5	3.2	3.2
	5% WB	MCDBR	7.3	7.4	8.4	9.2	9.6	11.6	12.2	11.0	9.4	8.4	7.8	7.4
		MCWBR	4.0	3.6	3.5	3.5	3.7	4.8	5.4	4.5	3.1	2.9	3.0	3.3
Clear-Sky Solar Irradiance	taub	0.417	0.416	0.395	0.375	0.368	0.346	0.341	0.359	0.424	0.452	0.454	0.426	
	taud	2.511	2.511	2.572	2.589	2.541	2.555	2.564	2.506	2.365	2.313	2.345	2.468	
	Ebn at Noon	928	921	922	908	880	884	899	910	881	878	888	918	
	Edh at Noon	114	113	104	97	95	91	92	103	126	137	134	119	
All-Sky Solar Radiation	RadAvg	5.62	5.67	5.81	5.86	5.38	5.08	5.38	6.05	6.65	6.91	6.69	6.00	
	RadStd	0.60	0.83	0.68	0.38	0.26	0.21	0.15	0.15	0.24	0.28	0.29	0.52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	-0.86	N/A	+0.68	+0.22	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page