

MIDDLE POINT, Australia

WMO: 951210

Lat: 12.6050S

Lon: 131.2989E

Elev: 51

StdP: 14.67

Time Zone: 9.50 (AUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	52.2	55.1	32.9	27.4	83.5	37.6	33.1	78.5	17.9	87.1	16.5	86.7	3.4	180	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	20.4	98.3	73.5	96.9	74.2	95.6	74.6	81.6	90.2	80.8	89.4	80.2	88.5	9.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.6	153.7	84.8	78.9	150.1	84.0	78.2	146.8	83.5	45.4	90.3	44.6	89.6	43.9	88.9	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.8	13.4	DB	46.2	101.9	3.4	1.6	43.8	103.0	41.7	104.0	39.8	104.9	37.3	106.0	(4)
(5)			WB	43.8	83.4	3.1	1.2	41.5	84.3	39.7	85.0	37.9	85.7	35.7	86.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.9	83.0	83.1	83.3	82.6	79.1	74.8	74.6	75.9	81.1	84.3	85.0	84.4
	DBStd	4.77	2.55	2.35	2.23	2.33	3.64	4.59	3.94	3.66	3.04	2.05	1.92	2.30
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDD50	11282	1022	928	1033	977	902	745	762	801	933	1063	1049	1067
	CDD65	5809	557	508	568	527	437	295	298	337	483	598	599	602
	CDH74	63265	5772	5222	5822	5509	4320	3078	3379	4047	5609	7109	6861	6537
	CDH80	29850	2232	2086	2340	2570	2017	1377	1581	2086	3155	3957	3506	2943
Wind	WSAvg	5.4	6.0	5.5	4.9	4.8	5.3	5.7	5.6	5.6	5.7	5.9	5.3	5.0
Precipitation	PrecAvg	55.4	13.5	10.7	10.4	2.8	0.5	0.0	0.0	0.1	0.5	2.3	5.2	8.7
	PrecMax	86.1	34.1	20.6	21.8	8.1	3.0	1.1	0.9	0.6	2.7	6.4	9.3	19.1
	PrecMin	34.4	5.3	1.9	1.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	0.7
	PrecStd	10.7	5.4	4.7	5.0	2.2	0.7	0.2	0.2	0.1	0.7	1.9	2.4	4.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.1	96.3	96.2	95.6	94.3	93.0	93.2	95.4	98.9	100.6	99.9	98.4
		MCWB	79.4	78.8	78.6	74.8	72.4	71.0	69.2	67.8	69.1	71.7	75.1	78.1
	2%	DB	93.9	94.3	94.2	94.0	92.5	91.1	91.3	93.4	96.9	98.4	97.6	96.2
		MCWB	79.3	79.1	78.6	74.7	72.5	70.2	68.2	67.6	69.9	72.3	75.7	78.7
	5%	DB	92.1	92.6	92.5	92.7	91.2	89.6	89.9	91.7	95.4	96.8	95.9	94.5
		MCWB	79.3	79.1	78.6	74.6	72.5	69.4	67.6	66.8	70.1	73.1	76.1	78.5
	10%	DB	90.1	90.6	90.6	91.4	89.7	87.8	88.2	89.9	93.7	95.2	94.0	92.5
		MCWB	79.1	79.0	78.6	74.9	72.4	68.2	67.0	66.4	70.4	73.4	76.5	78.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.5	82.7	82.1	80.9	78.9	75.9	75.1	74.6	77.3	79.2	80.9	82.0
		MCDB	91.1	89.4	90.5	88.4	86.5	85.7	85.9	88.3	88.9	90.1	91.2	91.8
	2%	WB	81.2	81.2	81.0	79.6	77.7	74.1	73.2	73.0	76.1	78.2	79.8	80.8
		MCDB	89.5	89.4	89.0	87.0	85.4	84.8	84.9	86.0	87.7	89.1	90.3	90.6
	5%	WB	80.4	80.4	80.3	78.8	76.8	72.7	71.8	71.9	75.2	77.4	78.9	80.1
		MCDB	88.3	88.8	88.0	86.0	84.6	83.8	83.8	84.2	86.5	88.1	89.5	89.5
	10%	WB	79.6	79.7	79.6	78.1	75.7	71.3	70.1	70.6	74.2	76.6	78.1	79.4
		MCDB	87.1	87.3	86.8	84.9	83.5	82.4	82.1	82.9	85.4	87.2	88.3	88.5
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.6	15.0	18.9	22.9	27.5	29.5	31.1	28.1	24.3	20.4	16.7
		MCDBR	17.6	18.5	18.5	20.9	23.7	26.7	29.4	31.5	29.7	26.5	22.9	20.2
		MCWBR	6.2	6.4	6.0	5.8	7.2	8.8	9.6	10.1	8.7	7.0	5.9	6.1
	5% WB	MCDBR	15.1	16.1	15.8	16.9	18.6	23.9	25.4	27.6	24.5	21.9	19.8	17.6
		MCWBR	6.2	6.3	6.0	5.3	5.9	8.5	9.1	9.6	7.2	6.1	6.5	6.3
Clear-Sky Solar Irradiance	taub	0.422	0.411	0.399	0.377	0.372	0.354	0.347	0.367	0.431	0.454	0.456	0.424	
	taud	2.473	2.499	2.531	2.571	2.534	2.529	2.544	2.476	2.320	2.281	2.312	2.450	
	Ebn at Noon	293	294	292	288	279	280	285	287	278	278	281	292	
	Edh at Noon	37	36	34	31	31	30	30	34	42	45	44	38	
All-Sky Solar Radiation	RadAvg	1659	1735	1773	1841	1714	1648	1724	1926	2084	2148	2036	1813	
	RadStd	165	249	211	143	87	54	43	54	84	89	73	161	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page