

NGAYAWILI, Australia

WMO: 951460

Lat: 11.997S

Lon: 135.572E

Elev: 9

StdP: 101.22

Time Zone: 9.50 (AUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	19.0	11.5	8.4	25.5	12.9	9.3	24.5	8.1	24.9	7.5	25.5	2.8	160	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.6	33.3	25.6	32.9	25.9	32.4	25.9	28.9	30.7	28.2	30.5	27.8	30.3	5.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.4	24.8	30.1	27.7	23.7	29.8	27.1	22.9	29.6	94.3	30.8	91.3	30.5	89.1	30.4	33.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	10.5	9.0	DB	14.8	35.1	1.9	0.6	13.4	35.6	12.3	35.9	11.2	36.3	9.9	36.7	(4)
(5)			WB	13.6	30.2	1.2	2.0	12.7	31.7	12.0	32.8	11.3	34.0	10.4	35.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	28.7	28.4	28.2	27.5	26.7	24.9	24.6	24.9	26.2	27.5	28.6	29.2	(6)	
	DBStd	2.00	1.20	1.16	1.11	0.94	1.21	1.71	1.32	1.27	1.28	1.19	1.06	1.24	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6238	579	516	563	526	517	446	452	461	485	543	557	594	(10)	
	CDD18.3	3197	321	283	304	276	258	196	194	202	235	284	307	336	(11)	
	CDH23.3	33822	3986	3419	3468	2861	2370	1363	1280	1537	2192	3181	3817	4348	(12)	
	CDH26.7	12680	1618	1310	1262	965	705	324	296	443	782	1293	1694	1988	(13)	
(14) Wind	WSAvg	4.2	6.0	6.0	4.1	3.1	3.6	4.1	3.9	3.5	3.4	3.7	4.0	4.8	(14)	
(15) Precipitation	PrecAvg	1460	369	333	300	136	29	5	3	1	1	6	64	221	(15)	
	PrecMax	2216	954	835	684	454	156	69	15	20	12	44	566	647	(16)	
	PrecMin	639	102	93	51	7	0	0	0	0	0	0	0	36	(17)	
	PrecStd	387	170	153	155	123	34	11	4	3	2	10	95	141	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.0	33.0	33.1	32.2	31.1	30.7	31.6	33.0	34.1	34.0	33.7	(19)	
		MCWB	27.1	26.7	26.5	25.9	25.0	23.8	22.3	21.7	22.7	23.4	25.2	26.0	(20)	
	2%	DB	32.3	32.2	32.2	32.2	31.4	30.2	29.9	30.7	32.1	33.0	33.0	33.2	(21)	
		MCWB	27.0	26.7	26.6	25.5	24.9	23.4	22.1	21.6	23.0	24.3	25.9	26.4	(22)	
	5%	DB	31.7	31.6	31.5	31.6	30.8	29.4	29.2	30.0	31.3	32.2	32.5	32.7	(23)	
		MCWB	27.0	26.7	26.6	25.3	24.5	23.0	22.0	21.5	23.1	24.8	26.0	26.4	(24)	
	10%	DB	31.1	30.9	30.9	30.9	30.0	28.6	28.5	29.2	30.5	31.4	31.9	32.2	(25)	
		MCWB	26.9	26.7	26.6	25.3	24.2	22.6	21.7	21.3	23.1	24.9	25.9	26.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.2	29.1	30.1	29.2	27.6	26.7	25.6	25.8	26.4	28.2	28.7	28.9	(27)	
		MCDB	31.2	30.7	30.5	30.7	30.1	28.7	28.4	28.8	30.3	30.7	31.8	31.7	(28)	
	2%	WB	28.5	28.2	28.6	27.7	26.5	25.0	24.5	24.3	25.6	27.1	27.7	28.1	(29)	
		MCDB	30.6	30.1	30.1	29.9	29.5	27.9	27.4	27.9	29.6	30.4	31.0	31.2	(30)	
	5%	WB	28.0	27.7	27.8	26.7	25.7	24.2	23.7	23.4	24.9	26.2	27.1	27.5	(31)	
		MCDB	30.2	29.9	30.2	29.5	28.8	27.6	26.8	27.4	28.8	30.1	30.8	31.0	(32)	
	10%	WB	27.5	27.2	27.2	26.2	25.1	23.6	22.9	22.7	24.3	25.7	26.7	27.1	(33)	
		MCDB	30.1	29.7	30.0	29.0	28.4	27.1	26.4	26.9	28.3	29.7	30.5	30.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	4.4	5.2	6.8	7.3	8.0	8.7	9.7	9.5	8.5	7.3	5.6	(35)	
		MCDBR	5.3	5.5	6.4	8.1	8.0	8.2	9.0	10.1	10.1	9.3	7.8	6.4	(36)	
	5% WB	MCWBR	2.5	2.5	2.9	3.1	3.0	2.9	3.0	3.3	3.3	3.1	2.9	2.6	(37)	
		MCWBR	4.4	4.2	5.5	6.9	7.1	7.4	7.8	8.9	8.9	8.2	6.5	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.417	0.405	0.393	0.385	0.381	0.371	0.360	0.365	0.396	0.414	0.420	0.412	(40)	
		taud	2.529	2.563	2.599	2.605	2.584	2.582	2.609	2.568	2.461	2.426	2.451	2.522	(41)	
	Ebn at Noon		927	932	925	902	874	868	887	908	908	913	917	930	(42)	
		Edh at Noon	112	108	102	96	93	90	89	98	115	122	120	112	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.19	5.29	5.19	5.19	4.97	4.74	5.04	5.88	6.60	6.97	6.81	5.94	(44)	
	RadStd		0.68	0.83	0.58	0.68	0.41	0.31	0.23	0.22	0.25	0.31	0.34	0.63	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	+0.41	+0.18	+0.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page