

WEST ROEBUCK, Australia

WMO: 952040

Lat: 17.8964S

Lon: 122.3122E

Elev: 105

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	51.0	53.9	N/A	N/A	N/A	N/A	N/A	N/A	19.2	71.7	17.5	74.0	6.5	100	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.4	100.7	N/A	98.2	N/A	96.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.0	16.1	14.4	DB	45.2	107.5	3.9	2.8	42.4	109.5	40.1	111.1	37.9	112.7	35.0	114.8	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	84.8	84.1	85.0	83.3	76.6	72.4	71.9	73.5	78.3	82.4	85.2	86.2
	DBStd	6.28	2.88	2.94	2.74	3.24	4.39	4.61	4.00	3.44	3.36	3.36	3.08	3.07
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	9	0	0	0	0	1	5	2	1	0	0	0	0
	CDD50	11057	1078	956	1086	998	824	673	680	729	848	1004	1057	1124
	CDD65	5590	613	536	621	548	360	227	217	265	398	539	607	659
	CDH74	64902	7578	6453	7585	6279	3540	2036	1988	2712	4129	6238	7741	8623
	CDH80	30891	3490	2859	3640	3197	1614	727	707	1124	2022	3137	3985	4389
(14) Wind	WSAvg	7.6	7.8	7.6	7.1	6.9	7.1	7.5	7.4	7.4	7.7	7.8	8.2	8.7
(15) Precipitation	PrecAvg	28.5	7.6	7.7	4.0	1.1	0.9	0.9	0.4	0.1	0.0	0.2	0.6	4.7
	PrecMax	55.6	29.1	18.3	15.7	8.3	8.2	5.8	4.4	0.6	0.1	1.2	1.7	12.8
	PrecMin	8.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.4
	PrecStd	10.6	5.9	5.2	4.2	1.7	1.9	1.5	1.1	0.1	0.0	0.3	0.4	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.6	99.0	101.2	101.8	97.1	92.8	92.9	94.9	100.3	102.5	103.4	104.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	95.2	95.2	97.1	97.8	94.2	89.7	89.7	91.7	96.9	97.4	99.0	98.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	93.1	93.0	94.9	95.0	91.4	87.1	86.8	89.0	93.4	94.7	96.3	95.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	91.2	90.9	92.6	92.9	88.5	84.5	84.0	86.5	89.9	92.3	93.8	93.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	12.9	16.0	21.4	26.0	26.7	27.6	29.5	25.6	20.4	17.4	14.4
		MCDBR	15.9	16.6	20.0	24.5	29.2	28.2	30.2	32.5	32.1	24.7	21.9	19.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.421	0.411	0.389	0.370	0.355	0.330	0.327	0.335	0.366	0.404	0.408	0.408
	taud		2.469	2.504	2.563	2.557	2.534	2.577	2.567	2.503	2.462	2.396	2.427	2.488
	Ebn at Noon		294	293	293	287	280	282	286	293	295	292	295	297
	Edh at Noon		38	36	33	31	30	27	28	32	36	40	39	37
(44) All-Sky Solar Radiation	RadAvg		2075	2035	1958	1879	1623	1523	1615	1899	2179	2350	2428	2272
	RadStd		196	230	209	89	102	96	89	55	55	67	70	139

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.79	N/A	N/A	N/A	+0.97	+0.67	+0.58	N/A	N/A	+414	+416

Nomenclature: See separate page