

WEST ROEBUCK, Australia

WMO: 952040

Lat: 17.8964S

Lon: 122.3122E

Elev: 32

StdP: 100.94

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 10.6	(c) 12.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 8.6	(k) 22.1	(l) 7.8	(m) 23.3	(n) 2.9	(o) 100	(p) 0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 12	(b) 8.0	(c) 38.2	(d) N/A	(e) 36.8	(f) N/A	(g) 35.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.7	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.0	(b) 7.2	(c) 6.5	(e) 7.3	(f) 41.9	(g) 2.2	(h) 1.6	(i) 5.8	(j) 43.1	(k) 4.5	(l) 44.0	(m) 3.3	(n) 44.8	(o) 1.7	(p) 46.0		
			DB													
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	29.3	29.0	29.5	28.5	24.8	22.5	22.2	23.1	25.7	28.0	29.6	30.1		
	DBStd	3.49	1.60	1.63	1.52	1.80	2.44	2.56	2.22	1.91	1.87	1.87	1.71	1.71		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	5	0	0	0	0	1	3	1	1	0	0	0	0		
	CDD10.0	6143	599	531	603	554	458	374	378	405	471	558	587	624		
	CDD18.3	3106	341	298	345	304	200	126	121	147	221	299	337	366		
	CDH23.3	36057	4210	3585	4214	3488	1967	1131	1104	1507	2294	3466	4301	4791		
	CDH26.7	17162	1939	1588	2022	1776	897	404	393	624	1123	1743	2214	2438		
(14) Wind	WSAvg	3.4	3.5	3.4	3.2	3.1	3.2	3.3	3.3	3.3	3.4	3.5	3.7	3.9		
(15) Precipitation	PrecAvg	723	194	195	102	27	23	22	10	2	1	4	14	119		
	PrecMax	1413	739	466	398	212	208	148	111	14	3	30	42	324		
	PrecMin	202	0	0	0	1	0	1	0	0	0	0	2	10		
	PrecStd	268	150	133	107	43	48	37	28	3	1	7	11	75		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	37.2	38.4	38.8	36.1	33.8	33.8	35.0	37.9	39.1	39.7	40.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	35.1	35.1	36.2	36.6	34.5	32.1	32.0	33.1	36.0	36.3	37.2	37.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	33.9	33.9	34.9	35.0	33.0	30.6	30.4	31.6	34.1	34.8	35.7	35.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	32.9	32.7	33.7	33.8	31.4	29.2	28.9	30.3	32.2	33.5	34.3	34.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		7.1	7.2	8.9	11.9	14.5	14.8	15.3	16.4	14.2	11.4	9.7	8.0		
	5% DB	MCDBR	8.8	9.2	11.1	13.6	16.2	15.7	16.8	18.1	17.8	13.7	12.1	10.6		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.421	0.411	0.389	0.370	0.355	0.330	0.327	0.335	0.366	0.404	0.408	0.408		
	taud		2.469	2.504	2.563	2.557	2.534	2.577	2.567	2.503	2.462	2.396	2.427	2.488		
	Ebn at Noon		926	925	923	904	882	889	903	925	930	920	931	937		
	Edh at Noon		119	114	104	98	93	86	89	101	113	125	124	117		
(44) All-Sky Solar Radiation	RadAvg		6.54	6.42	6.17	5.92	5.12	4.80	5.09	5.99	6.87	7.41	7.66	7.16		
	RadStd		0.62	0.73	0.66	0.28	0.32	0.30	0.28	0.17	0.17	0.21	0.22	0.44		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.44	N/A	N/A	+0.54	+0.37	+0.32	N/A	N/A	+230	+231

Nomenclature: See separate page