

WYNDHAM AP, Australia

WMO: 952140

Lat: 15.510S

Lon: 128.150E

Elev: 4

StdP: 101.27

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.8	13.4	-7.2	2.0	27.1	-5.5	2.4	25.6	10.0	24.9	9.3	25.7	1.4	80	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.4	40.9	23.0	39.9	23.2	38.9	23.3	28.2	32.6	27.5	32.2	27.0	32.0	4.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.1	29.9	26.5	22.0	29.3	25.9	21.2	29.0	90.8	32.4	87.4	32.3	85.3	31.8	35.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.8	7.8	DB	8.9	43.0	1.7	0.8	7.7	43.6	6.7	44.1	5.8	44.5	4.5	45.1	(4)
(5)			WB	4.2	29.0	1.4	2.1	3.2	30.5	2.4	31.7	1.7	32.9	0.7	34.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	31.0	30.7	30.8	30.0	26.7	23.6	23.6	24.9	29.3	31.9	32.9	32.2
	DBStd	3.97	2.14	2.27	2.01	1.92	2.68	2.96	2.60	2.45	2.25	1.75	1.81	2.41
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDD10.0	6918	650	580	644	599	518	408	422	462	578	680	687	689
	CDD18.3	3878	392	347	386	349	259	159	164	203	328	422	437	431
	CDH23.3	51332	5214	4563	5089	4551	3033	1736	1914	2498	4292	5965	6361	6118
	CDH26.7	29092	2839	2447	2746	2582	1585	765	889	1288	2541	3682	4011	3718
Wind	WSAvg	3.5	3.6	3.4	3.0	3.0	3.3	3.4	3.3	3.5	3.8	4.1	3.9	3.8
Precipitation	PrecAvg	759	169	193	144	29	7	2	4	0	3	20	56	137
	PrecMax	1429	363	377	428	149	98	23	84	0	48	107	174	312
	PrecMin	463	36	43	0	0	0	0	0	0	0	0	2	15
	PrecStd	217	83	84	107	36	19	5	15	0	9	29	46	90
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.7	40.6	40.1	39.2	37.0	35.0	35.0	36.4	39.4	41.4	42.0	42.2
		MCWB	24.0	24.0	23.3	22.6	21.6	20.9	19.0	20.0	20.3	21.3	22.3	23.8
	2%	DB	38.8	38.9	38.4	38.0	35.8	33.6	33.9	35.0	38.2	40.1	40.7	40.6
		MCWB	25.0	24.2	24.3	22.2	20.5	19.9	18.4	19.1	20.3	21.7	22.8	24.4
	5%	DB	37.2	37.4	37.2	37.0	34.9	32.4	32.8	34.0	37.2	39.0	39.5	38.9
		MCWB	25.6	24.9	24.6	22.2	20.5	18.9	17.8	18.3	20.5	22.0	23.3	24.9
	10%	DB	35.7	35.6	35.9	36.0	33.7	31.1	31.6	32.8	36.2	37.9	38.2	37.3
		MCWB	25.8	25.5	24.8	22.1	20.0	18.0	17.1	17.5	20.3	22.0	23.8	25.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.4	28.0	29.1	27.8	26.4	23.8	21.7	22.8	24.9	26.2	29.6	31.7
		MCDB	33.6	32.1	32.7	34.3	30.0	28.7	31.8	32.3	31.2	32.7	35.0	37.3
	2%	WB	27.5	27.5	28.0	26.1	25.0	22.2	20.7	21.8	24.0	25.5	26.6	27.9
		MCDB	32.8	31.9	31.9	30.5	29.5	30.1	30.4	31.4	31.5	32.0	32.3	32.3
	5%	WB	27.1	27.0	27.2	25.4	23.9	21.0	19.4	21.0	23.2	24.9	26.0	27.0
		MCDB	32.4	31.8	31.7	30.2	30.2	29.8	29.4	30.1	31.5	31.7	31.9	31.9
	10%	WB	26.7	26.6	26.6	24.8	22.7	19.6	18.2	20.0	22.6	24.4	25.6	26.5
		MCDB	31.9	31.3	31.2	30.3	30.3	28.4	28.8	29.0	31.4	31.8	32.0	31.8
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	9.2	12.0	13.4	14.2	15.4	16.2	14.5	12.8	11.4	10.0
		MCDBR	11.2	11.6	11.6	13.1	14.3	14.5	16.3	16.5	14.8	14.0	12.9	12.1
		MCWBR	3.3	3.3	3.5	3.6	4.6	5.2	6.0	5.8	4.5	4.0	3.6	3.5
	5% WB	MCDBR	9.4	9.1	9.3	9.8	10.2	12.3	14.1	13.6	12.7	12.0	11.3	10.4
		MCWBR	3.3	3.1	3.8	3.4	4.1	4.5	5.4	5.0	3.7	3.5	3.6	4.0
Clear-Sky Solar Irradiance	taub	0.417	0.415	0.399	0.381	0.374	0.345	0.349	0.365	0.425	0.447	0.456	0.426	
	taud	2.466	2.475	2.515	2.503	2.453	2.496	2.462	2.395	2.279	2.255	2.283	2.422	
	Ebn at Noon	928	922	916	898	869	881	886	900	877	882	887	919	
	Edh at Noon	120	117	110	104	103	95	101	114	136	145	143	125	
All-Sky Solar Radiation	RadAvg	6.20	6.18	6.03	5.96	5.40	5.10	5.41	6.16	6.79	7.07	6.96	6.42	
	RadStd	0.49	0.77	0.70	0.41	0.35	0.22	0.19	0.18	0.27	0.36	0.30	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page