

COOKTOWN, Australia

WMO: 952830

Lat: 15.4461S

Lon: 145.1861E

Elev: 19

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	55.8	59.2	51.7	57.0	65.3	54.1	62.3	66.6	22.6	75.0	20.8	75.3	2.3	300	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.0	92.8	78.6	90.3	78.1	88.7	77.6	81.4	87.0	80.4	86.4	79.7	85.4	10.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	156.1	83.3	78.9	150.3	83.0	78.2	146.5	82.3	45.2	87.4	44.1	86.7	43.4	85.9	91.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	19.2	18.0	51.4	98.5	3.9	2.8	48.6	100.5	46.3	102.1	44.1	103.6	41.2	105.6		
(5)			50.7	86.1	3.6	2.9	48.1	88.1	46.0	89.8	43.9	91.5	41.3	93.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	82.1	81.9	80.5	78.7	75.7	72.9	71.4	72.4	75.8	78.8	81.0	82.5
	DBStd	4.71	2.25	2.21	1.96	2.26	2.92	3.54	3.74	3.35	2.78	2.24	2.00	2.21
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	7	0	0	0	0	0	2	4	1	0	0	0	0
	CDD50	10138	994	893	945	860	798	688	663	694	773	892	931	1007
	CDD65	4669	529	473	480	410	333	240	201	230	323	427	481	542
	CDH74	38616	5527	4774	4532	3491	1984	897	621	903	1856	3403	4709	5919
	CDH80	10020	1908	1569	1191	567	139	37	10	44	235	778	1412	2130
Wind	WSAvg	9.5	7.3	6.6	7.6	10.0	9.9	9.6	9.7	10.2	11.1	11.4	10.8	9.1
Precipitation	PrecAvg	65.0	12.8	14.3	14.2	6.6	2.2	1.6	1.1	0.8	0.5	0.9	2.6	7.2
	PrecMax	108.0	26.6	25.0	40.0	24.0	9.8	4.6	2.9	2.8	1.7	6.2	19.4	26.7
	PrecMin	26.3	3.3	1.4	1.4	0.4	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.5
	PrecStd	20.2	7.3	5.9	9.3	5.9	2.0	1.1	0.7	0.7	0.5	1.3	4.1	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.3	95.4	91.6	86.4	84.5	82.7	81.3	83.1	86.0	90.0	93.1	95.8
		MCWB	79.2	78.5	79.2	77.7	75.6	73.8	71.0	71.5	73.4	75.9	77.6	78.4
	2%	DB	92.1	91.6	88.1	85.2	82.6	80.9	79.8	81.2	83.7	86.8	89.0	91.4
		MCWB	79.0	79.1	78.9	76.6	74.0	72.3	70.3	70.3	72.4	75.1	76.5	78.4
	5%	DB	89.4	88.8	86.6	84.2	81.5	79.6	78.5	79.8	82.4	85.3	87.5	89.5
		MCWB	78.4	78.8	78.1	75.9	73.3	71.4	69.5	69.2	71.4	73.9	75.6	77.1
	10%	DB	87.6	87.1	85.3	83.1	80.6	78.4	77.4	78.6	81.2	84.0	86.3	88.2
		MCWB	78.0	78.4	77.4	75.3	72.7	70.7	68.9	68.4	70.5	72.7	74.6	76.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.3	82.8	81.8	80.1	78.0	76.0	74.5	75.3	77.3	80.4	81.9	82.8
		MCDB	90.4	88.0	86.5	84.4	82.1	79.6	78.2	79.9	82.0	82.4	85.5	86.8
	2%	WB	80.7	81.0	80.2	78.8	76.4	74.3	72.9	73.2	75.3	77.3	79.0	80.5
		MCDB	87.5	87.0	85.8	82.9	80.5	78.5	77.0	77.6	80.5	83.0	84.6	86.8
	5%	WB	79.9	80.1	79.5	77.9	75.3	73.2	71.7	71.8	73.9	76.2	77.8	79.4
		MCDB	86.2	85.8	84.5	81.8	79.3	77.8	76.0	76.7	79.6	82.0	83.8	85.6
	10%	WB	79.1	79.4	78.7	77.0	74.4	72.1	70.6	70.5	72.6	75.1	76.9	78.6
		MCDB	85.0	84.8	83.2	80.8	78.7	76.8	75.4	76.0	78.8	80.9	83.2	84.7
Mean Daily Temperature Range	5% DB	MDBR	12.0	11.5	10.1	9.2	10.1	11.3	12.7	13.0	12.0	11.5	11.6	12.0
		MCDBR	15.3	14.6	12.1	9.9	11.0	11.7	12.9	14.1	13.1	13.2	13.2	14.5
		MCWBR	5.3	5.3	4.9	4.6	5.4	5.7	6.3	6.3	5.4	4.9	4.4	4.9
	5% WB	MCDBR	13.4	12.5	10.9	9.0	8.8	10.2	9.7	11.1	12.2	12.2	12.6	13.4
		MCWBR	5.5	5.3	5.1	4.8	4.8	5.6	5.5	5.8	6.2	6.1	5.8	5.8
Clear-Sky Solar Irradiance	taub	0.402	0.400	0.395	0.388	0.377	0.372	0.359	0.361	0.388	0.402	0.406	0.406	
	taud	2.535	2.546	2.554	2.550	2.546	2.552	2.572	2.551	2.455	2.433	2.453	2.491	
	Ebn at Noon	299	297	292	283	275	271	279	287	290	293	296	298	
	Edh at Noon	36	35	33	32	30	29	29	31	36	38	38	37	
All-Sky Solar Radiation	RadAvg	1859	1785	1671	1620	1434	1292	1391	1666	1980	2150	2179	2050	
	RadStd	164	215	125	150	110	89	95	98	78	120	149	223	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page