

GREEN ISLAND, Australia

WMO: 952890

Lat: 16.759S

Lon: 145.973E

Elev: 10

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	65.7	66.9	N/A	N/A	N/A	N/A	N/A	N/A	40.4	68.9	37.9	70.9	15.0	160	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.4	91.1	N/A	89.4	N/A	87.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.0	33.5	31.3	DB	61.8	93.0	3.2	2.7	59.5	95.0	57.6	96.6	55.8	98.1	53.5	100.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	82.2	81.6	80.2	78.4	75.2	72.5	71.0	71.8	74.9	78.3	80.9	82.5
	DBStd	4.60	2.51	2.54	2.00	1.97	1.98	2.36	1.95	1.97	1.92	2.10	2.25	2.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10018	999	884	935	852	782	676	652	677	748	878	928	1007
	CDD65	4543	534	464	470	402	317	226	187	212	298	413	478	542
	CDH74	33553	5646	4757	4385	3075	1219	284	73	206	1022	2796	4393	5697
	CDH80	7375	1677	1224	733	214	9	1	0	2	48	462	1144	1861
Wind	WSAvg	17.9	14.4	15.3	19.9	21.1	20.9	22.9	20.9	19.4	15.7	15.5	14.3	13.8
Precipitation	PrecAvg	88.1	15.0	20.8	15.7	8.5	4.6	3.3	2.4	2.1	1.4	2.1	3.6	9.0
	PrecMax	140.0	36.7	54.2	41.3	27.3	13.1	9.4	6.0	7.8	4.1	9.0	11.6	20.0
	PrecMin	32.5	3.4	3.2	2.4	0.5	0.3	0.6	0.6	0.0	0.0	0.0	0.0	1.3
	PrecStd	27.4	9.1	13.0	11.1	5.8	2.6	2.0	1.4	1.9	1.6	2.3	3.5	5.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.9	92.4	87.9	84.7	81.0	78.8	77.1	79.2	83.3	87.8	91.0	93.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	90.4	89.0	86.0	83.3	79.7	77.3	75.7	77.6	81.4	85.8	89.0	91.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	88.3	87.1	84.6	82.1	78.8	76.4	74.7	76.2	79.9	84.2	87.3	89.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	86.4	85.3	83.4	81.2	78.0	75.6	73.8	75.1	78.6	82.6	85.6	87.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.3	6.8	5.7	4.9	4.3	3.5	4.5	5.6	7.9	9.3	9.7	9.4
		MCDBR	11.3	9.6	7.6	6.0	5.2	4.2	5.9	7.9	9.6	11.5	12.2	12.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.394	0.396	0.396	0.384	0.372	0.365	0.346	0.352	0.377	0.394	0.397	0.406
	taud		2.584	2.584	2.566	2.583	2.583	2.589	2.626	2.597	2.503	2.478	2.508	2.513
	Ebn at Noon		301	298	291	283	276	272	282	289	292	295	298	298
	Edh at Noon		34	33	33	30	29	27	27	30	35	37	36	36
All-Sky Solar Radiation	RadAvg		1923	1846	1693	1562	1373	1218	1333	1620	1956	2131	2184	2099
	RadStd		164	206	145	149	119	109	99	118	91	126	171	229

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page